



SHREE KRISHNA CABLES

Plot No. 1, Pocket-I
Sector-1, DSIDC Industrial Area
Bawana, Delhi-110039

TEST REPORT Plugs & Socket Outlets As per IS : 1293-2005



RATING **6A 250 V AC**
DATE **4/01/2021**
QUANTITY **4000 Pcs.**

Each Plug/Socket	Each Controls Unit (3 Pcs.)	Every week Test (3 pcs.)	Every Month Test (3 pcs.)	Three monthly Test (3 pcs.)	Yearly Test (3 pcs.)
Cat No. Visual Examination Rating Classification Marking Cl. A, T, B, C	Dimensions Cl. 8	Electric Strength (Flash Test) Cl. 17.3 Protection Against Electric Shock Cl. 18 Protection for earthing Cl. 19 Terminals Cl. 12.3.11 (For Screwless Terminals) Insulation resistance & electric strength Cl. 17 Degree of earthing (concrete) Cl. 16.4.21 Temperature Rise Cl. 16 Withstand Tests Cl. 22	Construction of fixed and portable plug/socket outlets Cl. 12.3.11 Vertical socket outlet Cl. 15 Flexible Cable and their connection Cl. 23 Resistance to Heat Cl. 21 Rubber Corded Carrying Parts and connections Cl. 25 Complete Insulation Resistance Cl. 21 Resistance to tearing Cl. 25	Resistance to abnormal heat, fire & tracking Cl. 25 Tensile Strength Cl. 24 Resistance to ageing, harmful rigors of water and humidity Cl. 16 Additional tests on Pcs. Provided with insulating sleeves Cl. 25 Terminals Cl. 12.3.11	Making & Breaking Capacity Cl. 25 Normal Operation Cl. 21
6A 250V AC, Made In India, ISI Mark L, N, Earth, CM/LM 2679376 KRISHNA	Passed In Dimensions Grade Test OK	With stand Satisfactory Satisfactory N/A IR - 100 M Ω W/S Passed in Test 12°C 13°C 13°C N/A	With stand N/A Passed In Test Satisfactory N/A More than 5mm No Flame No Damage With stand N/A Passed in Test N/A	Passed in Test N/A	Passed in Test N/A

For SHREE KRISHNA C
Anilpaswan