

ALGAL REPORT

CLIENT :	Australian Laboratory Services Pty Ltd SA
LABORATORY NO./BATCH NO. :	7545131 22-57032
LOCALITY :	EM2213883-004
SITE :	Noonameena
SAMPLE :	Surface
DATE SAMPLED :	20/07/2022
DATE ANALYSED :	25/07/2022
SAMPLED BY :	Sample analysed as received

COMMENTS: + Current low levels of algae are insufficient to influence water quality.

Sedgewick-Rafter Vol.(ml)	1.0327	Toxigenic (T) or Potentially toxic (P)	- 200x	- 100x	Total Cell Count (cells/mL)	Individual Algal Unit Volume (um3)	Total Biovolume (mm3/L)
Concentration	1 : 1	*	20	500			
Magnification							
Fields							

BACILLARIOPHYCEAE

Pennales		0	1	2	300	0.00058
Pennales (small <20um)		2	0	97	251	0.02431

CHLOROPHYCEAE

Chlamydomonads		14	0	678	250	0.16946
Chlorococcoids (<10um)		6	0	291	60	0.01743
Oocystis		2	0	97	300	0.02905

TOTAL BGA	0	0.00000
TOTAL TOXIGENIC BGA	0	0.00000
TOTAL POTENTIALLY TOXIC BGA	0	0.00000
TOTAL ALGAE	1165	0.24083

+ The comments are discretionary and are for the purpose of helping to understand WQ implications. The comments are not accredited by NATA.

The biovolume values reported are those derived from documented information, including scientific literature. These are average values and not those measured on individual samples.

A Certificate of analysis will follow, linked by the above batch number. Independent algal reports are forwarded to clients expeditiously to facilitate operational decision making.

* P's and T's denote those cyanobacteria/blue-green algae (BGA) associated with toxin production in Australian waters. Overseas studies have shown other cyanobacteria to produce toxins. All contain lipopolysaccharides (LPS) in their cell wall and many have been found to produce β -N-methylamino-L-alanine (BMAA) and its analogues. Therefore all cyanobacteria could be considered to pose a level of risk.

ANALYST: **Kirsten Mudie (signatory)**
Biologist

REVIEWED: **Adam Deliyiannis (signatory)**
Biologist

DATE: **26/07/2022**

METHOD NO.: MB010/MW024VCA

Page 1 of 1