SECTION 1 — MODEL DESCRIPTION


BUILDING DESCRIPTION

Sector	Commercial-Institutional
Building type	Office
Building subtype	Low-rise (1-3 storeys)
Vintage	After 2010

HVAC SYSTEM

Heating	Electric boiler (hot water) + Hydronic baseboards / radiators
Cooling	Water-cooled chiller
Air distribution	Constant air volume (CAV) (1 air loop)
Heat recovery	None

3D MODEL



Three-dimensional geometric representation of the building model used for energy simulation.

BUILDING CHARACTERISTICS

Total floor area [m²]	2,012
Conditioned floor area [m²]	2,012
Above-ground storeys	2
Climate zone	6A
Weather file	Montreal-Trudeau Intl AP QC CAN CWEC2016 WMO#=716270

WINDOW-TO-WALL RATIO [%]

Average	40.0
North	40.0
East	40.0
South	40.0
West	40.0

ENVELOPE & INTERNAL LOADS

INSULATION & AIR TIGHTNESS

Exterior walls [W/m²K]	0.14
Roof [W/m²K]	0.14
Exposed floors / slabs [W/m²K]	2.94
Infiltration [m³/h/m² ext. surface]	0.82

GLAZING

Glazing U-factor [W/m²K]	1.30
SHGC	0.35


INTERNAL LOADS (MODEL INPUTS)

Occupant density [m²/person]	14.0
Lighting power density [W/m²]	6.7
Equipment power density [W/m²]	7.5

ANNUAL END USES [kWh/year]


END USE	ELECTRICITY	DISTRICT HEATING	TOTAL	kWh/m²
Heating	136,344	0	136,344	67.8
Cooling	22,458	0	22,458	11.2
Interior lighting	110,378	0	110,378	54.9
Plug loads & equipment	84,522	0	84,522	42.0
Fans	10,206	0	10,206	5.1
Pumps	7,683	0	7,683	3.8
Heat rejection	5,139	0	5,139	2.6
Service hot water	0	39,200	39,200	19.5
Total			**415,931**	**206.8**

SHARE OF ANNUAL CONSUMPTION




ENERGY USE INTENSITY	TOTAL CONSUMPTION	ELECTRICITY	NATURAL GAS	OTHER FUELS	PEAK ELECTRIC DEMAND
207 kWh/m²/yr (total area)	415,931 kWh/yr	376,731 kWh/yr	0 kWh/yr	39,200 kWh/yr	142 kW · 70.7 W/m²


MONTHLY CONSUMPTION BY END USE



Monthly energy consumption by end use, all fuels combined.

TYPICAL DAY PROFILES — WEEKDAY VS. WEEKEND





Average hourly demand by end use for winter and summer. Weekdays (Monday to Friday) are shown on the left and weekends and holidays on the right, showing the office occupancy schedule and HVAC set-back.

NOTES & ASSUMPTIONS

- Archetype energy model simulated with OpenStudio/EnergyPlus. Values are model outputs for the reference weather year and are not measured data.
- Energy use intensity is normalized by the total floor area (2,012 m²). Offices are not normalized per unit.
- Archetype: Low-rise office (1-3 storeys), built after 2010.
- HVAC entries marked "(typical)" are not modelled explicitly and come from the archetype assumption table.
- Peak electric demand occurs on 25-DEC-04:45.