

YORK ABSORPTION CHILLER



Project Name :

YORK (Wuxi) Air Conditioning and Refrigeration Co., Ltd.

23-Jun-26

Single-Effect Hot Water Type

Quotation No. : S00000001

1. Specifications

Model		YHAU-CL500EXE-B		Qty	1
Cooling Capacity		1,231 kW	350.0 USRT	(4,200 MBH)	
COP		0.77			
Chilled Water	Fluid	25wt% Propylene glycol			
	Temperature	Inlet 32.0 degC(89.6 degF)		Outlet 22.0 degC(71.6 degF)	
	Flow Rate	109.7 m³/h		(483 GPM)	
	Pipe Diameter (DN PN10)	Inlet 125 A		Outlet 125 A	6 Passes
	Pressure Drop	126 kPa		(42 ft Aq)	
	Max.Working Press.	1,000 kPa.G		(10.0 bar.G)	
	Fouling Factor	0.0180 m²K/kW		(0.00010 ft²h F/BTU)	
Cooling Water	Fluid	25wt% Propylene glycol			
	Amount of heat	2,829 kW		(9,655 MBH)	
	Temperature	Inlet 46.0 degC(114.8 degF)		Outlet 51.0 degC(123.8 degF)	
	Flow Rate	506.8 m³/h		(2,231 GPM)	
	Pipe Diameter (DN PN10)	Inlet 250 A		Outlet 250 A	4 Passes
	Pressure Drop	144 kPa		(48 ft Aq)	
	Max.Working Press.	1,000 kPa.G		(10.0 bar.G)	
Driving Hot Water	Fluid	Fresh Water			
	Amount of heat	1,598 kW		(5,455 MBH)	
	Temperature	Inlet 95.5 degC(203.9 degF)		Outlet 88.0 degC(190.4 degF)	
	Flow Rate	189.0 m³/h		(832 GPM)	
	Pipe Diameter (DN PN10)	Inlet 250 A		Outlet 250 A	6 Passes
	Pressure Drop	85 kPa		(28 ft Aq)	
	Max.Working Press.	1,000 kPa.G		(10.0 bar.G)	
Electric Power	Power Source	3 Ph 3 Wires AC 380 V ±10%		50 Hz ±1Hz	
	Motor Output	Solution Pump 3.7+3 kW		Refrigerant Pump 1.5 kW	
	Power Consumption	Vacuum Pump 0.75 kW			
	Capacity	13.5 kW			
Weight		Operating 24.0 ton	Shipping 19.5 ton		
Insulation Area Approx.		Cold 24 m²	Hot 28 m²		
Water Volume		Chilled 1.00 m³	Cooling 2.27 m³	Driven Hot 1.20 m³	
Painting Color	Chiller Unit	Munsell 4.65BG 4.50/2.85 (Finish coating)			
	Control Panel	Munsell 4.65BG 4.50/2.85 (Inside, Outside)			
Dimensions	Overall (For Reference)	L= 7,000 mm	W= 2,320 mm	H= 3,330 mm	
	Tube Extracting Space	5,500 mm			

2. Operating Condition

Application	For General Air-Conditioning
Installation Condition	Indoors / Non-Explosion-Proof

Pressure Vessel (GB Code)	Not Applicable
---------------------------	----------------

3. Option

1	Copper Tube (0.8mm Thickness) for Evaporator
2	SUS316L Tube (0.8mm Thickness) for Absorber and Condenser
3	
4	
5	
6	
7	
8	

4. Note

- This equipment shall be manufactured based on GB/T 18431(2014).
- Chilled/Hot water and Cooling water quality should be controlled in accordance with GB/T 18431(2014).
- The other items shall be manufacturer standard specifications and scope of supply.
- Pressure drop of driven hot water line is indicated as pressure drop in chiller unit only, therefore this value does not include pressure drop caused by driven hot water control valve.
- Chilled Water : 25wt% Propylene glycol * Density : 1016kg/m³, Viscosity : 0.0020Pa·s, Specific heat : 3.975kJ/kgK, Heat conductivity : 0.00049kW/mK
- Cooling Water : 25wt% Propylene glycol * Density : 1006kg/m³, Viscosity : 0.0011Pa·s, Specific heat : 3.995kJ/kgK, Heat conductivity : 0.00051kW/mK