

YORK ABSORPTION CHILLER



Project Name :

YORK (Wuxi) Air Conditioning and Refrigeration Co., Ltd.

23-Jun-26

Single-Effect Hot Water Type

Quotation No. : S00000001

1. Specifications

Model		YHAU-CL400EXE-B		Qty	1
Cooling Capacity		1,020 kW	290.0 USRT	(3,480 MBH)	
COP		0.77			
Chilled Water	Fluid	25wt% Propylene glycol			
	Temperature	Inlet 32.0 degC(89.6 degF)	Outlet 22.0 degC(71.6 degF)		
	Flow Rate	90.9 m³/h	(400 GPM)		
	Pipe Diameter (DN PN10)	Inlet 100 A	Outlet 100 A	7 Passes	
	Pressure Drop	112 kPa	(37 ft Aq)		
	Max.Working Press.	1,000 kPa.G	(10.0 bar.G)		
	Fouling Factor	0.0180 m²K/kW	(0.00010 ft²h F/BTU)		
Cooling Water	Fluid	25wt% Propylene glycol			
	Amount of heat	2,344 kW	(7,999 MBH)		
	Temperature	Inlet 46.0 degC(114.8 degF)	Outlet 51.0 degC(123.8 degF)		
	Flow Rate	419.9 m³/h	(1,849 GPM)		
	Pipe Diameter (DN PN10)	Inlet 250 A	Outlet 250 A	4 Passes	
	Pressure Drop	90 kPa	(30 ft Aq)		
	Max.Working Press.	1,000 kPa.G	(10.0 bar.G)		
Driving Hot Water	Fluid	Fresh Water			
	Amount of heat	1,324 kW	(4,519 MBH)		
	Temperature	Inlet 95.5 degC(203.9 degF)	Outlet 89.3 degC(192.7 degF)		
	Flow Rate	189.0 m³/h	(832 GPM)		
	Pipe Diameter (DN PN10)	Inlet 250 A	Outlet 250 A	6 Passes	
	Pressure Drop	71 kPa	(24 ft Aq)		
	Max.Working Press.	1,000 kPa.G	(10.0 bar.G)		
Electric Power	Fouling Factor	0.0180 m²K/kW	(0.00010 ft²h F/BTU)		
	Capacity Control Range	100 ~ Approx. 20%			
	Power Source	3 Ph 3 Wires AC 380 V ±10%	50 Hz ±1Hz		
	Motor Output	Solution Pump 3+3 kW	Refrigerant Pump 0.4 kW		
	Vacuum Pump	0.75 kW			
Weight	Power Consumption	10.6 kW			
	Capacity	13.2 kVA			
Insulation Area Approx.		Cold 21 m²	Hot 24 m²		
Water Volume		Chilled 0.84 m³	Cooling 1.94 m³	Driven Hot 0.99 m³	
Painting Color	Chiller Unit	Munsell 4.65BG 4.50/2.85 (Finish coating)			
	Control Panel	Munsell 4.65BG 4.50/2.85 (Inside, Outside)			
Dimensions	Overall (For Reference)	L= 5,900 mm	W= 2,320 mm	H= 3,330 mm	
	Tube Extracting Space	4,400 mm			

2. Operating Condition

Application	For General Air-Conditioning
Installation Condition	Indoors / Non-Explosion-Proof

Pressure Vessel (GB Code)	Not Applicable
---------------------------	----------------

3. Option

1	Copper Tube (0.8mm Thickness) for Evaporator
2	SUS316L Tube (0.8mm Thickness) for Absorber and Condenser
3	
4	
5	
6	
7	
8	

4. Note

- This equipment shall be manufactured based on GB/T 18431(2014).
- Chilled/Hot water and Cooling water quality should be controlled in accordance with GB/T 18431(2014).
- The other items shall be manufacturer standard specifications and scope of supply.
- Pressure drop of driven hot water line is indicated as pressure drop in chiller unit only, therefore this value does not include pressure drop caused by driven hot water control valve.
- Chilled Water : 25wt% Propylene glycol * Density : 1016kg/m³, Viscosity : 0.0020Pa·s, Specific heat : 3.975kJ/kgK, Heat conductivity : 0.00049kW/mK
- Cooling Water : 25wt% Propylene glycol * Density : 1006kg/m³, Viscosity : 0.0011Pa·s, Specific heat : 3.995kJ/kgK, Heat conductivity : 0.00051kW/mK