

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage(-)/Surplus(+) #	Requirement	Freq (Hz)	Demand Met	Shortage(-)/Surplus(+) #	Requirement	Freq (Hz)	Demand Met	Shortage #
48,411	0	48,411	50.06	40,038	0	40,038	50	1,123.73	0

* MW Availability indicated above includes SR ISTS Loss.

2(A)State's Load Deails (At State Periphery) in MUs:

STATE	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL/ NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net MU)	(Net MU)	(Net MU)
ANDHRA PRADESH	101.55	4.85	0	61.58	9.56	1.95	31.24	30.11	-1.13	210.72	209.6	0
KARNATAKA	40.2	38.9	0	69.32	24.23	12	43.48	41.55	-1.93	228.14	226.21	0
KERALA	0	43.08	0	0.62	1.15	0.3	36.61	33.33	-3.28	81.76	78.47	0
PONDICHERRY	0	0	0.54	0	0.04	0	9.99	9.85	-0.14	10.57	10.43	0
TAMILNADU	60.87	27.18	3.66	96.92	30	14.21	139.19	137.62	-1.58	372.03	370.45	0
TELANGANA	73.71	5.86	0	2.59	13.02	4.47	128.86	128.92	0.06	228.51	228.57	0
Region	276.33	119.87	4.2	231.03	78	32.93	389.37	381.38	-8	1,131.73	1,123.73	0

The accuracy of shortage computation depends on timely load shedding details furnished in the web directly by constituents

2(B)State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand (MW)	Day Energy(Net MU)	
	Demand Met	Shortage(-)/Surplus(+) #	Requirement at Evening peak	Demand Met	Shortage(-)/Surplus(+) #	Requirement at Off-Peak		ForeCast (LGBR) (mus)	Deviation[Forecast(LGBR)-Consumption] (mus)
ANDHRA PRADESH	8,562	0	8,562	8,304	0	8,304	8,795	229	-19.4
KARNATAKA	9,388	0	9,388	6,739	0	6,739	9,243	235.12	-8.91
KERALA	4,068	0	4,068	2,542	0	2,542	3,119	81.81	-3.34
PONDICHERRY	469	0	469	351	0	351	418	11.11	-0.68
TAMILNADU	17,498	0	17,498	13,253	0	13,253	15,674	406	-35.55
TELANGANA	8,426	0	8,426	8,849	0	8,849	9,778	230	-1.43
Region	48,411	0	48,411	40,038	0	40,038	47,027	1,193.04	-69.31

2(C)State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met of the day	Time	Shortage(-)/Surplus(+) during at maximum demand	Requirement at the max demand met of the day	Demand Met at maximum requiremnet	Time	Shortage(-)/Surplus(+) during at maximum Requirement	Maximum Requirement of the day	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
AP	9,611	14:54	0	9,611	9,611	14:54	0	9,611	700.29	04:21	-910.27	14:53
KAR	12,218	10:00	0	12,218	12,218	10:00	0	12,218	794.06	17:35	-632.86	11:16
KER	4,089	19:00	0	4,089	4,089	19:00	0	4,089	457.32	05:02	-232.36	10:31
PONDY	504	22:00	0	504	504	22:00	0	504	66.79	00:59	-50.71	18:29
TN	17,786	19:00	0	17,786	17,786	19:00	0	17,786	1,414.57	11:00	-1,568.27	08:46
TG	11,477	07:41	0	11,477	11,477	07:41	0	11,477	1,165.76	17:44	-757.6	07:46
Region	52,372	09:43:29	0	52,372	52,372	09:43:29	0	52,372	1,868	05:01	-2,934.25	07:47

3(A) State Entities Generation:

ANDHRA PRADESH										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
HINDUJA POWER CORPORATION LTD(2 * 520)	1,040	535	529	545	07:03	295	09:48	10.16	9.45	394
KRISHNAPATTANAM (3 * 800)	2,400	964	964	989	21:05	784	16:59	22.55	21.17	882
RAYALASEEMA TPP(1 * 600 + 5 * 210)	1,650	1,159	1,169	1,259	00:28	882	15:22	25.9	23.17	965
SEIL P2 UNIT-2(1 * 660)	660	620	623	630	00:08	336	11:21	13.87	13.03	543
VIJAYAWADA TPS(1 * 800 + 1 * 500 + 6 * 210)	2,560	1,112	1,668	1,807	07:05	1,012	17:59	38.27	34.73	1,447
OTHER THERMAL	0	0	0	0	00:00	0	-	-	-	-
Total THERMAL	8,310	4,390	4,953	-	-	-	-	110.75	101.55	4,231
HAMPI	36	0	0	0	00:00	0	-	0	0	0
LOWER SILERU(4 * 115)	460	252	207	313	18:44	11	11:02	2.71	2.7	113
SRISAILAM RBPH(7 * 110)	770	0	0	107	12:20	0	11:45	0.06	0.05	2
UPPER SILERU(4 * 60)	240	55	0	165	14:56	1	06:57	0.86	0.86	36
OTHER HYDEL	431	37	53	53	00:00	0	-	1.24	1.24	52
Total HYDEL	1,937	344	260	-	-	-	-	4.87	4.85	203
GAUTAMI CCPP(1 * 174 + 2 * 145)	464	0	0	0	00:00	0	11:11	0	0	0
GMR (BARG)(1 * 237)	237	0	0	0	00:00	0	11:11	0	0	0
JEGURUPADU (GAS)(1 * 49.9 + 1 * 75.5 + 2 * 45.8)	217	0	0	0	00:00	0	11:11	0	0	0
JEGRUPADU EXT.(1 * 220)	220	0	0	0	00:00	0	-	-	-	-
KONASEEMA CCPP(1 * 140 + 1 * 145 + 1 * 165)	450	0	0	0	00:00	0	11:11	0	0	0
LANCO (GAS)(1 * 121 + 2 * 115)	351	0	0	0	00:00	0	11:11	0	0	0
RELIANCE ENERGY LTD. (GAS)(1 * 140 + 1 * 80)	220	0	0	0	00:00	0	11:11	0	0	0
SPECTRUM (GAS)(1 * 46.8 + 1 * 68.8 + 2 * 46.1)	208	0	0	0	00:00	0	11:11	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS)(1 * 137 + 1 * 233)	370	0	0	0	00:00	0	-	0	0	0

VIJESWARAM GTS(1 * 112.5 + 1 * 34 + 1 * 59.5 + 2 * 33)	272	0	0	0	00:00	0	11:11	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	-	-	-	-
Total GAS/NAPTHA/DIESEL	3,036	0	0	-	-	-	-	0	0	0
WIND	4,084	2,780	2,121	3,113	16:45	1,939	06:02	61.58	61.58	2,566
SOLAR	3,192	0	0	1,568	11:36	1	06:00	9.56	9.56	398
OTHERS	619	94	83	102	02:06	83	07:01	1.95	1.95	81
Total AP	21,178	7,608	7,417	-	-	-	-	188.71	179.49	7,479

TELANGANA										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BHADRADRI TPS(4 * 270)	1,080	927	425	994	22:27	416	10:54	15.08	13.38	558
KAKATIYA ST1&ST2(1 * 500 + 1 * 600)	1,100	1,024	596	1,032	22:17	576	16:01	18.51	17.35	723
KOTHAGUEDEM TPS(1 * 500 + 1 * 800 + 2 * 250)	1,800	1,202	855	1,265	21:05	824	10:06	24.74	23.13	964
RAMAGUNDAM-B(1 * 62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS(2 * 600)	1,200	600	367	618	20:48	329	09:43	10.29	9.52	397
YADADRI(1 * 800)	800	494	534	638	08:51	373	16:48	11.12	10.34	431
Total THERMAL	6,043	4,247	2,777					79.74	73.72	3,073
NAGARJUNA SAGAR(1 * 110 + 7 * 100.8)	816	212	0	437	21:31	327	10:49	1.34	1.32	55
NAGARJUNA SAGAR (PUMP)(1 * 110 + 7 * 100.8)	816	0	0	99	00:00	0	-	0	2.37	99
SRISAILAM LBPH(6 * 150)	900	0	0	0	00:00	0	11:11	0	0	0
SRISAILAM LBPH(PUMP)(6 * 150)	900	0	0	0	00:00	0	-	0	0	0
OTHER HYDEL	957	188	188	189	00:00	0	11:11	4.56	4.54	189
Total HYDEL	2,673	400	188					5.9	5.86	244
WIND	128	0	0	108	00:00	0	-	2.59	2.59	108
SOLAR	3,811	0	0	1,766	11:15	20	06:00	13.02	13.02	543
OTHERS	252	0	0	186	00:00	0	-	4.47	4.47	186
Total TG	12,907	4,647	2,965					105.72	99.66	4,154

KARNATAKA										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BELLARY TPS(1 * 700 + 2 * 500)	1,700	925	893	967	20:07	610	10:34	21.11	19.61	817
JINDAL(2 * 130 + 4 * 300)	1,460	0	0	213	22:54	0	-	21.58	19.89	40
JINDAL (EXCL. CAPTIVE CONSUMPTION)(2 * 130 + 4 * 300)	1,460	62	36	213	22:54	0	06:22	0.96	0.96	40
RAICHUR TPS(1 * 250 + 7 * 210)	1,720	217	562	572	02:47	159	17:44	9.01	8.04	335
UPCL(2 * 600)	1,200	0	0	0	00:00	0	06:13	0	0	0
YERAMARAS TPS(2 * 800)	1,600	494	534	638	08:51	373	16:48	12.58	11.6	483
Total THERMAL	7,680	1,698	2,025	-	-	-	-	43.66	40.21	886
NAGJHERI(1 * 135 + 5 * 150)	885	389	248	441	06:14	88	11:11	6.33	6.23	260
SHARAVATHI(10 * 103.5)	1,035	669	268	757	19:31	187	10:46	12.63	12.53	522
VARAHI UGPH(4 * 115)	460	42	45	347	21:22	15	08:55	2.78	2.73	114
OTHER HYDEL	2,137	1,366	871	1,366	00:14	687	06:48	17.42	17.42	726
Total HYDEL	4,517	2,466	1,432	-	-	-	-	39.16	38.91	1,622
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	1	11:11	0	0	0
Total GAS/NAPTHA/DIESEL	126	0	0	-	-	-	-	0	0	0
WIND	5,408	3,010	2,461	3,586	11:28	2,222	06:18	69.32	69.32	2,888
SOLAR	6,404	0	0	3,528	12:04	0	06:00	24.23	24.23	1,010
OTHERS	1,832	82	69	1,510	06:22	31	07:34	12	12	1,510
Total KAR	25,967	7,256	5,987	-	-	-	-	188.37	184.67	7,916

KERALA										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
IDDUKKI(6 * 130)	780	728	529	749	12:39	206	11:03	14.75	14.71	613
LOWER PERIYAR (3 * 60)	180	120	119	120	17:34	119	11:06	2.87	2.87	120
SABARIGIRI(2 * 60 + 4 * 55)	340	328	328	331	11:55	217	14:01	7.84	7.83	326
OTHER HYDEL	834	661	639	737	00:36	309	08:01	17.68	17.68	737
Total HYDEL	2,134	1,837	1,615	-	-	-	-	43.14	43.09	1,796
BRAHMAPURAM DGPP (DIESEL)(3 * 21.32)	64	0	0	0	00:00	4	13:07	0	0	0
BSES (NAPTHA)(1 * 35.5 + 3 * 40.5)	157	0	0	0	00:00	0	11:11	-	-	-
KOZHIKODE DPP (DIESEL)(6 * 16)	96	0	0	0	00:00	0	11:11	0	0	0
MPS STEEL CASTINGS(1 * 10)	10	0	0	0	00:00	0	-	-	-	-
RGCCPP KAYAMKULAM (KSEB) - NTPC(1 * 126.38 + 2 * 116.6)	360	0	0	0	00:00	1	08:01	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	11:11	-	-	-
Total GAS/NAPTHA/DIESEL	709	0	0	-	-	-	-	0	0	0
WIND	70	0	0	26	00:00	0	-	0.62	0.62	26
SOLAR	417	0	0	48	00:00	0	-	1.15	1.15	48
OTHERS	20	0	0	13	00:00	0	-	0.3	0.3	13
Total KER	3,350	1,837	1,615	-	-	-	-	45.21	45.16	1,883

TAMIL NADU										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
METTUR TPS(1 * 600 + 4 * 210)	1,440	600	970	1,181	07:58	593	12:30	19.59	17.59	733
NORTH CHENNAI TPS STG-II(2 * 600)	1,200	437	437	437	02:06	437	11:11	9.05	8.04	335
NORTH CHENNAI TPS(3 * 210)	630	461	461	461	02:06	461	11:11	7.01	6.14	256
SEPC(1 * 525)	525	0	0	0	00:00	1	14:16	0	0	0
ST - CMS(1 * 250)	250	169	169	253	10:26	167	13:56	4.72	4.34	181
TUTICORIN(5 * 210)	1,050	402	410	555	14:19	399	08:35	12.22	11.07	461
OTHER THERMAL	0	0	0	570	00:00	0	-	14.61	13.69	570
Total THERMAL	5,095	2,069	2,447					67.2	60.87	2,536
KADAMPARAI (4 * 100)	400	100	98	102	19:08	3	10:51	1.85	1.84	77
KADAMPARAI (PUMP)(4 * 100)	400	0	0	0	00:00	0	-	0	0	0
OTHER HYDEL	1,826	1,359	892	1,359	11:36	77	06:01	25.57	25.34	1,056
Total HYDEL	2,226	1,459	990					27.42	27.18	1,133
BASIN BRIDGE (NAPTHA)(4 * 30)	120	0	0	0	00:00	0	07:19	0	0	0
KOVIL KALAPPAL (GAS)(1 * 37.8 + 1 * 70)	108	0	0	0	00:00	0	14:39	0	0	0
KUTTALAM (GAS)(1 * 37 + 1 * 64)	101	84	86	87	00:12	82	16:29	2	1.86	78
MADURAI POWER CL (DIESEL)(1 * 106)	106	0	0	0	00:00	0	11:11	0	0	0
P P NALLUR (NAPTHA)(1 * 330.5)	331	0	0	0	00:00	0	11:11	0	0	0
SAMALPATTY (DIESEL)(7 * 15.1)	106	0	0	0	00:00	0	11:11	0	0	0
VALATTUR(STGI&STG2)(1 * 32 + 1 * 35 + 2 * 60)	187	141	141	141	02:06	141	11:11	1.94	1.8	75
OTHER GAS/NAPTHA/DIESEL	196	0	0	0	00:00	0	-	0	0	0
OTHER GAS/NAPTHA/DIESEL	166	0	0	0	00:00	0	06:00	0	0	0
Total GAS/NAPTHA/DIESEL	1,421	225	227					3.94	3.66	153
WIND	9,299	4,255	4,096	5,109	13:25	2,514	07:21	96.92	96.92	4,038
SOLAR	8,631	0	0	5,547	12:34	12	06:00	30	30	1,250
OTHERS	2,029	613	613	613	01:23	600	07:19	14.21	14.21	592
Total TN	28,701	8,621	8,373					239.69	232.84	9,702

3(B) Regional Entities Generation										
ISGS										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
KUDGI(3 * 800)	2,400	820	448	820	19:44	427	08:13	12.63	12.11	505
NEYVELI TS I EXPN (2 * 210)	420	277	227	283	21:40	212	10:08	6.3	5.76	240
NEYVELI TS II(7 * 210)	1,470	688	639	750	00:22	532	15:15	18.74	15.01	625
NEYVELI TS II EXPN (2 * 250)	500	150	129	160	16:33	107	13:02	4.17	3.46	144
NNTPS(2 * 500)	1,000	471	445	481	21:56	268	13:11	11.1	9.14	381
NTPC-TELANGANA STPP(2*800)	1,600	1,503	1,257	1,503	20:00	0	-	28.24	26.27	1,095
RAMAGUNDAM(3 * 200 + 4 * 500)	2,600	1,764	990	1,774	21:11	1,006	06:58	32.77	30.13	1,255
SIMHADRI STAGE I(2 * 500)	1,000	917	536	937	21:20	0	17:53	16.25	15.12	630
SIMHADRI STAGE II(2 * 500)	1,000	468	328	479	18:54	50	17:53	8.66	7.95	331
TALCHER ST2(4 * 500)	2,000	1,317	1,335	1,376	07:55	434	17:37	32.8	30.93	1,289
Total THERMAL	13,990	8,375	6,334	-	-	-	-	171.66	155.88	6,495
KAIGA STG1(2 * 220)	440	0	0	18	00:00	0	11:11	0	-0.42	-18
KAIGA STG2(2 * 220)	440	212	215	217	10:06	204	11:44	5.74	5.16	215
KUDANKULAM(2 * 1000)	2,000	2,050	2,053	2,065	01:13	1,979	12:51	49.42	46.37	1,932
MAPS(2 * 220)	440	241	245	250	07:58	184	17:52	5.31	4.39	183
Total NUCLEAR	3,320	2,503	2,513	-	-	-	-	60.47	55.5	2,312
Total ISGS	17,310	10,878	8,847					232.13	211.38	8,807

JOINT VENTURE										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
NTPL(2 * 500)	1,000	924	504	965	22:27	423	13:09	16.11	15.17	632
VALLUR TPS(3 * 500)	1,500	864	512	926	22:02	497	10:42	16.38	14.84	618
Total THERMAL	2,500	1,788	1,016	-	-	-	-	32.49	30.01	1,250
Total JOINT_VENTURE	2,500	1,788	1,016					32.49	30.01	1,250

IPP UNDER OPEN ACCESS										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
COASTAL ENERGEN(2 * 600)	1,200	370	569	783	17:12	518	14:21	14.42	13.16	548
IL&FS(2 * 600)	1,200	759	517	1,025	23:58	515	11:00	17.28	15.84	660
JINDAL POWER LIMITED (SIMHAPURI UNIT)(4 * 150)	600	267	142	484	17:50	113	10:54	4.48	4.06	169
MEENAKSHI ENERGY LTD(2 * 150)	300	147	83	165	20:25	0	17:47	4.58	3.97	165
SEIL P1(2 * 660)	1,320	1,258	994	1,268	19:46	490	15:21	22.21	20.87	870
SEIL P2 UNIT-1(1 * 660)	660	623	621	628	02:06	414	11:45	14.58	13.88	578
Total THERMAL	5,280	3,424	2,926	-	-	-	-	77.55	71.78	2,990
LKPPL ST2(1 * 133 + 1 * 233)	366	0	0	0	00:00	3	12:51	0	0	0
LKPPL ST3(2 * 133 + 2 * 233)	732	0	0	0	00:00	0	-	0	0	0
Total GAS/NAPTHA/DIESEL	1,098	0	0	-	-	-	-	0	0	0
Total REGIONAL_IPP	6,378	3,424	2,926					77.55	71.78	2,990

RENEWABLE WIND										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
GADAG_GREENINFRA_W	55	0	0	0	00:00	0	07:56	0	0	0
GADAG_RSPL_W	92	0	0	0	00:00	0	07:56	0	0	0
GADAG_VENA_W	133	0	0	0	00:00	0	-	0	0	0
GREEN INFRA(1 * 249.90)	250	206	223	246	00:33	103	07:44	5.23	5.23	218
HIRIYUR_OSTRO(1 *300.3)	300	0	0	0	00:00	0	11:14	0	0	0
HIRIYUR_ZREPL_W	66	64	60	85	20:00	0	-	2.04	2.04	85
JSW RENEW ENERGY TWO LTD	300	157	171	265	00:41	15	08:02	3.97	3.97	165
KARUR_JSWRETWO_W	150	84	84	84	20:00	0	-	2.02	2.02	84
KOPPAL_AYANASIX_W	300	285	228	285	20:00	0	-	2.68	2.68	112
KOPPAL_RENEWOJAS_W	308	0	217	316	12:47	239	13:13	6.27	6.27	261
KOPPAL_RENEWROSHNI_W	291	240	161	256	07:35	203	12:36	5.42	5.42	226
KURNOOL_AMGREEEN_W	280	0	0	250	00:00	0	11:11	6	6	250
MYTRA(1 * 250)	250	48	41	215	00:14	19	07:15	1.24	1.24	52
ORANGE(1 * 200)	200	155	164	189	00:46	0	09:50	3.69	3.69	154
PGLR_SREPL(1 * 300)	300	231	249	266	06:26	213	07:47	5.79	5.79	241
TUTICORINJSWRENEWW(1 * 51.3)	500	241	243	241	20:00	0	-	5.07	5.07	211
VIVID SOLAIRE (BEETAM)(1 * 220)	220	195	196	215	23:05	135	10:14	4.78	4.78	199
Total RENEWABLE_WIND	3,995	1,906	2,037					54.2	54.2	2,258

RENEWABLE SOLAR										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Get(MU)	
NP_KUNTA										
ANP_ADANIAPSEVEN(5 * 50)	250	0	0	219	11:50	0	06:00	1.11	1.11	93
ANP_ATHENA BIWADI(1 * 50)	50	0	0	39	11:31	1	06:20	0.22	0.22	18
ANP_ATHENA HISAR(1 * 50)	50	0	0	42	11:37	0	06:00	0.21	0.21	18
ANP_ATHENA KARNAL(1 * 50)	50	0	0	42	11:30	0	06:00	0.2	0.2	17
ANP_AYANA(1 * 250)	250	0	0	196	11:15	0	06:00	1.1	1.1	92
ANP_AZURE(1 * 50)	50	0	0	32	11:53	0	06:00	0.18	0.18	15
ANP_IGS1(1 * 50)	50	0	0	43	11:30	0	06:00	0.2	0.2	17
ANP_IGS2(1 * 50)	50	0	0	40	11:29	0	06:00	0.21	0.21	18
ANP_NTPC(5 * 50)	250	0	0	126	11:23	1	06:02	0.66	0.66	55
ANP_TATA(2 * 50)	100	0	0	68	11:30	0	06:00	0.36	0.36	30
SPRING ANG ITRA(1 * 250)	250	0	0	0	00:00	0	11:14	0	0	0
PAVAGADA										
PVG_ADYAH(6 * 50)	300	0	0	50	00:00	0	11:14	1.19	1.19	99
PVG_AMPLUS PAVAGADA(1 * 50)	50	0	0	49	11:09	1	06:00	0.26	0.26	22
PVG_AMPLUS TUMKUR(1 * 50)	50	0	0	49	11:40	1	06:00	0.25	0.25	21
PVG_AVAADA SOLAR(3 * 50)	150	0	0	125	11:22	1	06:00	0.67	0.67	56
PVG_AVAADA SOLARISE(3 * 50)	150	0	0	135	11:10	1	06:00	0.68	0.68	57
PVG_AZURE POWER EARTH (2 * 50)	100	0	0	72	11:54	1	06:00	0.38	0.38	32
PVG_FORTUM FIN SURYA(2 * 50)	100	0	0	84	11:10	1	06:00	0.41	0.41	34
PVG_IRCON_S	100	0	0	33	00:00	0	-	0.79	0.79	66
PVG_KREDL(1 * 50)	50	0	0	40	11:20	1	06:00	0.23	0.23	19
PVG_PARAMPUJYA(3 * 50)	150	0	0	124	11:07	1	06:00	0.62	0.62	52
PVG_RENEW TN2(1 * 50)	50	0	0	45	11:11	1	06:00	0.22	0.22	18
PVG_SBG ENERGY(4 * 50)	200	0	0	194	11:44	0	06:00	0.95	0.95	79
PVG_SPRING SOLAR INDIA(5 * 50)	250	0	0	206	11:51	1	06:00	1.14	1.14	95
PVG_TATA RENEWABLES(8 * 50)	400	0	0	327	11:16	1	06:00	1.7	1.7	142
PVG_YARROW(1 * 50)	50	0	0	48	11:39	1	06:00	0.24	0.24	20
OTHER										
GADAG_VENA_S	31	0	0	0	00:00	0	-	0	0	0
GRT(1 * 150)	150	0	0	131	13:16	0	06:01	0.7	0.7	58
KOPPAL_KLEIO_S	105	0	0	13	00:00	0	-	0.3	0.3	25
KOPPAL_RENEWOJAS_S	81	0	0	14	00:00	0	11:11	0.34	0.34	28
KOPPAL_SRIIPL_S	159	0	0	34	00:00	0	-	0.81	0.81	68
KURNOOL_AMGREEN_S	550	0	0	0	00:00	0	-	0	0	0
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	228	13:07	1	06:00	1.18	1.18	98
RAMANGUNDAM (SOLAR)(1 * 100)	100	0	0	91	11:09	0	06:00	0.42	0.42	35
SIMHADRI (SOLAR)(1 * 25)	25	0	0	0	00:00	0	08:13	0	0	0
Total	4,981	0	0					17.93	17.93	1,497

Total ISGS IPP Thermal	21,770	13,587	10,276					281.7	257.67	
STATE THERMAL	27,928	12,404	12,202					301.35	276.35	
Total CPP Import										
Total ISGS & IPP Hydro										
HYDEL	13,487	6,506	4,485	-	-	-	-	120.8	119.89	
GAS/NAPTHA/DIESEL	6,826	225	227	-	-	-	-	4.52	4.2	
NUCLEAR	3,320	2,502	2,513	-	-	-	-	60.47	55.51	
WIND	22,984	11,951	10,715	-	-	-	-	285.23	285.23	
SOLAR	27,538	0	0	-	-	-	-	95.93	95.93	
OTHERS	4,752	789	765	-	-	-	-	32.93	32.93	

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	-	-	-	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	502	502	-	499	0	12.05	-12.05
3	765KV-SRIKAKULAM-ANGUL	1,476	1,242	2,796	-	37.99	0	37.99
4	HVDC500KV-TALCHER-KOLAR_DC	791	1,382	1,383	-	26.81	0	26.81
Sub-Total EAST REGION		2,769	3,126	4,179	499	64.8	12.05	52.75
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	-	-	0	0	0
2	220KV-AMBEWADI-XELDEM	84	69	-	101	0	1.95	-1.95
3	220KV-CHIKKODI-MUDASANGI	0	0	0	-	-	-	-
4	220KV-CHIKKODI-TALANGADE	-	-	-	-	-	-	-
5	220KV-LOWER_SILERU-BARSUR	-	-	-	-	-	-	-
6	400KV-BHADRAVTAHI-RAMAGUNDAM	1,024	1,023	1,056	-	0	22.81	-22.81
7	400KV-KUDGI_PG-KHOLAPUR_PG	1,453	1,600	-	2,067	0	34.05	-34.05
8	765KV-NIZAMABAD-WARDHA	412	360	2,531	-	19.9	0	19.9
9	765KV-RAICHUR_PG-SHOLAPUR	1,432	2,124	-	2,559	0	32.86	-32.86
10	765KV-WARANGAL(NEW)-WARORA	353	186	2,447	-	17.26	0	17.26
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	623	429	-	562	23.31	0	23.31
Sub-Total WEST REGION		5,381	5,791	6,034	5,289	60.47	91.67	-31.2
TOTAL IR EXCHANGE		8,150	8,917	10,213	5,788	125.27	103.72	21.55

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	T-GNA Bilateral	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
SR-ER	6.51	-7.69	0	0	0	0	-34.6	21.826	56.426
SR-WR	-5.85	-42.84	0.39	60.12	0	9.42	21.24	-31.205	-52.445
Total	0.66	-50.53	0.39	60.12	0	9.42	-13.36	-9.379	3.981

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0	15.752	66.424	43.762	17.824

<-----Frequency (Hz)----->

Maximum		Minimum		Average Frequency	Freq Variation Index	Standard Deviation	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time				Max.	Min.
50.327	23:57:20	49.722	12:38:50	49.987	0.079	0.088	50.27	49.8

6.Voltage Profile: 400kV

STATION	Maximum		Minimum		Voltage (in %)			
	VOLTAGE	TIME	VOLTAGE	TIME	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	424	23:28	400	12:54	0	0	9.306	0
GOOTY - 400KV	421	23:55	392	11:21	0	0	.347	0
HIRIYUR - 400KV	420	02:01	394	11:28	0	0	0	0
KAIGA - 400KV	420	02:01	393	11:56	0	0	.417	0
KOLAR_AC - 400KV	422	02:04	393	08:44	0	0	8.125	0
KUDANKULAM - 400KV	410	01:07	399	11:25	0	0	0	0
SHANKARAPALLY - 400KV	416	02:00	403	11:16	0	0	0	0
SOMANAHALLI - 400KV	418	02:00	389	09:18	0	1.528	0	0
SRIPERUMBADUR - 400KV	416	03:19	392	11:20	0	0	0	0
TRICHY - 400KV	416	19:59	396	11:19	0	0	0	0
TRIVANDRUM - 400KV	421	01:07	402	11:28	0	0	.069	0
VIJAYAWADA - 400KV	418	17:32	392	11:42	0	0	0	0

6.1 Voltage Profile: 220kV

STATION	Maximum		Minimum		Voltage (in %)			
	VOLTAGE	TIME	VOLTAGE	TIME	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	235	23:34	221	11:36	0	0	0	0
GOOTY - 220KV	228	23:58	211	11:20	0	0	0	0
HIRIYUR - 220KV	226	23:58	208	11:56	0	4.653	0	0
KAIGA - 220KV	234	14:21	234	14:21	0	0	0	0
KOLAR_AC - 220KV	230	02:03	212	09:13	0	0	0	0
SOMANAHALLI - 220KV	228	02:05	208	09:19	0	7.014	0	0
SRIPERUMBADUR - 220KV	0	18:02	0	18:02	N/A	N/A	N/A	N/A
TRICHY - 220KV	230	20:00	216	11:20	0	0	0	0
TRIVANDRUM - 220KV	231	01:05	220	11:28	0	0	0	0
VIJAYAWADA - 220KV	230	23:58	224	11:41	0	0	0	0

6.2 Voltage Profile: 765kV

		Maximum		Minimum		Voltage (in %)			
STATION		VOLTAGE	TIME	VOLTAGE	TIME	< 720	< 750	> 780	> 800
KURNOOL - 765KV		795	23:58	751	11:20	0	0	30.35	0
NIZAMABAD - 765KV		802	23:34	0	17:35	0	0	70.56	2.01
RAICHUR_PG - 765KV		794	23:31	750	11:39	0	.07	34.51	0
SRIKAKULAM - 765KV		792	23:59	756	07:19	0	0	42.57	0

7.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (Mts)	FRL (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (Mus)	Usage (Mus)	"Prog. Inflow (Mus)"	"Prog. Usage (Mus)"
NILAGIRIS	0	0	1,504	0	1,010	0	29	17.96	7.46	448.37	147.91
IDUKKI	694.94	732.43	2,148	717	1,030	709.53	626	12.18	16.54	458.53	341.41
JALAPUT	818.39	838.4	534	831.11	260	822.21	79	11.43	2.33	23.29	48.21
N.SAGAR	155.45	179.9	1,398	156.76	41	153.71	0	1.7	1.95	38.21	38.6
SRISAILAM	243.84	270.7	1,392	260.94	362	248.41	46	17.13	0	261.48	40.03
SUPA	495	564	3,159	532.37	951	525.75	659	18.01	6.63	161.31	189.16
LINGANAMAKKI	522.73	554.5	4,557	541.11	1,415	531.74	420	63.44	12.61	520.44	344.13
KAKKI	908.3	981.45	916	966.28	471	944.97	167	10.73	7.02	232.6	163.35
TOTAL	-	-	15,608	-	5,540	-	2,026	152.58	59.69	2,144.23	1,355.68

8(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AP	-498.62	-3	15.82	0	155.97	0	0	0	0	0	0	0	0
KARNATAKA	-548.7	-142.07	-9.75	0	-27.1	0	0	0	0	0	0	0	0
KERALA	-176.64	0	-4.8	0	-6.9	0	0	0	0	0	0	0	0
PONDICHER ..	0	0	0	0	-31	0	0	0	0	0	0	0	0
TAMILNADU	-368.08	55.57	98.45	0	-610.3	0	0	0	0	0	0	0	0
TELANGANA	-1,068.12	0	2,926.32	0	820.84	0	0	0	0	0	0	0	0
TOTAL	-2,660.16	-89.5	3,026.04	0	301.51	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AP	-907.75	0.69	-16.4	0	574.59	0	0	0	0	0	0	0	0
KARNATAKA	-548.72	-170.07	-197.48	0	-18.55	0	0	0	0	0	0	0	0
KERALA	-176.64	66.3	224.43	0	516.01	0	0	0	0	0	0	0	0
PONDICHER ..	0	0	14.5	0	0	0	0	0	0	0	0	0	0
TAMILNADU	2,421.06	112.48	221.33	0	-298.38	0	0	0	0	0	0	0	0
TELANGANA	-1,068.12	81.27	1,243.51	0	-300.6	0	0	0	0	0	0	0	0
TOTAL	-280.17	90.67	1,489.89	0	473.07	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA Schedule	T-GNA Bilateral	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
ANDHRA PRADESH	32.56	-11.78	0.77	5.75	0	3.94	31.24
KARNATAKA	65.93	-12.95	-3.97	-5.05	0	-0.48	43.48
KERALA	37.2	-2.72	0.94	0.85	0	0.34	36.61
PONDICHERY	9.99	0	0.12	0.07	0	-0.19	9.99
TAMILNADU	146.08	10.8	1.91	-6.22	0	-13.38	139.19
TELANGANA	52.4	-10.66	1.87	63.97	0	21.28	128.86
TOTAL	344.16	-27.31	1.64	59.37	0	11.51	389.37

8(B). Short-Term Open Access Details

State	ISGS+GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ANDHRA PRADESH	2,422.84	438.48	-16.06	-922.26	75.88	-7.7	0	0	0	0	871.58	-23.65	0	0
KARNATAKA	4,356.53	1,452.83	-523.42	-548.77	-105.58	-273.07	0	0	0	0	662.95	-757.11	0	0
KERALA	1,982.34	1,283.9	-57.76	-176.64	79.15	0	0	0	0	0	611.57	-184.8	0	0
PONDICHERY	459.81	362.23	0	0	62.82	0	0	0	0	0	35.03	0	0	0
TAMILNADU	7,279.42	4,311.47	2,446.97	-368.08	153.17	0	0	0	0	0	557.83	-1314.96	0	0
TELANGANA	3,657.94	361.34	16.88	-1,068.12	167.67	-0.3	0	0	0	0	4575.43	742.18	0	0

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ANDHRA PRADESH	0	0	0	0	0	0	0	0	762.41	19.1	0	0	0	0
KARNATAKA	0	0	0	0	0	0	0	0	8.31	-150.85	0	0	0	0
KERALA	0	0	0	0	0	0	0	0	674.99	-273.43	0	0	0	0
PONDICHER ..	0	0	0	0	0	0	0	0	26.09	-66	0	0	0	0
TAMILNADU	0	0	0	0	0	0	0	0	47.21	-1,973.42	0	0	0	0
TELANGANA	0	0	0	0	0	0	0	0	2,194.09	-400.6	0	0	0	0

9. Synchronisation of new generating units :

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time
-------	--------------	-------	----------------------	------	------

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation :

11.Significant events (If any):

12.Constraints and instances of congestion in the transmission system

1) 400KV Gadag-Kudgi PG Line-01 & 02 has tripped on 13.05.2025 at 15:00 hrs due to tower collapse at location 16kms from Kudgi(New Narendra) end. (Gadag green infra, Gadag veena and RSRPL RE generation affected)
2) 400kV Kalavindapattu-Thiruvellam lines 01& 02 Shutdown availed due to Chennai - Bangalore Express Highway construction works - NHAI Line Diversion works. Expected revival date is 24-06-2025

13. Weather Condition:

Telangana: Light rains reported in Nizamabad,Karimnagar,Kamareddy districts.Kerala:Light rains reported in the state.AP:Light rains reported in Vishakapatnam,East &West Godavari,Srikakulam distircts.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				Reason
	Energy	Maximum	At the time of maximum demand	Wind		Solar		
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
ANDHRA PRADESH	0	0	0	0	0	0	0	
KARNATAKA	0	0	0	0	0	0	0	
KERALA	0	0	0	0	0	0	0	
TAMILNADU	0	0	0	0	0	0	0	
PONDICHERRY	0	0	0	0	0	0	0	
TELANGANA	0	0	0	0	0	0	0	

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance
ANDHRA PRADESH	0	2	1	0	0	0	0	0	0	0	0	0
KARNATAKA	0	1	0	0	0	0	0	0	0	0	0	0
KERALA	0	0	0	0	0	0	0	0	0	0	0	0
TAMILNADU	0	4	1	2	0	0	0	0	0	0	0	0
PONDICHERRY	0	0	0	0	0	0	0	0	0	0	0	0
TELANGANA	0	3	0	0	0	0	0	0	0	0	0	0

REMARKS:

Shift In Charge