



GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTH EASTERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTH EASTERN REGION

Power Supply Position in NORTH EASTERN Region For 23-Jun-2025

Date of Reporting:24-Jun-2025

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
3371	0	3371	49.96	2737	0	2737	49.99	67.48	0

2(A)State's Load Details (At State Periphery) in MUs:

STATE	State's Control Area Generation (Net MU)						TOTAL STATE	Net SCH	Drawal	UI	Availability	Demand Met	Shortage
	THERMAL	HYDRO	GAS/DIESEL/ NAPTHA	WIND	SOLAR	OTHERS	GENERATION(MU)	(Net Mu)	(Net Mu)	(Net Mu)	(Net MU)	(Net MU)	(Net MU)
ARUNACHAL PRADESH	0	0.36	0	0	0	0	0.36	3.11	2.8	-0.31	3.47	3.16	0
ASSAM	0	1.47	3.88	0	0.41	0	5.76	37.93	38.07	0.14	43.69	43.83	0
MANIPUR	0	0	0	0	0	0	0	3.06	3.15	0.09	3.06	3.15	0
MEGHALAYA	0.02	6.55	0	0	0	0	6.57	-0.82	-0.95	-0.13	5.75	5.62	0
MIZORAM	0	1.25	0	0	0.05	0	1.3	0.8	0.47	-0.33	2.1	1.77	0
NAGALAND	0	1.25	0	0	0	0	1.25	2.68	2.61	-0.07	3.93	3.86	0
TRIPURA	0	0	1.7	0	0	0	1.7	5.26	5.25	-0.01	6.96	6.09	0
Region	0.02	10.88	5.58	0	0.46	0	16.94	52.02	51.4	-0.62	68.96	67.48	0

2(B)State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Day Energy(Net MU)	
	Demand Met	Shortage	Requirement at Evening peak	Demand Met	Shortage	Requirement at Off-Peak	ForeCast (LGBR) (mus)	Deviation]Forecast(LGBR)-Consumption] (mus)
ARUNACHAL PRADESH	156	0	156	113	0	113	3.1	-0.06
ASSAM	2152	0	2152	1928	0	1928	50.23	6.4
MANIPUR	175	0	175	96	0	96	3.36	0.21
MEGHALAYA	324	0	324	193	0	193	5.67	0.05
MIZORAM	103	0	103	47	0	47	2.01	0.24
NAGALAND	130	0	130	98	0	98	2.92	-0.94
TRIPURA	331	0	331	262	0	262	6.19	0.1
Region	3371	0	3371	2737	0	2737	73.48	6

2(C)State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day			
	Maximum Demand Met of the day	Time	Shortage during maximum demand	Requirement at max demand met of the day	Demand Met at maximum requiremnet	Time	Shortage during maximum Requirement	Maximum Requirement of the day
ARUNACHAL PRADESH	174	20:07	0	174	174	20:07	0	174
ASSAM	2327	20:38	0	2327	2327	20:38	0	2327
MANIPUR	211	18:59	0	211	211	18:59	0	211
MEGHALAYA	339	19:10	0	339	339	19:10	0	339
MIZORAM	122	18:53	0	122	122	18:53	0	122
NAGALAND	172	18:08	0	172	172	18:08	0	172
TRIPURA	330	19:30	0	330	330	19:30	0	330
Region	3562	19:02	0	3562	3562	19:02	0	3562

3(A) State Entities Generation:

ARUNACHAL PRADESH									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
DIKSHI HEP (3*8)	24	27	11	28	23:00	0	-	0.36	15
Total HYDEL	24	27	11	-	-	-	-	0.36	15
Total ARUNACHAL PRADESH	24	27	11	-	-	-	-	0.36	15

ASSAM									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
KARBI LANGPI HEP (2*50)	100	88	50	94	03:00	42.51	06:00	1.39	57.92
MYNTRENG HEP (3*1.5+3*3)	13.5	3	3	3	20:00	2.73	06:00	0.07	2.92
OTHER HYDEL (1*4.05)	4.05	0	0	0	03:00	0	17:00	0.01	0.42
Total HYDEL	117.55	91	53	-	-	-	-	1.47	61.26
LAKWA REPLACEMENT PP (7*9.965)	69.76	56	55	56	19:00	55.14	08:00	1.32	55
LAKWA TPS (3*20+1*20.4)	80.4	0	37	38	01:00	0	06:00	0.03	1.25
NAMRUP REPLACEMENT PP (1*62.25+1*36.15)	98.4	92	92	93	23:36	91.3	09:00	2.09	87.08
NAMRUP TPS (1*17+1*15+1*9)	41	20	20	20	01:00	20	06:00	0.44	18.33
Total GAS/NAPTHA/DIESEL	289.56	168	204	-	-	-	-	3.88	161.66
SOLAR (1*5+1*25+1*25+1*15+1*10+1*70+1*25+1*4+1*20)	199	0	0	66	11:00	1.56	18:00	0.41	17.08
Total ASSAM	606.11	259	257	-	-	-	-	5.76	240

MEGHALAYA									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
PRIVATE_GENERATORS (THERMAL) (1*12+1*51)	63	1	3	4	02:00	0	07:00	0.02	0.83
Total THERMAL	63	1	3	-	-	-	-	0.02	0.83
GANOL HEP (3*7.5)	22.5	22	22	23	05:00	0	13:00	0.39	16.25
LAKROH (1*1.5)	1.5	1	0	1	14:00	0	06:00	0.01	0.42
MYNDTU LESHKA (3*42)	126	119	119	119	10:00	118.93	11:00	2.85	118.75
NEW UMTRU (2*20)	40	39	40	40	01:00	39.11	12:00	0.95	39.58
SONAPANI HEP (1*1.5)	1.5	1	1	1	13:00	0.81	06:00	0.02	0.83
UMIAM ST I (4*9)	36	35	24	35	20:00	18.77	06:00	0.76	31.67
UMIAM ST II (2*10)	20	19	13	20	08:00	9.24	06:00	0.41	17.08
UMIAM ST III (2*30)	60	0	0	0	00:00	0	06:00	0	0
UMIAM ST IV (2*30)	60	48	59	60	02:00	29.68	16:00	1.16	48.33
Total HYDEL	367.5	284	278	-	-	-	-	6.55	272.91
Total MEGHALAYA	430.5	285	281	-	-	-	-	6.57	273.74

MIZORAM									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
SERLUI-B (4*3)	12	0	0	0	0	0	-	0	0
Tuirial (2*30)	60	50	52	54	00:01	0	-	1.25	52.08
OTHER HYDEL (1*3+1*4+1*5+1*1.05+1*5+1*3+1*0.6)	21.65	0	0	0	0	0	-	0	0
Total HYDEL	93.65	50	52	-	-	-	-	1.25	52.08
SOLAR (1*20+1*2)	22	0	0	9	10:00	0	-	0.05	2.08
Total MIZORAM	115.65	50	52	-	-	-	-	1.3	54.16

NAGALAND									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
LIKIMRO HEP (3*8)	24	18	21	21	03:00	0	-	1.25	52.08
Total HYDEL	24	18	21	-	-	-	-	1.25	52.08
Total NAGALAND	24	18	21	-	-	-	-	1.25	52.08

TRIPURA									
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
Gumti (3*5)	15	0	0	0	00:00	0	06:00	0	0
Total HYDEL	15	0	0	-	-	-	-	0	0
Baramura (2*21)	42	0	0	0	00:00	0	06:00	0	0
Monarchak(Thermal) (1*65.42+1*35.58)	101	53	53	54	11:00	52.45	06:00	1.29	53.75
Rokhia (3*21)	63	17	17	18	00:00	15.0506	06:00	0.41	17.08
Total GAS/NAPTHA/DIESEL	206	70	70	-	-	-	-	1.7	70.83
SOLAR (1*5)	5	0	0	3	10:00	0	18:00	0	0
Total TRIPURA	226	70	70	-	-	-	-	1.7	70.83

3(B) Regional Entities Generation

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG	Schedule	UI	RRAS
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	(MW)	(Mu)	(MU)	Sch
NEEPCO												
Agartala Gas Turbine CCPP (1*21+2*25.5)	135	64	40	64	01:00	38.66	06:00	1.08	45	1	0.08	0.03
Assam Gas Based PP (6*33.5+3*30)	291	196	130	196	01:00	120.64	06:00	3.41	142.08	3.16	0.25	0.11
Doyang HEP (3*25)	75	53	19	55	07:00	0	06:00	0.72	30	0.7	0.02	0
Kameng HEP (4*150)	600	457	458	459	08:00	0		10.91	454.58	10.8	0.11	0
Khandong HEP (2*25)	50	0	0	0	0	0	06:00	0	0	0	0	0
Kopili HEP (4*50)	200	197	148	205	06:00	0	06:00	2.5	104.17	2.51	-0.01	0
Kopili-2 HEP (1*25)	25	0	0	0	0	0	06:00	0	0	0	0	0
Pare HEP (2*55)	110	110	56	110	21:00	0		1.58	65.83	1.58	0	0
Ranganadi HEP (3*135)	405	268	130	268	03:00	260.72	08:00	4.17	173.75	4.1	0.07	0
Sub-Total	1891	1345	981	1357	0	1357	0	24.37	1015.41	23.85	0.52	0.14
NHPC												
Loktak HEP (3*35)	105	104	104	104	01:00	183.4	07:00	2.4	100	2.41	-0.01	0
Sub-Total	105	104	104	104	0	104	0	2.4	100	2.41	-0.01	0
NTPC												
Bongaigaon TPP (3*250)	750	750	418	750	22:00	373.08	11:00	10.67	444.58	10.64	0.03	-0.01
Sub-Total	750	750	418	750	0	750	0	10.67	444.58	10.64	0.03	-0.01
OTPCCL												
Palatana (2*232.2+2*131.1)	726.6	469	483	483	03:00	423.2	06:00	10.72	446.67	10.69	0.03	0
Sub-Total	726.6	469	483	483	0	483	0	10.72	446.67	10.69	0.03	0
Total	3472.6	2668	1986					48.16	2006.66	47.59	0.57	0.13

Station/Constituents	Inst. Capacity	N/A	N/A	Day Peak		Min Generation (06:00-18:00)		Day Energy	AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	(MU)	
Total ISGS and IPP Thermal	750	750	418					10.67	444.58
Total State Thermal	63	1	3					0.02	0.83
Total ISGS and IPP Gas	1152.6	729	653					15.21	633.75
Total State Gas	495.56	238	274					5.58	232.49
Total ISGS and IPP Hydro	1570	1189	915					22.28	928.33
Total State Hydro	641.7	470	415					10.88	453.33
Total Solar Generation	226	0	0					0.46	19.16

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between BHUTAN and NORTH_EAST REGION								
1	132KV-RANGIA-DEOTHANG	47	59	61	0	1.17	-	1.17
2	132KV-RANGIA-MOTONGA	-	-	-	-	-	-	0
3	132KV-SALAKATI-GELEPHU	45	46	53	0	1.17	-	1.17
Sub-Total BHUTAN		92	105	114	0	2.34	0	2.34
Import/Export between EAST REGION and NORTH_EAST REGION								
1	220KV-SALAKATI-ALIPURDUAR-1	30	35	55	0	0.77	-	0.77
2	220KV-SALAKATI-ALIPURDUAR-2	30	35	55	0	0.77	-	0.77
3	400KV-BONGAIGAON-ALIPURDUAR-1	164	161	274	0	4.15	-	4.15
4	400KV-BONGAIGAON-ALIPURDUAR-2	164	161	275	0	4.15	-	4.15
5	400KV-BONGAIGAON-NEW SILIGURI-1	37	34	127	51	0.74	-	0.74
6	400KV-BONGAIGAON-NEW SILIGURI-2	37	34	127	52	0.74	-	0.74
Sub-Total EAST REGION		462	460	913	103	11.32	0	11.32
Import/Export between NORTH REGION and NORTH_EAST REGION								
1	HVDC800KV-BISWANATH CHARIALI-AGRA	-353	-353	0	505	-	8.12	-8.12
Sub-Total NORTH REGION		-353	-353	0	505	0	8.12	-8.12
TOTAL IR EXCHANGE		201	212	1027	608	13.66	8.12	5.54

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve)/Export =(-ve)) in MU

	ISGS+GNA+URS Schedule	T-GNA Bilateral	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NER-ER	10.67	3.69	1.98	-9.88	0	4.26	6.03	5.54	-0.49
Total	10.67	3.69	1.98	-9.88	0	4.26	6.03	5.54	-0.49

4(C) Inter-National Exchanges with Bangladesh (Import=(+ve)/Export =(-ve)) [Linkwise]

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
1	132KV-SURAJMANI NAGAR-COMILLA(BANGLADESH)-	-19	-19	0	21	-	0.43	-0.43
2	132KV-SURAJMANI NAGAR-COMILLA(BANGLADESH)-	-19	-19	0	21	-	0.43	-0.43
TOTAL INT. EXCHANGE		-38	-38	0	42	0	0.86	-0.86

5.Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50
%	0	0	0	0	0	15.75	66.42	43.76

<-----Frequency (Hz)----->

Maximum		Minimum		Average Frequency	Freq Variation Index	Standard Deviation	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time				Max.	Min.
50.33	23:57:20	49.72	12:38:50	49.99	0.079	0.088	50.27	49.8

6.Voltage Profile: 132kV

STATION	Maximum		Minimum		Voltage (in %)			
	VOLTAGE	TIME	VOLTAGE	TIME	< 110	< 119	> 135	> 145
KUMARGHAT - 132KV	135	23:56	131	11:54	0	0	0	0
AIZWAL - 132KV	134	05:09	129	18:42	0	0	0	0
KHELIEHRIAT - 132KV	136	06:01	133	18:44	0	0	30.87	0
JIRIBAM(PG) - 132KV	135	05:02	132	19:10	0	0	3.13	0
IMPHAL(PG) - 132KV	134	23:46	130	16:17	0	0	0	0
HAFLONG - 132KV	137	05:03	133	18:57	0	0	45.38	0
BADARPUR - 132KV	135	23:58	132	01:38	0	0	1.49	0
NIRJULI - 132KV	134	06:01	129	18:58	0	0	0	0
KAHILIPARA - 132KV	137	05:30	128	12:09	0	0	16.11	0

6.Voltage Profile: 220kV

STATION	Maximum		Minimum		Voltage (in %)			
	VOLTAGE	TIME	VOLTAGE	TIME	< 198	< 210	> 235	> 245
SALAKATI - 220KV	226	06:01	219	19:21	0	0	0	0
DIMAPUR (PG) - 220KV	225	05:00	216	18:26	0	0	0	0
MARIANI (PG) - 220KV	227	23:56	222	16:12	0	0	0	0
MISA - 220KV	226	05:01	220	18:54	0	0	0	0

6.Voltage Profile: 400kV

STATION	Maximum		Minimum		Voltage (in %)			
	VOLTAGE	TIME	VOLTAGE	TIME	< 380	< 390	> 420	> 430
BgTTP - 400KV	410	06:01	402	21:23	0	0	0	0
SILCHAR - 400KV	413	23:54	402	12:43	0	0	0	0
PALATANA - 400KV	411	23:57	403	11:55	0	0	0	0
BYRNIHAT (KILLING) - 400KV	411	05:04	402	18:54	0	0	0	0
MISA - 400KV	406	05:03	396	00:08	0	0	0	0
AZARA - 400KV	408	05:31	402	21:05	0	0	0	0
RANGANADI - 400KV	411	06:01	401	18:53	0	0	0	0
BALIPARA - 400KV	407	03:52	398	18:42	0	0	0	0
BISWANATH CHARIALI - 400KV	407	05:01	397	19:10	0	0	0	0
BONGAIGAON - 400KV	408	03:31	401	22:38	0	0	0	0

7.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)
Doyang	306	333	227	0	-	308.1	3	0	-
Gumti	83.6	93.55	85	0	-	89.25	13	0	-
Kameng	764.5	770	0	769.98	-	769.87	-	769.73	-
Khandong	704.26	727.3	278	719.2	-	720	0	719.3	-
Kopili	592.8	609.6	1186	606.5	76	608.75	96	606.55	77
Loktak	766.2	769	448	766.69	17	767.13	37	766.7	17
Pare	240	245.15	0	242.87	-	243.11	-	242.23	-
Ranganadi	560	567	0	565.06	-	564.71	-	566.74	-
Umium	960.12	981.43	50	6.71	-	974.64	28	972.28	21
TOTAL	-	-	2274	-	93	-	177	-	115

8. Synchronisation of new generating units :

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time
-------	--------------	-------	----------------------	------	------

9. Synchronisation of new 220 / 400 / 132 KV Transmission elements and energising of bus/substation :

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time
-------	--------------	-------	----------------------	------	------

10A. Short-Term Open Access Details:

State	Off- Peak Hours (03:00)												
	Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
ARUNACHAL PRADESH	-47	-	0	-	-23	-	0	-	0	-	-	-	-
ASSAM	335.73	-	-120	-	86.98	-	0	-	0	-	-	-	-
MANIPUR	-31.86	-	0	-	-42	-	0	-	0	-	-	-	-
TRIPURA	0	-	0	-	0	-	0	-	0	-	-	-	-
NAGALAND	-15	-	-25	-	-7	-	0	-	0	-	-	-	-
MEGHALAYA	0	-	0	-	20.23	-	0	-	0	-	-	-	-
MIZORAM	0	-	-78	-	0	-	0	-	0	-	-	-	-
TOTAL	241.87	0	-223	0	35.21	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
ARUNACHAL PRADESH	-47	-	0	-	-7	-	0	-	0	-	-	-	-
ASSAM	410.72	-	0	-	-200	-	0	-	0	-	-	-	-
MANIPUR	-53.86	-	0	-	48.32	-	0	-	0	-	-	-	-
TRIPURA	0	-	28.99	-	0	-	0	-	0	-	-	-	-
NAGALAND	0	-	0	-	-9	-	0	-	0	-	-	-	-
MEGHALAYA	0	-	0	-	-0.52	-	0	-	0	-	-	-	-
MIZORAM	0	-	-46	-	0	-	0	-	0	-	-	-	-
TOTAL	309.86	0	-17.01	0	-168.2	0	0	0	0	0	0	0	0

	Day Energy (MU)						
State	ISGS(LT+MT) Schedule	BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
ARUNACHAL PRADESH	4.48	-0.57	-	0	-	-0.8	3.11
ASSAM	34.49	8.97	-	-2.91	-	-2.62	37.93
MANIPUR	3.81	-0.92	-	0	-	0.17	3.06
TRIPURA	4.81	0	-	0.19	-	0.26	5.26
NAGALAND	3.05	-0.09	-	-0.13	-	-0.15	2.68
MEGHALAYA	1.15	0.07	-	-0.1	-	0.04	1.16
MIZORAM	1.58	0	-	-0.78	-	0	0.8
TOTAL	53.37	7.46	0	-3.73	53.37	-3.1	54

10(B). Short-Term Open Access Details

State	ISGS(LT+MT) Schedule		Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM(MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ARUNACHAL PRADESH	218.43	169.39	-7	-47	0	0	0	0	0	0	0	0	0	0
ASSAM	1836.91	1168.72	413.04	333.41	0	0	0	0	0	0	0	-460	0	0
MANIPUR	180.15	142	-31.86	-53.86	0	0	0	0	0	0	0	0	0	0
MEGHALAYA	178.12	-6.29	6.47	0	0	-204	0	0	0	0	23.39	-141	0	0
MIZORAM	117.8	21.06	0	0	0	0	0	0	0	0	0	-95	0	0
NAGALAND	144.86	111.61	0	-15	0	0	0	0	0	0	16.43	-30	0	0
TRIPURA	246.95	123.48	0	0	0	0	0	0	0	0	28.99	0	0	0

State	HPX DAM (MW)		IEX HPDAM(MW)		PXIL HPDAM (MW)		HPX HPDAM (MW)		IEX RTM (MW)		PXIL RTM (MW)		HPX RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
ARUNACHAL	0	0	0	0	0	0	0	0	1.93	-67	0	0	0	0
ASSAM	0	0	0	0	0	0	0	0	144.96	-430	0	0	0	0
MANIPUR	0	0	0	0	0	0	0	0	57.98	-44	0	0	0	0
MEGHALAYA	0	0	0	0	0	0	0	0	37.62	-28.94	0	0	0	0
MIZORAM	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NAGALAND	0	0	0	0	0	0	0	0	14.5	-43	0	0	0	0
TRIPURA	0	0	0	0	0	0	0	0	62.82	-75	0	0	0	0

12.Significant events (If any):

13.System Constraints (If any)

14. Weather Condition:

Shift In Charge