

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				/Day Energy(Net MU)	
मांग पूरत/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्त/ Freq (Hz)	मांग पूरत/ Demand Met	अभाव/Shortage	आवश्यकता/ Requirement	आवृत्त/ Freq (Hz)	मांग पूरत/ Demand Met	अभाव/Shortage
59,193	0	59,193	49.96	53,692	0	53,692	49.99	1,373.4	0

2(A) /Load Details (/in state periphery) in MU:

राज्य/STATE	State's Control Area Generation (Net MU)							/Net SCH		/Drawal		/UI		Availability	Requirement	/ Shortage	/ Consump -tion
	तापीय/ THERMAL	जलीय/ HYDRO	गैस/ Gas	पवन/ WIND	सौर/ SOLAR	अन्य/ OTHERS	कुल/TOTAL	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
BALCO	-	0	0	0	0	0	0	12.7	11.3	-1.4	11.3	11.3	11.3	0	11.3		
CHHATTISGARH	54	0.8	0	0	2.3	1.1	58.2	61.9	60.4	-1.5	118.6	118.6	118.6	0	118.6		
DNHDDPDCL	-	0	0	0	0	0	0	31.4	31.4	0	31.4	31.4	31.4	0	31.4		
AMNSIL	10.5	0	0	0	0	0	10.5	9.4	9.3	-0.1	19.8	19.8	19.8	0	19.8		
GOA	0.4	0	0	0	0	0	0.4	12.1	14	1.9	14.4	14.4	14.4	0	14.4		
GUJARAT	111.4	0.1	15.6	67.4	22.4	0	216.9	186.7	186.8	0.1	403.7	403.7	403.7	0	403.7		
MADHYA PRADESH	68.8	10.9	0	18.9	3.3	0.6	102.5	120	118.5	-1.5	221	221	221	0	221		
MAHARASHTRA	283.2	11.5	8.7	65.3	15.9	0	384.6	165.9	162.9	-3	547.5	547.5	547.5	0	547.5		
RIL JAMNAGAR	-	0	0	0	0	0	0	5.7	5.7	0	5.7	5.7	5.7	0	5.7		
Region	528.3	23.3	24.3	151.6	43.9	1.7	773.1	605.8	600.3	-5.5	1,373.4	1,373.4	1,373.4	0	1,373.4		

2(B) / /State's Demand Met in MW and day energy forecast and deviation particulars

राज्य/State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			AVG (MW)	/Day Energy(Net MU)	
	मांग पूरत/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Evening peak	मांग पूरत/ Demand Met	अभाव/ Shortage	आवश्यकता/ Requirement at Off-Peak		पूरवानुमान/ForeCast(MU)	वचिलन/Deviation[Fore .. -Consumption] (MU)
BALCO	190	0	190	531	0	531	470	13	1.7
CHHATTISGARH	4,863	0	4,863	5,018	0	5,018	4,961	119.89	1.29
DNHDDPDCL	1,305	0	1,305	1,228	0	1,228	1,308	30.85	-0.55
AMNSIL	835	0	835	849	0	849	826	17	-2.8
GOA	642	0	642	517	0	517	594	12.88	-1.52
GUJARAT	17,072	0	17,072	15,428	0	15,428	16,823	421.32	17.62
MADHYA PRADESH	9,939	0	9,939	8,897	0	8,897	9,411	228.74	7.74
MAHARASHTRA	24,120	0	24,120	20,999	0	20,999	22,812	518.36	-29.14
RIL JAMNAGAR	227	0	227	225	0	225	237	2	-3.7
Region	59,193	0	59,193	53,692	0	53,692	57,442	1,364.04	-9.36

2(C) /State's Demand Met in MW (/maximum demand met and /Maximum requirement of the day details)

राज्य/State	Maximum Demand, corresponding shortage and requirement details for the day				ACE			
	अधिकतम मांग पूरत/Maximum Demand Met of the day	समय/Time	अभाव/Shortage at maximum demand	आवश्यकता/Requirement at the max demand met of the day	ACE_MAX	बजे/Time	ACE_MIN	बजे/Time
BALCO	533	02:00	0	533	-	-	-	-
CHHATTISGARH	5,261	06:30	0	5,261	340.62	10:02:00	-328.78	08:47:00
DNHDDPDCL	1,385	18:00	0	1,385	61.49	06:32:00	-48.1	22:30:00
AMNSIL	878	06:00	0	878	227.51	05:07:00	-374.57	07:04:00
GOA	592	19:45	0	592	51.19	09:49:00	-96.13	20:10:00
GUJARAT	18,132	17:00	0	18,132	1,184.13	08:45:00	-1,534.97	23:37:00
MADHYA PRADESH	10,380	20:00	0	10,380	405.76	13:44:00	-768.44	16:00:00
MAHARASHTRA	24,636	20:00	0	24,636	696.54	11:41:00	-1,298.05	23:37:00
RIL JAMNAGAR	251	11:00	0	251	-	-	-	-
WR	60,671	19:00	0	60,671	-	-	-	-

3(A) State Entities Generation:

CHHATTISGARH										
स्टेशन/ Station/Constituents	स्थापित क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
KORBA EAST EXT(DSPM)(2*250)	500	472	428	473	19:01	360	13:40	11.1	10.2	425
KORBA(W) CSETCL(4*210 + 1*500)	1,340	953	967	983	01:18	761	10:45	24.08	22.03	918
MARWA TPS(1*500 + 1*500)	1,000	954	940	959	07:21	615	13:13	21.79	20.65	860
OTHER CPP	50	0	0	0	-	0	-	1.11	1.11	46
TOTAL THERMAL	2,890	2,379	2,335	-	-	-	-	58.08	53.99	2,249
HASDEO BANGO(3*40)	120	1	1	39	21:00	1	00:06	0.11	0.11	5
KWB MINI MICRO(2*0.85)	1.7	0	0	0	-	0	-	0.02	0.02	1
SMALL HYDRO	50	0	0	0	-	0	-	0.65	0.65	27
TOTAL HYDEL	171.7	1	1	-	-	-	-	0.78	0.78	33
WIND	0	0	0	0	-	0	-	0	0	0
SOLAR	507	-2	-2	-2	00:00	-2	00:00	2.29	2.29	95
BIO MASS	50	0	0	0	-	0	-	1.06	1.06	44
TOTAL BIO MASS	50	0	0	-	-	-	-	1.06	1.06	44
TOTAL CHHATTISGARH	3,618.7	-	-	-	-	-	-	62.21	58.12	2,421

GUJARAT

संस्थान/ Station/Constituents	सुधपति कषमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AEEO(1*120 + 2*121)	362	360	321	366	22:29	228	03:46	7.06	6.43	268
ALTPS(2*125)	250	-1	-1	-1	00:00	-1	00:00	0	0	0
APL MUNDRA(4*330 + 2*660 + 3*660)	4,620	2,586	2,116	3,042	22:24	1,961	10:23	59.92	55.27	2,303
BLTPS(2*250)	500	114	0	124	22:39	76	06:00	2.14	1.45	60
GANDHINAGAR(GTPS)(3*210)	630	0	0	0	00:00	0	00:00	0	0	0
KLTPS(2*75)	150	44	0	50	17:58	0	00:00	0.34	0.24	10
OTHER CPP	1,000	0	0	0	-	0	-	8.03	8.03	335
SLPP(4*125)	500	312	299	319	21:42	197	14:48	8.03	8.03	335
STPS(2*250)	500	0	0	0	00:00	0	00:00	0	0	0
UKAI(2*200 + 1*210 + 1*500)	1,110	300	406	587	07:04	125	13:59	7.46	6.44	268
VADINAR(2*600)	1,200	570	564	580	17:12	312	14:59	13.61	12.79	533
WANAKBORI(7*210 + 1*800)	2,270	512	513	774	09:40	499	13:49	13.6	12.72	530
TOTAL THERMAL	13,092	4,797	4,218	-	-	-	-	120.19	111.4	4,642
DGBBP(1*107 + 1*112 + 1*376)	594	0	0	0	00:00	0	16:45	0	0	0
ESSAR POWER GAS(3*110 + 1*185)	515	0	0	0	-	0	-	0	0	0
GIPCL STG(3*32 + 49)	145	0	0	0	00:00	0	00:00	0	0	0
GIPCL STG 2(111 + 54)	165	0	0	0	00:00	0	00:00	0	0	0
GPEC(3*138 +241)	654	0	0	0	-	0	-	0	0	0
GPPC(2*351.43)	702	0	0	0	00:00	0	00:00	0	0	0
GSEC(3*52)	156	0	0	28	05:30	0	00:00	0.04	0.02	1
SUGEN 1(3*382.5)	1,147.5	634	356	672	16:56	-347	16:44	13.53	13.15	548
UNOSUGEN(1*382.5)	382.5	-1	-1	0	16:44	-2	11:06	0	0	0
UTRAN STG II(1*229 + 1*146(ST))	375	0	0	0	00:00	0	00:00	2.52	2.44	102
TOTAL GAS	4,836	633	355	-	-	-	-	16.09	15.61	651
KADANA(4*60)	240	0	0	46	00:00	0	00:05	0.12	0.12	5
LBC PANAM HYDRO	5	0	0	0	-	0	-	0.02	0.01	0
PVT HYDRO	20.6	0	0	0	-	0	-	0.14	0.14	6
UKAI HYDRO(4*75)	300	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	565.6	0	0	-	-	-	-	0.28	0.27	11
WIND	6,998	3,538	2,357	4,103	23:59	1,071	17:25	67.41	67.41	2,809
SOLAR	6,332	0	11	6,398	17:25	18	06:04	22.45	22.45	935
BIO MASS	51.65	0	0	0	-	0	-	1.06	1.06	44
TOTAL GUJARAT	31,875.25	-	-	-	-	-	-	227.48	218.2	9,092

MADHYA PRADESH

स्टेशन/ Station/Constituents	सुथपति कषमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
AMARKANTAK(1*210)	210	192	192	199	18:02	118	13:18	4.87	4.43	185
BLA IPP(2*45)	90	62	50	81	21:09	47	08:24	1.47	1.28	53
JP BINA(2*250)	500	453	281	470	21:51	275	10:24	8.3	7.5	313
SANJAY GANDHI TPS(4*210 + 1*500)	1,340	990	986	1,001	19:51	642	13:46	23.24	21.32	888
SATPURA IV(2*250)	500	470	272	471	19:51	258	14:20	8	7.2	300
SINGAJI(2*600 + 2*660)	2,520	1,626	998	1,718	23:11	956	13:30	29.01	27.04	1,127
TOTAL THERMAL	5,160	3,793	2,779	-	-	-	-	74.89	68.77	2,866
BANASAGAR TONS(3*105)	315	92	99	104	15:54	0	11:05	2.09	2.07	86
BARGI(2*45)	90	0	0	0	00:00	0	00:00	0.82	0.81	34
BIRSINGHPUR	20	0	0	0	-	0	-	0	0	0
BSGR(DEVLONE)(3*20)	60	0	0	0	00:00	0	00:00	0	0	0
BSGR(SILPARA)(2*15)	30	-12	-12	-8	17:12	-13	08:58	0.3	0.3	13
INDIRASAGAR(8*125)	1,000	562	0	694	20:43	0	00:39	4.01	3.99	166
JHINNA(2*10)	20	10	10	10	14:35	10	16:55	0.24	0.24	10
MADIKHEADA(3*20)	60	60	60	60	00:00	60	00:00	0	0	0
MP CHAMBAL	386	0	0	0	-	0	-	0	0	0
OMKARESHWAR(8*65)	520	323	65	340	19:37	0	11:06	3.36	3.35	140
PENCH(2*80)	160	0	0	0	-	0	-	0.1	0.1	4
RAJGHAT HYDRO(3*15)	45	0	0	0	00:00	0	00:00	0	0	0
TOTAL HYDEL	2,706	1,035	222	-	-	-	-	10.92	10.86	453
WIND	2,428	444	985	1,012	07:53	356	15:48	18.94	18.94	789
SOLAR	1,610	0	0	526	12:57	0	05:59	3.29	3.29	137
BIO + SMALL HYDRO	100	0	0	0	-	0	-	0.61	0.61	25
TOTAL MADHYA PRADESH	12,004	-	-	-	-	-	-	108.65	102.47	4,270

MAHARASHTRA										
स्टेशन/ Station/Constituents	स्थापति क्षमता/Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross(MU)	Net(MU)	
APML TIRODA(5*660)	3,300	3,092	2,285	3,134	21:24	1,716	12:04	62.17	58.59	2,441
BHUSAWAL(1*210 + 2*500+1*660)	1,870	1,024	790	1,052	21:09	593	15:15	20.12	18.83	785
CHANDRAPUR(2*210 + 5*500)	2,920	1,840	1,354	1,847	20:04	1,200	15:57	37.7	34.76	1,448
DAHANU(2*250)	500	242	184	401	23:43	140	10:32	4.6	4	167
IEPL(1*270)	270	273	271	274	18:51	157	12:10	5.77	5.19	216
JAIGAD(4*300)	1,200	1,035	907	1,089	21:36	640	08:26	22.36	20.35	848
JPL DHULE (SHIRPUR)(2*150)	300	137	121	145	20:27	0	15:59	2.75	2.62	109
KHAPARKHEDA(4*210 + 1*500)	1,340	1,016	941	1,032	19:03	748	11:45	24.28	22.29	929
KORADI(1*210 + 3*660)	2,190	1,568	1,637	1,685	02:32	1,201	12:15	37.92	35.75	1,490
NASIK(3*210)	630	296	209	302	21:30	192	12:51	6.31	5.68	237
OTHER CPP	3,305	0	0	0	-	0	-	21.63	21.63	901
PARAS(2*250)	500	388	227	399	22:43	239	11:21	7.66	6.92	288
PARLI(3*250)	750	-1	-1	-1	00:00	-1	00:00	0	0	0
RATTAN INDIA (AMARAVATI)(5*270)	1,350	728	990	999	03:56	420	13:00	21.78	19.78	824
SWPGL(4*135)	540	352	354	361	19:23	208	12:14	9.17	8.31	346
TROMBAY(250+1*500)	750	515	383	516	19:59	353	09:37	9.71	9.1	379
VIPL(2*300)	600	0	0	0	-	0	-	9.42	9.42	393
TOTAL THERMAL	22,315	12,505	10,652	-	-	-	-	303.35	283.22	11,801
TROMBAY_GAS(1*120+1*60)	180	167	75	176	18:56	74	00:30	2.41	2.39	100
URAN(4*108 + 2*120)	672	267	263	272	23:05	254	14:49	6.52	6.3	263
TOTAL GAS	852	434	338	-	-	-	-	8.93	8.69	363
BHIRA(6*25)	150	124	78	155	19:12	3	16:55	0	0	0
BHIRA PSS	150	161	-1	162	16:30	-1	01:31	0	0	0
BHIRA TR(2*40)	80	0	0	0	-	0	-	0.37	0.36	15
BHIVPURI(3*24 + 2*1.5)	75	54	0	54	19:32	-1	08:54	0	0	0
GHATGHAR(2*125)	250	233	-155	240	19:55	0	00:00	0.15	0.14	6
HYDRO VTRNA(1*60)	60	0	0	0	00:00	0	00:00	0.36	0.35	15
HYDROSLHY_PTN(1*350)	350	0	0	0	-	0	-	2.72	2.66	111
KHOPOLI(3*24)	72	24	24	24	00:25	22	11:06	0	0	0
KOYNA I AND II(4*(65+5) + 4*(75+5))	600	40	41	337	12:57	33	08:56	1.5	1.47	61
KOYNA III(4*80)	320	78	0	157	07:56	0	00:00	0.79	0.78	33
KOYNA ST-IV(4*250)	1,000	-5	-5	-1	05:38	-22	09:07	0	0	0
TILLARI(1*66)	66	0	0	62	15:04	0	00:00	0.15	0.15	6
OTHER HYDRO	122	0	0	0	-	0	-	5.61	5.61	234
TOTAL HYDEL	3,295	709	-18	-	-	-	-	11.65	11.52	481
WIND	5,005	2,335	1,789	2,441	19:21	1,749	06:52	65.29	65.29	2,720
SOLAR	2,957	79	43	1,894	13:55	63	06:00	15.9	15.9	663
TOTAL MAHARASHTRA	34,424	-	-	-	-	-	-	405.12	384.62	16,028

3(B) Regional Entities Generation

ISGS

स्टेशन/ Station/Constituents	स्थापति क्षमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
GADARWARA(2*800)	1,600	723	602	789	01:21	362	09:59	13.6	14.59	13.58	566
GANDHAR(3*144.3 + 1*224.49)	657	9	-1	296	23:07	-17	17:17	0.94	0.77	0.74	31
KAPS(2*220)	440	391	391	391	00:00	391	00:00	4.75	5.35	4.82	201
KAPS3&4(2*700)	1,400	553	-57	575	22:53	429	06:00	9.47	10.88	9.1	379
KAWAS(4*106 + 2*116.1)	656.2	-1	-1	422	22:23	-8	12:28	0.94	1	0.98	41
KHARGONE(2*660)	1,320	1,249	675	1,270	19:18	658	17:39	19.42	21.36	20.08	837
KSTPS1&2(3*200 + 3*500)	2,100	1,736	1,707	1,745	19:45	950	13:11	40.26	42.81	39.83	1,660
KSTPS3(1*500)	500	479	474	491	05:59	285	13:10	10.8	11.28	10.65	444
LARA(2*800)	1,600	1,507	1,491	1,540	05:55	855	11:51	34.92	36.89	34.77	1,449
MOUDA I(2*500)	1,000	477	382	489	05:22	245	15:36	9.19	9.9	9.28	387
MOUDA II(2*660)	1,320	1,235	980	1,268	06:04	638	09:47	24.35	25.97	24.38	1,016
NSPCL(2*250)	500	458	449	472	16:53	241	09:58	9.62	10.5	9.61	400
RGPPL(2*320 + 4*331.75)	1,967	6	-1	9	09:32	-4	00:00	0.11	0.14	0.14	6
SASAN(6*660)	3,960	3,721	3,679	3,759	09:13	3,258	11:41	86.98	93.52	87.82	3,659
SIPAT I(3*660)	1,980	1,843	1,895	1,914	01:32	1,108	12:45	42.76	45.14	42.35	1,765
SIPAT II(2*500)	1,000	957	943	967	05:21	525	13:12	21.63	22.77	21.38	891
SOLAPUR STPS(2*660)	1,320	-8	-20	1	13:42	-9	17:15	1.16	0.35	0.35	15
SSP(RBPH+CHPH)(6*200 + 5*50)	1,450	834	868	868	03:02	830	15:12	20.94	20.83	20.94	873
TARAPUR I(2*160)	320	1	-1	13	12:04	-12	08:06	0	0.04	0.04	2
TARAPUR II(2*540)	1,080	886	899	915	07:49	881	17:27	21.17	23.51	21.17	882
VSTPS I(6*210)	1,260	934	922	938	20:02	537	12:17	20.21	22.17	19.71	821
VSTPS II(2*500)	1,000	890	824	907	18:52	517	12:17	19.43	20.24	18.78	783
VSTPS III(2*500)	1,000	951	930	975	22:18	511	10:45	20.26	21.21	20.08	837
VSTPS IV(2*500)	1,000	939	901	947	19:19	490	09:50	19.9	20.87	19.62	818
VSTPS V(1*500)	500	473	438	495	16:40	236	10:00	9.86	10.46	9.83	410
SUB-TOTAL	30,930.2	21,243	19,369	-	-	-	-	462.67	492.55	460.03	19,173
TOTAL	30,930.2	-	-					462.67	492.55	460.03	19,173

सटेशन/ Station/Constituents	सुथापति कषमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACBIL(2*135 + 2*50 + 2*30 + 1*63)	493	268	273	278	03:53	218	11:50	6.56	7.61	6.48	270
ADANI RAIPUR(2*685)	1,370	1,178	1,040	1,197	19:05	609	11:43	26.53	27.58	24.84	1,035
APL RAIGARH(1*600)	600	572	569	587	15:51	229	13:12	12.62	13.38	12.68	528
BALCO(4*300)	1,200	-156	1,017	1,061	16:45	541	11:46	17.53	17.53	15	625
DB POWER(2*600)	1,200	1,139	1,052	1,157	16:51	702	11:33	24.61	26.27	24.73	1,030
DCPP(2*135)	270	238	243	245	04:18	156	11:26	5.66	6.42	5.69	237
DGEN(3*400)	1,200	-2	-3	-2	20:00	-4	13:00	0	0.05	0.05	2
DHARIWAL CTU(2*300)	600	390	225	458	22:33	207	13:12	6.79	7.43	6.74	281
GMR WARORA(2*300)	600	551	491	571	18:20	331	10:43	11.9	13	12	500
JHABUA POWER(1*600)	600	543	356	558	22:03	329	15:02	9.44	10.04	9.46	394
JP NIGRIE(2*660)	1,320	1,246	1,237	1,264	21:25	810	11:55	25.77	27.42	26.11	1,088
JPL STG-I(4*250)	1,000	724	721	759	13:27	623	11:39	17.37	20.02	17.55	731
JPL STG-II(4*600)	2,400	2,310	2,315	2,358	07:58	1,445	12:35	54.69	57.08	54.13	2,255
KSK MAHANADI(3*600)	1,800	1,684	1,333	1,704	19:16	940	11:21	31.78	34.39	31.85	1,327
LANCO(2*300)	600	550	543	574	19:39	296	11:06	11.62	12.97	11.78	491
MAHAN ENERGEN(2*600)	1,200	1,121	1,121	1,134	16:56	637	11:40	23.98	25.84	24.24	1,010
MB POWER(2*600)	1,200	1,151	1,136	1,169	16:54	493	11:06	23.17	24.84	23.33	972
MCCPL(1*300)	300	275	251	278	17:30	163	11:25	5.78	6.34	5.77	240
RKM POWER(4*360)	1,440	984	688	988	20:02	551	05:51	17.87	20.15	18.12	755
SKS POWER(2*300)	600	528	543	551	07:52	363	13:55	12.58	13.72	12.35	515
TPCL(5*800)	4,000	3,544	3,102	3,821	22:27	2,147	09:08	74.56	80.54	74.15	3,090
TRN ENERGY(2*300)	600	271	384	502	11:56	267	16:35	8.95	10.08	9.1	379
VEDANTA (2*600)	1,200	191	131	250	21:42	127	13:45	-	0	0	0
SUB-TOTAL	25,793	19,300	18,768	-	-	-	-	429.76	462.7	426.15	17,755
TOTAL	25,793	-	-					429.76	462.7	426.15	17,755

RENEWABLE											
सुटेसन/ Station/Constituents	सुथापति कृषमता/ Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	GROSS(MU)	NET (MU)	
ACL_PSS3_KPS1_S	200	0	0	136	12:29	0	00:00	0.74	0.69	0.69	29
AGE24AL_PSS3_KPS1_S	400	-1	0	253	11:55	0	01:08	1.26	1.38	1.38	58
AGE25AL_PSS2_KPS1_S	500	-1	0	299	10:54	0	00:00	1.91	1.88	1.88	78
AGE25BL_PSS2_KPS1_S	582.98	4	0	309	13:30	0	00:03	2.2	2.32	2.32	97
AGE26AL_PSS3_KPS1_S	12.5	0	0	9	09:29	0	00:00	-	0.04	0.04	2
AGE26BL_PSS2_KPS1_S	167	0	0	101	10:09	0	00:12	0.63	0.69	0.69	29
AHEJ5L_PSS5_KPS1_S	145	1	0	85	13:01	0	06:19	0.7	0.48	0.48	20
APSEZ_PSS3_KPS1_S	200	0	0	125	12:00	0	00:00	0.66	0.7	0.7	29
ARE45L_PSS5_KPS1_S	50	0	0	59	12:26	0	06:05	0.35	0.28	0.28	12
ARE55L_PSS3_KPS1_HS	25	0	0	8	10:57	0	00:00	0.08	0.07	0.07	3
ARE55L_PSS3_KPS1_S	162.5	11	10	20	23:03	1	07:32	0.55	0.21	0.21	9
ARE56L_PSS10_KPS1_S	100	0	0	107	11:10	-2	06:19	0.63	0.58	0.58	24
ARE56L_PSS9_KPS1_S	100	0	0	216	12:39	0	06:06	0.88	1.04	1.04	43
ARE57L_PSS13_KPS1_S	300	-1	-1	395	10:59	-1	00:00	2.54	2.59	2.59	108
AREH4L_PSS1_KPS1_SF	1,000	-4	-3	531	14:37	-3	00:30	3.85	3.82	3.82	159
ARINSUN SOLAR (BARSITADESH)	250	-1	-1	178	11:08	-1	05:51	0.92	1.03	1.03	43
ATHENA SOLAR	250	0	0	179	14:35	0	06:03	0.91	0.99	0.99	41
AVAADA_AGAR_RUMS_S	200	-1	-1	99	15:44	0	06:10	0.42	0.36	0.36	15
BEEMPOW_AGAR_RUMS_S	350	-1	-1	211	15:54	-1	00:52	0.68	0.61	0.61	25
ESPL_RSP SOLAR	200	0	0	207	12:39	0	05:54	0.98	1.07	1.07	45
GANDHAR SOLAR	20	0	0	0	00:00	0	00:00	0	0	0	0
GIPCL_RSP SOLAR	100	0	-1	105	14:50	-1	00:00	0.54	0.39	0.39	16
GSEC 2	100	0	0	69	14:51	0	00:00	0.37	0.35	0.35	15
GSECL_RSP SOLAR	100	0	69	69	00:00	3	18:00	0.34	1.13	1.13	47
KAWAS SOLAR	56	0	0	11	17:08	0	07:18	0.11	0.03	0.03	1
MAHINDRA SOLAR (BADWAR)	250	-1	-1	167	09:54	-1	06:05	0.85	0.93	0.93	39
MASAYA SOLAR	300	0	0	114	11:24	0	00:00	0.79	0.61	0.61	25
SGEL_RSP_S	100	0	0	104	14:52	0	00:00	0.55	0.4	0.4	17
SHERISHA RAIPUR	50	0	0	47	13:12	0	00:00	0.21	0.18	0.18	8
SOLAPUR SOLAR PV PROJECT	10	0	0	23	12:54	0	00:00	0.06	0.11	0.11	5
TPREL_RSP SOLAR	100	0	0	105	12:26	0	00:00	0.54	0.58	0.58	24
TPSOURY_BRVD_NMCH_S	160	0	0	24	16:00	0	00:00	0.29	0.1	0.1	4
TPSOURY_KWAI_NMCH_S	170	-2	-3	29	15:45	-2	06:01	0.29	0.11	0.11	5
ACL_PSS4_KPS1_W	125	82	41	92	14:31	6	08:03	2.01	1.12	1.12	47
ADANI WIND ENERGY KUTCHH FOUR LTD	300	246	237	282	18:02	154	09:23	5.39	5.37	5.37	224
AGE24L_PSS4_KPS1_W	100	86	51	96	19:36	6	08:17	1.45	1.16	1.16	48
AHEJ5L_PSS4_KPS1_W	52	45	25	46	18:14	4	08:16	0.81	0.54	0.54	23
ALFANAR WIND (NANAVALKA)	300	137	129	216	16:56	53	09:16	3.78	3.33	3.33	139
APRAAVA ENERGY PRIVATE LIMITED (AEPL)	252	192	213	249	16:49	164	11:17	4.74	4.86	4.86	203
APSEZ_PSS4_KPS1_W	52	61	24	74	14:30	4	08:06	0.6	0.8	0.8	33
ARE41L_PSS13_KPS1_W	124.8	55	42	95	16:37	5	10:59	-	0.93	0.93	39
ARE41L_PSS3_KPS1_W	250	176	122	218	23:08	24	10:42	3.65	2.75	2.75	115
ARE41L_PSS4_KPS1_W	50	43	25	49	14:28	7	08:34	0.81	0.66	0.66	28
ARE48L_SRPL_PSS9_KPS1_W	119.6	90	48	113	23:56	12	08:22	0	1.38	1.38	58
ARE55L_PSS3_KPS1_HW	20.8	0	0	0	-	0	-	0.26	-	0	0
ASIPL WIND (BARANDA)	170.1	110	84	163	17:17	46	06:35	2.55	2.47	2.47	103
AWEK1L WIND (RATADIYA)	425	309	235	422	18:00	107	07:21	5.82	6.37	6.37	265
AWEKFL WIND (RATADIYA)	130	138	104	184	16:48	49	07:22	1.6	2.81	2.81	117
AWEMP1PL_PTNGR_IDR_W	324.4	141	174	258	00:47	49	18:00	4.03	3.44	3.44	143
CPTTNPL WIND (DAYAPAR)	126	53	38	90	18:03	19	07:25	1.35	1.13	1.13	47
GIWEL-II WIND (VADVA)	250	141	145	224	16:27	58	06:57	3.2	3.03	3.03	126
GIWEL-III WIND (NARANPAR)	300	105	154	233	23:53	79	08:54	3.41	3.29	3.29	137
IGESL_DAYAPAR_BHUJ_W	250	91	91	91	00:00	91	00:00	1.88	2.18	2.18	91
NETRA_KOTDA_BHUJ_W	206.5	118	83	173	17:17	45	06:18	2.73	2.61	2.61	109
NTPC_REL_DYPR_BHUJ_W	50	31	31	31	00:00	31	00:00	1.19	0.75	0.75	31
OEPL WIND (OSTRO KUTCH)	50	31	30	37	13:46	0	16:30	0.52	0.48	0.48	20
OKWPL WIND (OSTRO KUTCH)	250	90	129	226	16:00	0	16:29	2.79	2.35	2.35	98
POWERICA WIND	50.6	12	12	12	00:00	12	00:00	0.8	0.29	0.29	12
RENEW AP2 WIND (GHADSISA)	300	227	170	250	02:24	115	09:29	4.21	4.5	4.5	188
RENEW WIND (BHUVAD)	230.1	147	153	208	23:30	36	08:37	2.43	2.78	2.78	116
SITAC WIND	300	0	0	0	00:00	0	15:30	0	0	0	0
SRIJAN WIND	148.5	81	57	114	16:50	27	09:16	1.89	1.63	1.63	68
TORRENT SOLARGEN LIMITED	115	85	-84	107	16:16	-105	15:06	1.8	0.37	0.37	15
TOTAL	12,133.38	-	-					91.53	89.13	89.13	3,718

REGIONAL GENERATION SUMMARY

	THERMAL GEN MU	GAS GEN MU	SOLAR GEN MU	WIND GEN MU	HYDRO GEN MU	NUCLEAR GEN MU	OTHER GEN MU	TOTAL GEN MU	SCHEDULE MU
ISGS	402.1	1.86	-	-	20.94	35.13	-	460.03	462.67
IPP	426.1	0.05	-	-	-	-	-	426.15	429.76
Constituents	528.3	24.3	43.9	151.6	23.3	-	1.7	773.1	767.6
Renewables	-	-	25.75	63.38	-	-	-	89.13	91.53

Region	1,356.5	26.21	69.65	214.98	44.24	35.13	1.7	1,748.41	1,751.56
--------	---------	-------	-------	--------	-------	-------	-----	----------	----------

4(A) अंतर क्षेत्रीय वनिमिय/INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))								
SL.No.	Element	20:00	03:00	अधिकतम पस्पर वनिमिय/Maximum Interchange (MW)		आयात/Import in MU	नरियात/Export in MU	शुद्ध वनिमिय/NET
		(MW)	MW	आयात/Import (MW)	नरियात/Export (MW)			
EAST REGION WEST REGION //Import/Export between EAST REGION and WEST REGION								
1	220KV-KORBA-BUDIPADAR	-56	-64	29	-131	0	-1.32	-1.32
2	220KV-RAIGARH-BUDIPADAR	0	0	61	-48	0.22	-0.16	0.06
3	400KV-JAGDALPUR-JEYPORE	-	-	-	-	2.91	0	2.91
4	400KV-RAIGARH-JHARSUGUDA	-68	-98	118	-320	0.07	-1.99	-1.92
5	400KV-SIPAT-RANCHI	-	-	-	-	0	-4.16	-4.16
6	765KV-DHARJAYGARH-JHARSUGUDA	243	242	817	-589	0	0.04	0.04
7	765KV-DHARJAYGARH-RANCHI	-1,685	-1,571	-	-2,033	0	-32.54	-32.54
8	765KV-RAIPUR-PS (DURG)-JHARSUGUDA	189	167	460	-75	4.58	0	4.58
Sub-Total EAST REGION		-1,377	-1,324	1,485	-3,196	7.78	-40.13	-32.35
NORTH REGION WEST REGION //Import/Export between NORTH REGION and WEST REGION								
1	132KV-RAJGHAT-LALITPUR	0	0	-	0	0	0	0
2	220KV-BHANPURA-MODAK	-110	-110	-	-110	0	-2.41	-2.41
3	220KV-BHANPURA-RANPUR	-30	-30	-	-30	0	-1.77	-1.77
4	220KV-MALANPUR-AURIYA	-37	-40	58	-71	0.14	-0.69	-0.55
5	220KV-MEHGAON-AURIYA	-24	0	9	-32	0	-0.05	-0.05
6	400KV-KANSARI-KANKROLI	-211	-29	255	-278	0.97	-1.88	-0.91
7	400KV-KANSARI-KANKROLI 2(BYPASS AT BHINMAL)	0	-20	177	-144	0.67	-0.56	0.11
8	400KV-NEEMUCH-CHITTORGARH	-546	-446	338	-690	1.08	-7.06	-5.98
9	400KV-SUJALPUR-RAPP	-577	-466	259	-689	0.84	-7.91	-7.07
10	400KV-VINDHYACHAL PS-RIHAND(III)	-1	-1	-	-1	0	0	0
11	765KV-BANASKANTHA-CHITTORGARH	-1,195	-454	958	-1,964	2.31	-17.6	-15.29
12	765KV-GWALIOR-AGRA	-2,669	-2,364	-	-3,205	0	-51.55	-51.55
13	765KV-GWALIOR-JAIPUR	-1,780	-1,598	250	-1,947	0.35	-30.18	-29.83
14	765KV-GWALIOR-ORAI	558	510	949	-	12.94	0	12.94
15	765KV-JABALPUR-ORAI	-1,305	-1,221	-	-1,456	0	-47.52	-47.52
16	765KV-SATNA-ORAI	-1,164	-1,096	-	-1,245	0	-22.95	-22.95
17	765KV-VINDHYACHAL(PS)-VARANASI	-3,329	-3,035	-	-3,827	0	-64.88	-64.88
18	HVDC400KV-VINDYACHAL(PS)-RIHAND	46	46	46	-	1.24	0	1.24
19	HVDC500KV-MUNDRA-MOHINDARGARH	-1,446	-1,448	-	-1,453	0	-36.31	-36.31
20	HVDC800KV-CHAMPA-KURUKSHETRA	-2,920	-2,920	-	-2,923	0	-71.5	-71.5
Sub-Total NORTH REGION		-16,740	-14,722	3,299	-20,065	20.54	-364.82	-344.28
SOUTH REGION WEST REGION //Import/Export between SOUTH REGION and WEST REGION								
1	220KV-KOLHAPUR-CHIKKODI-II	-	-	-	-	-	-	0
2	220KV-PONDA-AMBEWADI	0	0	-	0	0	0	0
3	220KV-TALANGADE(MS)-CHIKKODI-II	-	-	-	-	-	-	0
4	220KV-XELDEM-AMBEWADI	83	69	-	99	1.9	0	1.9
5	400KV-KOLHAPUR GIS-NARENDRA KUDGI	1,423	1,566	2,005	-	33.37	0	33.37
6	765KV-SOLAPUR-RAICHUR	1,424	2,115	2,538	-494	32.09	-0.3	31.79
7	765KV-WARDHA-NIZAMABAD	-426	-373	336	-2,568	0.22	-20.46	-20.24
8	765KV-WARORA-PG-WARANGAL	-361	-198	402	-2,486	0.32	-18.25	-17.93
9	HVDC205KV-BHADRAWATI-RAMAGUNDAM	998	999	1,003	-	22.4	0	22.4
10	HVDC400KV-BARSUR-L.SILERU	-	-	-	-	-	-	0
11	HVDC800KV-RAIGARH-GIS-HVDC-PUGALUR	-1,300	-899	-	-1,303	0	-23.31	-23.31
Sub-Total SOUTH REGION		1,841	3,279	6,284	-6,752	90.3	-62.32	27.98
TOTAL IR EXCHANGE		-16,276	-12,767	11,068	-30,013	118.62	-467.27	-348.65

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU									
	ISGS+GNA+URS Schedule	TGNA BILT Schedule	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
WR-ER	30.12	-21.94		7.66		0	9.81	-32.35	-42.16
WR-NR	-215.42	-127.47		4.69		0	-343.89	-344.28	-0.39
WR-SR	-16.51	41.34		-69.93		0	-21.24	27.98	49.22
Total	-201.81	-108.07	0	-57.58	0	0	-355.32	-348.65	6.67

5.Frequency Profile								
RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50.05
%	.00	.00	.00	.00	.00	15.80	66.40	17.80
Percentage of Time Frequency Remained outside IEGC Band					33.6			
No. of hours frequency outside IEGC Band					8.064			

अधिकतम /Maximum		न्यूनतम/Minimum		औसत/Average Frequency	Freq Variation Index	Standard Deviation	Freq. in 15 mnt blk	
Frequency	Time	Frequency	Time				Max.	Min.
50.33	23:57:20	49.72	12:38:50	49.99	0.079	0.088	50.27	49.8

6.वोल्टेज प्रोफाइल/Voltage Profile: 400kV								
	अधिकतम/Maximum		न्यूनतम/Minimum		वभिवांतर/Voltage (in %)			Hours Volatge Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	>= 4000	IEGC Band (A)	> 420	(100-A)*24/100
AMRELI - 400KV	433.55	04:01	418.07	15:55	0	1.5	98.5	23.7
ASOJ - 400KV	419.9	04:01	401.04	16:56	0	100	0	0

BHILAI - 400KV	413.59	13:06	405.22	06:26	0	100	0	0
BHOPAL - 400KV	416.56	13:03	402.15	19:52	0	100	0	0
BOISAR - 400KV	421.18	04:01	402.05	09:25	0	96.3	3.8	.9
DEHGAM - 400KV	423.54	02:59	405.84	09:25	0	81.6	18.4	4.4
DHULE - 400KV	417.47	13:03	404.75	19:21	0	100	0	0
DAMOH - 400KV	415.34	13:03	398.06	22:18	0	100	0	0
GPEC - 400KV	420	16:45	152.16	14:23	0	90.1	0	2.4
GWALIOR - 400KV	409.45	08:01	387.63	22:16	0	100	0	0
HAZIRA - 400KV	416.48	04:38	390.84	10:25	0	100	0	0
INDORE - 400KV	414.96	13:03	403.79	19:14	0	100	0	0
ITARSI - 400KV	414.65	13:04	401.5	19:47	0	100	0	0
JETPUR - 400KV	430.51	04:02	413.83	16:52	0	37.6	62.4	15
KALA - 400KV	410.57	23:19	389.31	09:25	0	100	0	0
KALWA - 400KV	418.94	03:52	393	10:29	0	100	0	0
KARAD - 400KV	423.35	20:53	403.28	11:56	0	93.6	6.4	1.5
KASOR - 400KV	424.01	04:01	406.04	09:25	0	81.3	18.8	4.5
KHANDWA - 400KV	418.71	13:03	406.77	19:14	0	100	0	0
MAGARWADA - 400KV	413.66	00:00	413.66	00:00	0	100	0	0
MAPUSA - 400KV	419.31	02:28	384.84	11:56	0	100	0	0
NAGDA - 400KV	416.56	13:03	404.84	19:25	0	100	0	0
NEW KOYNA - 400KV	428.54	20:48	412.55	11:58	0	28.1	71.9	17.3
PARLI - 400KV	417.57	20:51	393.03	12:02	0	100	0	0
RAIPUR - 400KV	414.78	13:07	407.05	06:34	0	100	0	0
RAIGARH - 400KV	421.38	13:04	415.41	06:17	0	96.6	3.4	.8
VAPI - 400KV	411.52	04:01	390.28	10:28	0	100	0	0
WARDHA - 400KV	422.53	13:01	407.08	06:12	0	96.5	3.5	.9

6.1 Voltage Profile: 765kV

	/Maximum		/Minimum		/Voltage (in %)			Hours Voltage Outside IEGC Range(VDI)
STATION	VOLTAGE	TIME	VOLTAGE	TIME	< 728	IEGC Band (A)	> 800	(100-A)*24/100
BINA - 765KV	793.14	13:04	755.51	22:16	0	100	0	0
DURG - 765KV	780.13	23:55	761.69	07:19	0	100	0	0
GWALIOR - 765KV	792.85	07:53	749.53	04:25	0	100	0	0
INDORE - 765KV	779.52	13:04	755.55	19:14	0	100	0	0
KOTRA - 765KV	785.48	13:02	768.95	21:24	0	100	0	0
SASAN - 765KV	786.77	10:49	762.37	22:13	0	100	0	0
SATNA - 765KV	793.98	10:02	763.25	19:55	0	100	0	0
SEONI - 765KV	793	13:02	764	22:14	0	100	0	0
SIPAT - 765KV	779.14	13:01	759.93	21:25	0	100	0	0
TAMNAR - 765KV	782.99	13:02	767.79	21:24	0	100	0	0
VADODARA - 765KV	796.75	04:01	767.8	16:54	0	100	0	0
WARDHA - 765KV	792.78	00:00	792.78	00:00	0	100	0	0

7(A).Power Energy/Schedule Details

State	Off- Peak Hours (03:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	8.7	-	20.29	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	0	-	0	-	0	-	-	-	-
CHHATTISG ..	-412.12	-	-36.7	-	-56.3	-	0	-	0	-	-	-	-
DNHDDPDCL	16.43	-	126.6	-	67.65	-	0	-	0	-	-	-	-
GOA	106.31	-	-98	-	0	-	0	-	0	-	-	-	-
GUJARAT	-26.32	-	1,253.75	-	16.23	-	0	-	0	-	-	-	-
MADHYA PRADESH	-191.5	-	34.4	-	0	-	0	-	0	-	-	-	-
MAHARASHT..	-142.15	-	-41.28	-	566.19	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	-649.35	0	1,247.47	-	614.06	0	0	-	0	-	-	-	-

State	Peak Hours (20:00)												
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX HPDAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL HPDAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM(MW)	HPX HPDAM (MW)	HPX RTM (MW)
AMNSIL	0	-	15.46	-	32.86	-	0	-	0	-	-	-	-
BALCO	0	-	0	-	449.38	-	0	-	0	-	-	-	-
CHHATTISG ..	-412.22	-	-33.1	-	-110.9	-	0	-	0	-	-	-	-
DNHDDPDCL	16.43	-	149.79	-	4.83	-	0	-	0	-	-	-	-
GOA	106.31	-	-20	-	-70	-	0	-	0	-	-	-	-
GUJARAT	-235.61	-	1,765.4	-	-3.37	-	0	-	0	-	-	-	-
MADHYA PRADESH	-190.78	-	-633.3	-	-1,549.05	-	0	-	0	-	-	-	-
MAHARASHT ..	-579.11	-	690.33	-	568.08	-	0	-	0	-	-	-	-
RIL JAMNAGAR	0	-	0	-	0	-	0	-	0	-	-	-	-
TOTAL	-1,294.98	0	1,934.58	0	-678.17	0	0	-	0	-	-	-	-

State	Day Energy (MU)						
	ISGS + GNA Schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	HPDAM Schedule	RTM Schedule	Total (MU)
AMNSIL	7.33	0	1.31	0.24	-	0.53	9.41
BALCO	9.54	1.39	0	0	-	1.74	12.67
CHHATTISGARH	71.23	-6.58	-0.03	-1.73	-	-0.97	61.92
DNHDDPDCL	25.19	1.09	0	3.81	-	1.35	31.44
GOA	11.43	2.02	0	-0.92	-	-0.41	12.12
GUJARAT	159.7	0.04	2.19	22.2	-	2.52	186.65
MADHYA PRADESH	140.7	-4.07	0	0.04	-	-16.7	119.97
MAHARASHTRA	157.58	-4.9	0.99	-1.36	-	13.61	165.92
RIL JAMNAGAR	5.74	0	0	0	-	0	5.74
TOTAL	588.44	-11.01	4.46	22.28	0	1.67	605.84

7(B).Power Energy/Schedule Details

State	ISGS + GNA Schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)		HPX GDAM(MW)		IEX DAM (MW)		PXIL DAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	402.7	193.28	0	0	111.14	0	0	0	0	0	36.72	0	0	0
BALCO	529	18	172.02	0	0	0	0	0	0	0	0	0	0	0
CHHATTISGARH	3,208.71	2,670.19	-136.22	-412.22	0	-4.5	0	0	0	0	-32.5	-522.7	0	0
DNHDDPDCL	1,148.69	1,004.83	93.74	16.43	0	0	0	0	0	0	260.93	67.65	0	0
GOA	566.54	391.06	119.64	28.99	0	0	0	0	0	0	0	-141	0	0
GUJARAT	7,479.57	5,160.74	241.31	-235.61	203.91	3.87	0	0	0	0	2,528.53	14.76	0	0
MADHYA PRADESH	7,661.85	4,931.45	-129.95	-192.01	96.82	-49.5	0	0	0	0	741.4	-865.82	0	0
MAHARASHTRA	7,751.91	5,992.25	60.47	-610.54	168.92	-58.01	0	0	0	0	929.76	-405.1	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

State	HPX DAM(MW)		IEX HPDAM (MW)		PXIL HPDAM(MW)		HPX HPDAM(MW)		IEX RTM (MW)		PXIL RTM(MW)		HPX RTM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
AMNSIL	0	0	0	0	0	0	0	0	93.74	0	0	0	0	0
BALCO	0	0	0	0	0	0	0	0	508.33	0	0	0	0	0
CHHATTISGARH	0	0	0	0	0	0	0	0	235.3	-309.9	0	0	0	0
DNHDDPDCL	0	0	0	0	0	0	0	0	106.3	0	0	0	0	0
GOA	0	0	0	0	0	0	0	0	0	-70	0	0	0	0
GUJARAT	0	0	0	0	0	0	0	0	514.15	-159.96	0	0	0	0
MADHYA PRADESH	0	0	0	0	0	0	0	0	99.91	-2,777.65	0	0	0	0
MAHARASHTRA	0	0	0	0	0	0	0	0	1,063.27	-83.1	0	0	0	0
RIL JAMNAGAR	-	-	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL(Mts)	FRL(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Level(Mts)	Energy(MU)	Inflow(Mus)		"Prog.Inflow (Mus)"	"Prog.Usage (Mus)"
INDIRASAGAR	243.23	262.13	1,367	250.86	337.84	248.55	225.28	-		0	0
OMKARESHWAR	193.3	196.6	21.958	193.71	-	195.49	-	-		0	0
UKAI	82.296	105.156	770.67	96.129	287.289	93.09	193.243	0		0	0
KADANA	114.3	127.711	126.266	117.017	10.041	118.437	17.166	-		0	0
SSP	110.64	138.68	1,342.091	118.78	205.55	120.52	264.58	0		0	0
KOYNA	615.54	659.43	3,160	637.05	2,969.558	623.5	2,919.132	56.227		0	0
TATA BHIRA	590.1	607.1	582.4	597.71	221.22	591.33	30.36	597.44		0	0

9.Significant events (If any):

10.System Constraints (If any)

11. Weather Condition:

12. RE/Load Curtailment details								
	Load Curtailment			RE Curtailment				
State	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
AMNSIL	0	0	0	0	0	0	0	
BALCO	0	0	0	0	0	0	0	
CHHATTISGARH	0	0	0	0	0	0	0	
DAMAN AND DIU	0	0	0	0	0	0	0	
GOA	0	0	0	0	0	0	0	
GUJARAT	0	0	0	0	0	0	0	
MADHYA PRADESH	0	0	0	0	0	0	0	
MAHARASHTRA	0	0	0	0	0	0	0	
RIL JAMNAGAR	0	0	0	0	0	0	0	

Shift In Charge