



GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTHERN REGION

Power Supply Position in Northern Region For 23-Jun-2025

Date of Reporting:24-Jun-2025

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
78,929	0	78,929	50.06	66,621	0	66,621	49.99	1,753	0

2(A)State's Load Deails (At State Periphery) in MU:

State	State's Control Area Generation (Net MU)							Drawal Sch	Act Drawal	UI	Requirement	Shortage	Consumption
	Thermal	Hydro	Gas/Naptha/ Diesel	Solar	Wind	OthersBiomass/Co-gen etc.)	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
PUNJAB	104.46	19.57	0	4.35	0	2.37	130.75	208.36	208.15	-0.21	338.9	0	338.9
HARYANA	64.92	0.66	0	1.05	0	1.14	67.77	207.93	204.25	-3.68	272.02	0	272.02
RAJASTHAN	107.53	3.19	1.68	31.92	21.1	5.75	171.17	131.97	127.5	-4.47	298.67	0	298.67
DELHI	0	0	14.77	0	0	1.87	16.64	132.68	131.95	-0.73	148.59	0	148.59
UTTAR PRADESH	241.57	23.3	0	10.4	0	0.7	275.97	259.54	261.46	1.92	537.43	0	537.43
UTTARAKHAND	0	17.73	0.76	0.53	0	0	19.02	33.31	33.77	0.46	52.79	0	52.79
HIMACHAL PRADESH	0	39.29	0	0.14	0	0	39.42	-0.61	-1.41	-0.8	38.01	0	38.01
J&K(UT) & Ladakh(UT)	0	25.52	0	0	0	0	25.52	29.35	29	-0.35	54.52	0	54.52
CHANDIGARH	0	0	0	0	0	0	0	7.67	7.65	-0.02	7.65	0	7.65
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	3.91	3.98	0.07	3.98	0	3.98
Region	518.48	129.26	17.21	48.39	21.1	11.83	746.26	1,014.11	1,006.3	-7.81	1,752.56	0	1,752.56

2(B)State Demand Met (Peak and off-peak Hrs)

State	Evening Peak (20:00) MW				AVG DEMAND MW	Off-Peak (03:00) MW			
	Demand Met	Shortage	UI	STOA/PX/RTM Transaction		Demand Met	Shortage	UI	STOA/PX/RTM Transaction
PUNJAB	14,093	0	84	3,127	14,143	10,640	0	56	1,849
HARYANA	11,574	0	-248	1,887	11,455	10,875	0	-348	2,373
RAJASTHAN	12,525	0	-478	512	12,338	11,667	0	21	331
DELHI	5,917	0	-412	1,429	6,174	5,666	0	216	1,629
UTTAR PRADESH	27,497	0	-82	3,861	22,231	22,353	0	-180	2,776
UTTARAKHAND	2,496	0	-34	-17	2,203	1,978	0	27	218
HIMACHAL PRADESH	1,698	0	15	-887	1,597	1,274	0	-27	-1,177
J&K(UT) & Ladakh(UT)	2,580	0	-56	-331	2,272	1,722	0	41	-1,201
CHANDIGARH	359	0	19	-9	319	261	0	1	-61
RAILWAYS_NR ISTS	190	0	22	57	166	186	0	18	57
Region	78,929	0	-1,170	9,629	72,898	66,622	0	-175	6,794

2(C)State's Demand Met in MWs (Maximum Demand Met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day						ACE			
	Maximum Demand Met of the day	Time	Shortage during at maximum demand	Requirement at the max demand met of the day	Maximum Requirement of the day	Time	Shortage during at maximum Requirement	Demand Met at maximum requiremnet	Min Demand Met	Time	ACE_MAX	Time	ACE_MIN	Time
PUNJAB	16,623	14:00	0	16,623	16,623	14:00	0	16,623	10,640	3:00	667.74	08:31:00	-849.86	07:09:00
HARYANA	13,499	14:00	0	13,499	13,499	14:00	0	13,499	9,840	6:00	764.79	00:01:00	-347.17	15:01:00
RAJASTHAN	13,223	14:00	0	13,223	13,223	14:00	0	13,223	11,359	18:00	1,508.28	11:29:00	-585.99	12:41:00
DELHI	7,459	15:00	0	7,459	7,459	15:00	0	7,459	4,908	7:00	422.8	20:02:00	-370.52	14:29:00
UP	28,288	21:00	0	28,288	28,288	21:00	0	28,288	15,897	7:00	950.51	04:59:00	-951.94	03:01:00
UTTARAKHA ..	2,496	20:00	0	2,496	2,496	20:00	0	2,496	1,978	3:00	336.59	14:20:00	-167.98	18:56:00
HP	1,818	10:00	0	1,818	1,818	10:00	0	1,818	1,261	2:00	143.2	13:58:00	-91.89	15:28:00
J&K(UT)&Lad ..	2,660	21:00	0	2,660	2,660	21:00	0	2,660	1,722	3:00	365.04	00:04:00	-285.32	10:11:00
CHANDIGARH	392	14:00	0	392	392	14:00	0	392	234	6:00	66.14	16:59:00	-31.26	09:29:00
RAILWAYS_NR ISTS	201	18:00	0	201	201	18:00	0	201	110	13:00	0	-	0	-
NR	80,739	22:00	0	80,739	80,739	22:00	0	80,739	61,480	6:00	0	-	0	-

3(A) State Entities Generation:

CHANDIGARH										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
NIL										
Total	0	0	0					0	0	0
Total	0	0	0					0	0	0

DELHI										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAWANA GPS(2 * 253 + 4 * 216)	1,370	277	265	288.22	22:00	0		6.78	6.5	271
DELHI GAS TURBINES(3 * 34 + 6 * 30)	282	71	71	72.23	02:00	0		1.69	1.59	66
PRAGATI GAS TURBINES(1 * 121.2 + 2 * 104.6)	331	285	269	289.14	13:00	0		6.84	6.68	278
RITHALA GPS(3 * 36)	108	0	0	0		0				
Total GAS/NAPTHA/DIESEL	2,091	633	605					15.31	14.77	615
WIND	0	0	0	0		0				
BIOMASS(52)	52	66	54	0		0		1.9	1.87	78
SOLAR(2)	2	0	0	0		0				
Total DELHI	2,145	699	659					17.21	16.64	693

HARYANA										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
DCRTPP (YAMUNA NAGAR)(2 * 300)	600	383	341	522	14:00	334	17:30	10.36	9.37	390
JHAJJAR(CLP)(2 * 660)	1,320	1,034	744	1,219	23:00	735	11:15	24.3	22.67	945
MAGNUM DIESEL (IPP)(4 * 6.3)	25	0	0	0		0				
PANIPAT TPS(1 * 210 + 2 * 250)	710	548	540	660	00:00	534	07:00	14.04	12.67	528
RGTPP(KHEDAR)(2 * 600)	1,200	845	820	965	22:00	829	09:30	20.82	20.21	842
Total THERMAL	3,855	2,810	2,445					69.52	64.92	2,705
FARIDABAD GPS(1 * 156.07 + 2 * 137.75)	432	0	0	0		0				
Total GAS/NAPTHA/DIESEL	432	0	0					0	0	0
TOTAL HYDRO HARYANA(64.8)	65	36	15	37	22:00	14	08:45	0.66	0.66	28
Total HYDEL	65	36	15					0.66	0.66	28
WIND	0	0	0	0		0				
BIOMASS(106)	106	0	0	0		0		1.14	1.14	48
SOLAR(196)	196	0	0	0		0		1.05	1.05	44
Total HARYANA	4,654	2,846	2,460					72.37	67.77	2,825

HIMACHAL PRADESH										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAJOLI HOLI(3*60)	180	198	198	198	01:00	198	06:00	4.75	4.75	198
BASPA (IPP) HPS(3 * 100)	300	330	330	330	01:00	328	06:00	7.93	7.93	330
MALANA (IPP) HPS(2 * 43)	86	89	86	89	01:00	57	11:00	1.99	1.99	83
MALANA2(2 * 50)	100	0	0	0		0				
SAWARA KUDDU(3 * 37)	111	48	41	111	08:00	0	06:00	1.02	1.02	43
OTHER HYDRO HP(503.75)	504	419	374	0		0		9.17	9.13	380
Total HYDEL	1,281	1,084	1,029					24.86	24.82	1,034
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR(1 * 19)	19	0	0	0		0		0.14	0.14	6
SMALL HYDRO(765.25)	765	640	604	0		0		14.67	14.47	603
Total SMALL HYDRO	765	640	604					14.67	14.47	603
Total HP	2,065	1,724	1,633					39.67	39.43	1,643

J&K(UT) & LADAKH(UT)										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAS/DIESEL/OTHERS J&K(1 * 190)	190	0	0	0		0				
Total GAS/NAPTHA/DIESEL	190	0	0					0	0	0
BAGLIHAR (IPP) HPS(6 * 150)	900	0	0	0		0		21.34	21.34	889
OTHER HYDRO/IPP J&K(308)	308	0	0	0		0		4.18	4.18	174
Total HYDEL	1,208	0	0					25.52	25.52	1,063
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	0	0	0	0		0				
SMALL HYDRO(98)	98	0	0	0		0				
Total SMALL HYDRO	98	0	0					0	0	0
Total J&K(UT)&Ladakh(UT)	1,496	0	0					25.52	25.52	1,063

PUNJAB										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GOINDWAL(GVK)(2 * 270)	540	491	290	491	16:00	290	01:00	9.96	8.94	373
GURU GOBIND SINGH TPS (ROPAR)(4 * 210)	840	650	439	668	23:00	146	07:00	14.89	13.31	555
GURU HARGOBIND SINGH TPS (LEHRA MOHABBAT)(2 * 210 + 2 * 250)	920	598	474	604	21:00	474	01:00	14.83	13.46	561
RAJPURA(NPL) TPS(2 * 700)	1,400	1,320	1,320	1,320	01:00	1,170	04:00	32.88	31.42	1,309
TALWANDI SABO TPS(3 * 660)	1,980	1,831	1,324	1,841	12:00	924	05:00	40.02	37.33	1,555
Total THERMAL	5,680	4,890	3,847					112.58	104.46	4,353
ANANADPUR SAHIB HYDRO PLANT(2 * 33.5 + 2 * 33.5)	134	114	114	115	07:00	114	01:00	2.78	2.78	116
MUKERIAN HYDRO PLANT(6 * 15 + 6 * 19.5 + 2 * 9)	225	137	150	150	01:00	85	10:00	2.94	2.94	123
RANJIT SAGAR POWER PLANT (4 * 150)	600	240	480	560	16:00	0	07:00	8.32	8.3	346
SHANAN(4 * 15 + 1 * 50)	110	110	110	110	01:00	110	01:00	2.64	2.64	110
UBDC(3 * 15 + 3 * 15.5)	92	82	82	82	01:00	82	01:00	1.96	1.95	81
OTHER HYDRO PUNJAB	0	0	0	0		0		0.97	0.97	40
Total HYDEL	1,161	683	936					19.61	19.58	816
WIND	0	0	0	0		0				
BIOMASS(303)	303	0	0	0		0		2.37	2.37	99
SOLAR(881)	881	43	43	480	13:00	43	01:00	4.35	4.35	181
Total PUNJAB	8,025	5,616	4,826					138.91	130.76	5,449

RAJASTHAN										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BARSINGSAR (IPP) LTPS(2 * 125)	250	110	109	111	17:00	109	06:00	2.94	2.51	105
CHHABRA TPS(2 * 660 + 4 * 250)	2,320	1,113	1,145	1,462	01:00	1,043	13:00	30.97	28.41	1,184
GIRAL (IPP) LTPS(2 * 125)	250	0	0	0		0				
KALISINDH TPS(2 * 600)	1,200	405	311	435	07:00	322	11:00	9.68	8.96	373
KAWAI TPS(2 * 660)	1,320	1,150	723	1,248	22:00	723	12:00	21.86	20.55	856
KOTA TPS(2 * 110 + 2 * 195 + 3 * 210)	1,240	123	135	164	23:00	124	12:00	3.82	3.4	142
RAJWEST (IPP) LTPS(8 * 135)	1,080	828	630	832	00:00	618	11:00	20.12	17.48	728
SURATGARH TPS (6 * 250 + 2 * 660(SSCTPS))	2,820	1,141	876	1,229	23:00	854	12:00	25.43	23.69	987
VSLPP (IPP)(1 * 135)	135	107	106	107	20:00	105	08:00	2.9	2.53	105
Total THERMAL	10,615	4,977	4,035					117.72	107.53	4,480
DHOLPUR GPS(3 * 110)	330	0	0	0		0				
RAMGARH GPS(1 * 110 + 1 * 35.5 + 1 * 50 + 2 * 37.5)	271	68	68	69	09:00	68	17:00	1.74	1.68	70
Total GAS/NAPTHA/DIESEL	601	68	68					1.74	1.68	70
RAPS-A(1 * 100 + 1 * 200)	300	153	150	153	20:00	150	12:00	3.99	3.7	154
Total NUCLEAR	300	153	150					3.99	3.7	154
TOTAL HYDRO RAJASTHAN(550)	550	134	133	134	12:00	133	11:00	3.19	3.19	133
Total HYDEL	550	134	133					3.19	3.19	133
WIND(1 * 4328)	4,328	760	1,708	1,944	01:00	260	10:00	21.1	21.1	879
BIOMASS(102)	102	85	85	85	01:00	85	06:00	2.05	2.05	85
SOLAR(4568)	4,568	24	0	4,620	12:00	0	06:00	31.92	31.92	1,330
Total RAJASTHAN	21,064	6,201	6,179					181.71	171.17	7,131

UTTAR PRADESH										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
ANPARA TPS(2 * 500 + 3 * 210)	1,630	1,347	1,170	1,350	07:00	969	08:00	32.8	30.4	1,267
ANPARA-C TPS(2 * 600)	1,200	934	925	939	06:00	634	09:00	23	21.2	883
ANPARA-D TPS(2 * 500)	1,000	477	946	947	12:00	471	16:00	17.9	16.8	700
BAJAJ ENERGY PVT LTD (IPP) TPS(10 * 45)	450	0	0	0		0				
BARA PPGCL TPS(3 * 660)	1,980	1,727	1,186	1,739	21:00	1,067	08:00	39.5	36.5	1,521
GHATAMPUR TPS (1*660)	660	564	336	573	21:00	320	05:00	11.6	10.5	438
HARDUAGANJ TPS(1 * 110 + 2 * 250 + 1*660)	1,270	556	317	560	16:00	310	11:00	10.6	9.5	396
INFIRM POWER	660	0	0	139	23:59	0	01:00	0	0	0
JAWAHARPUR TPS(2*660)	1,320	0	0	0		0				
JP CHURK(3 * 60)	180	0	0	0		0				
KHURJA TPS(1 * 660)	660	662	649	688	21:32	0		11.83	10.77	449
LALITPUR TPS(3 * 660)	1,980	1,195	732	1,223	15:00	676	04:00	24.7	23.1	963
MEJA TPS(2 * 660)	1,320	1,223	713	1,224	22:00	680	11:00	22.7	21.3	888
OBRA TPS(5 * 200+1*660)	1,660	886	911	936	15:00	731	08:00	23.2	20.9	871
PANKI_I TPS(1 * 660)	660	0	0	0		0				
PARICHA TPS(2 * 210 + 2 * 250)	920	741	474	751	19:00	474	03:00	14.8	13.4	558
ROSA TPS(4 * 300)	1,200	1,078	608	1,082	21:00	593	10:00	20.6	18.8	783
TANDA TPS(4 * 110)	440	334	361	373	15:00	327	19:00	9.5	8.4	350
Total THERMAL	19,190	11,724	9,328					262.73	241.57	10,067
ALAKHANANDA HEP(4 * 82.5)	330	343	349	351	16:00	326	10:00	8.3	8.3	346
RIHAND HPS(6 * 50)	300	240	145	240	20:00	0	05:00	2.6	2.6	108
VISHNUPARYAG HPS(4 * 110)	440	396	396	436	07:00	396	01:00	10	10	417
OTHER HYDRO UP(227)	227	103	104	128	01:00	74	11:00	2.4	2.4	100
Total HYDEL	1,297	1,082	994					23.3	23.3	971
WIND	0	0	0	0		0				
BIOMASS(26)	26	0	0	0		0				
SOLAR(2430)	2,642	0	0	1,270	14:00	0	01:00	10.4	10.4	433
CO-GENERATION(1360)	1,360	30	30	30	01:00	0		0.7	0.7	29
Total OTHERs	1,360	30	30					0.7	0.7	29
Total UP	24,515	12,836	10,352					297.13	275.97	11,500

UTTARAKHAND										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAMMA	225	0	0	0		0				
SARAVANTI	450	90	0	95	23:00	28	15:00	0.81	0.76	32
Total GAS/NAPTHA/DIESEL	675	90	0					0.81	0.76	32
OTHER HYDRO UK(1250)	1,250	1,006	477	1,006	20:00	491	06:00	17.79	17.73	739
Total HYDEL	1,250	1,006	477					17.79	17.73	739
WIND	0	0	0	0		0				
BIOMASS(127)	127	0	0	0		0				
SOLAR(278)	278	0	0	83	13:00	4	07:00	0.53	0.53	22
SMALL HYDRO(180)	180	0	0	0		0				
Total SMALL HYDRO	180	0	0					0	0	0
Total UTTARAKHAND	2,510	1,096	477					19.13	19.02	793

(B) Regional Entities Generation														
Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy				AVG. MW	UI(Actual-Schedule-(+- AGC))
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen ACT (MU)	Net Gen ACT MU)	AGC(MU)		
Aravali Power Company Private Ltd														
ISTPP (JHAJJAR)(3 * 500)	1,500	1,411	1,011	577	1,017	19:30	539	15:00	14.6	16.07	14.61	0.3	609	-0.29
Sub-Total	1,500	1,411	1,011	577	-	-	-	-	14.6	16.07	14.61	0.3	609	-0.29
BBMB														
BHAKRA HPS(5 * 126 + 5 * 157)	1,415	1,335	1,275	987	1,373	22:00	892	14:00	24.7	25.22	24.87	0	1,036	0.17
DEHAR HPS(6 * 165)	990	640	660	600	660	22:00	580	14:00	13.98	14.6	14.28	0	595	0.3
PONG HPS(6 * 66)	396	245	250	100	250	22:00	50	12:00	2.64	2.73	2.92	0	122	0.28
Sub-Total	2,801	2,220	2,185	1,687	-	-	-	-	41.32	42.55	42.07	0	1,753	0.75
INFIRM														
TEHRI PSP	1,000	135	0	0	0	-	0	-	0.36	0.37	0.37	0	15	0.01
Sub-Total	1,000	135	0	0	-	-	-	-	0.36	0.37	0.37	0	15	0.01
NHPC														
BAIRASIUL HPS(3 * 60)	180	186	184	124	186	19:30	0	-	2.81	2.95	2.92	0	122	0.11
CHAMERA I HPS(3 * 180)	540	535	542	538	550	22:00	0	-	9.52	9.77	9.64	0	402	0.12
CHAMERA II HPS(3 * 100)	300	312	306	302	306	20:00	0	-	7.16	7.26	7.21	0.03	300	0.02
CHAMERA III HPS(3 * 77)	231	240	234	232	234	20:00	208.3	00:00	5.51	5.53	5.47	-0.01	228	-0.03
DHAULIGANGA HPS(4 * 70)	280	290	288	281	288	20:00	199.5	15:00	6.42	6.47	6.45	-0.01	269	0.04
DULHASTI HPS(3 * 130)	390	385	380	377	381	19:00	351.6	11:00	9.05	9.06	8.95	0	373	-0.1
KISHANGANGA(3 * 110)	330	336	337	335	337	20:00	0	-	7.94	8.01	8	0	333	0.06
PARBATI III HEP(4 * 130)	520	810	391	391	392	21:00	0	-	18.6	9.33	9.28	0	387	-9.32
PARBATI-II(4 * 200)	800	-	789	788	802	17:00	773.3	00:00	-	19.04	18.34	0	764	-
SALAL HPS(6 * 115)	690	710	722	723	723	02:00	605	21:00	17	17.13	16.94	0	706	-0.06
SEWA-II HPS(3 * 40)	120	126	121	0	122	21:00	0	-	0.5	0.51	0.5	0	21	0
TANAKPUR HPS(1 * 31.42 + 2 * 31.4)	94	93	99	98	100	19:00	68.33	18:00	2.15	2.24	2.21	0	92	0.06
URI HPS(4 * 120)	480	430	427	447	462	10:45	346.21	16:00	10.17	10.4	10.32	0	430	0.15
URI-II HPS(4 * 60)	240	200	206	226	239	14:15	181.96	12:00	5.14	5.3	5.27	0	220	0.13
Sub-Total	5,195	4,653	5,026	4,862	-	-	-	-	101.97	113	111.5	0.01	4,647	-8.82
NPCL														
NAPS(2 * 220)	440	188	209	213	216	04:00	207	12:00	4.51	5.04	4.47	0	186	-0.04
RAPP-D	700	261	0	0	324	-	0	-	6.26	7.37	6.13	0	255	-0.13
RAPS-B(2 * 220)	440	359	403	405	409	10:00	397	01:00	8.62	9.76	8.64	0	360	0.02
RAPS-C(2 * 220)	440	405	447	446	449	08:00	446	01:00	9.72	10.76	9.7	0	404	-0.02
Sub-Total	2,020	1,213	1,059	1,064	-	-	-	-	29.11	32.93	28.94	0	1,205	-0.17
NTPC														
ANTA GPS(1 * 153.2 + 3 * 88.71)	419	365	0	0	246	23:18	0	-	0.59	0.51	0.49	0	20	-0.1
AURAIYA GPS(2 * 109.3 + 4 * 111.19)	663	600	0	0	405	23:15	0	-	0.89	0.85	0.79	0	33	-0.1
DADRI GPS(2 * 154.51 + 4 * 130.19)	830	560	0	0	247	-	0	-	0.85	0.63	0.57	0	24	-0.28
DADRI-I TPS(4 * 210)	840	769	0	0	0	-	0	-	0	-	-	-	-	-
DADRI-II TPS(2 * 490)	980	919	879	539	879	20:00	0	-	14.16	15.89	14.8	0	617	0.64
KOLDAM HPS(4 * 200)	800	871	864	868	872	07:00	0	-	20.91	21.01	20.9	0	871	-0.01
NTPC NOKH SOLAR PROJECT	245	0	0	0	0	-	0	-	3.43	3.45	3.45	0	144	0.02
RIHAND-I STPS(2 * 500)	1,000	850	928	892	940	22:00	543	11:00	18.18	19.49	17.62	-0.08	734	-0.48
RIHAND-II STPS(2 * 500)	1,000	943	985	1,010	1,021	06:00	542	11:00	20.99	22.39	20.82	-0.06	868	-0.11
RIHAND-III STPS(2 * 500)	1,000	943	966	995	1,009	06:00	524	11:00	21.08	22.25	21.05	-0.09	877	0.06
SINGRAULI HYDRO(1 * 8)	8	5	6	6	6	20:00	0	-	0.13	0.13	0.13	0	5	0
SINGRAULI STPS(2 * 500 + 5 * 200)	2,000	1,863	1,980	1,957	1,980	20:00	0	-	40.73	43.59	39.97	0	1,665	-0.76
TANDA TPS STAGE-II(2 * 660)	1,320	1,244	1,220	929	1,220	20:00	0	-	24.18	25.87	24.17	0	1,007	-0.01
UNCHAHAH II TPS(2 * 210)	420	379	412	297	427	19:30	243	10:00	6.35	7.49	6.65	0.21	277	0.09
UNCHAHAH III TPS(1 * 210)	210	191	211	148	211	20:00	119	18:00	3.19	3.63	3.27	0.1	136	-0.02
UNCHAHAH IV TPS(1 * 500)	500	466	492	452	504	22:00	289	14:00	8.45	9.25	8.55	0.19	356	-0.09
UNCHAHAH TPS(2 * 210)	420	365	392	272	393	19:30	235	17:30	6.11	6.88	5.96	0	248	-0.15
Sub-Total	12,655	11,333	9,335	8,365	-	-	-	-	190.22	203.31	189.19	0.27	7,882	-1.3
SJVNL														
NATHPA-JHAKRI HPS(6 * 250)	1,500	1,630	1,629	1,643	1,647	19:00	1,555	00:00	38.81	39.34	39.02	0	1,626	0.21
RAMPUR HEP(6 * 68.67)	412	449	448	445	450	06:00	434	11:00	10.54	10.82	10.74	0	448	0.2
Sub-Total	1,912	2,079	2,077	2,088	-	-	-	-	49.35	50.16	49.76	0	2,074	0.41
THDC														
KOTESHWAR HPS(4 * 100)	400	300	295	98	297	22:00	96	10:00	2.84	3.01	3	0.12	125	0.04

TEHRI HPS(4 * 250)	1,000	528	522	513	535	22:00	0	07:00	5.84	5.87	5.84	0	243	0
Sub-Total	1,400	828	817	611	-	-	-	-	8.68	8.88	8.84	0.12	368	0.04
Total	28,483	23,872	21,510	19,254					435.61	467.27	445.28	0.7	18,553	-9.37

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
IPP													
ADHPL(IPP) HPS(2 * 96)	192	208	187	211	211	03:00	0	-	4.46	4.37	4.33	180	-0.13
BUDHIL HPS (IPP)(2 * 35)	70	69	78	78	78	20:00	77.28	11:00	1.82	1.86	1.85	77	0.03
KARCHAM WANGTOO HPS(4 * 261.25)	1,045	1,116	0	0	1,130	-	0	-	26.79	26.84	26.73	1,114	-0.06
SAINJ HEP(2 * 50)	100	109	110	110	110	20:30	0	-	2.54	2.61	2.57	107	0.03
SHREE CEMENT (IPP) TPS(2 * 150)	300	342	0	0	0	-	0	-	4.05	4.22	3.92	163	-0.13
SINGOLI BHATWARI HEP(3 * 33)	99	98	99	95	99	20:00	0	-	2.03	2.33	2.31	96	0.28
SORANG HYDROELECTRIC PROJECT(2 * 50)	100	96	110	103	110	20:00	0	-	2.4	2.48	2.48	103	0.08
Sub-Total	1,906	2,038	584	597	-	-	-	-	44.09	44.71	44.19	1,840	0.1
SOLAR IPP													
ADANI GREEN ENERGY TWENTY FIVE LIMITED	357	0	0	0	0	-	0	-	2.93	2.94	2.94	123	0.01
ABC RENEWABLE ENERGY(1 * 300)	300	0	0	0	0	-	0	-	1.66	1.68	1.68	70	0.02
ACME CHITTORGARH SOLAR ENERGY PVT LTD(1 * 250)	250	0	0	0	218	11:45	0	-	1.39	1.31	1.31	55	-0.08
ACME DEOGHAR SOLAR POWER PRIVATE LIMITED(ADSPPL)	300	0	0	0	311	12:02	0	-	2.22	1.98	1.97	82	-0.25
ACME HEERGARH POWERTECH PRIVATE LIMITED(1*300)	300	0	0	0	0	-	0	-	1.69	1.71	1.71	71	0.02
ACME PHALODI SOLAR ENERGY PRIVATE LIMITED(APSEPL)	300	0	0	0	304	12:18	0	-	2.16	1.95	1.95	81	-0.21
ACME RAISAR SOLAR ENERGY PRIVATE LIMITED(ARSEPL)	300	0	0	0	312	12:17	0	-	2.18	1.99	1.98	83	-0.2
ACME SIKAR SOLAR PRIVATE LIMITED	53	0	0	0	0	-	0	-	1.07	1.09	1.09	45	0.02
ACMEDHAULPUR POWERTECH PRIVATE LIMITED(ADPPL)	300	0	0	0	309	12:04	0	-	2.24	1.97	1.97	82	-0.27
AMP ENERGY GREEN SIX PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.68	0.7	0.7	29	0.02
AMP GREEN ENERGY FIVE PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.61	0.63	0.63	26	0.02
ADANI GREEN ENERGY TWENTY FOUR LIMITED	405	0	0	0	0	-	0	-	2.77	2.78	2.78	116	0.01
ADANI RENEWABLE ENERGY RJ LIMITED (ARERJL)(1 * 200)	200	0	0	0	198	11:53	0	-	1.17	1.11	1.11	46	-0.06
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(1*150)	150	0	0	0	138	11:15	0	-	0.83	0.61	0.61	25	-0.22
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED (PROJECT-2)(1*150)	150	0	0	0	129	11:30	0	-	0.89	0.59	0.59	25	-0.3
ADANI SOLAR ENERGY RJ TWO PVT LTD _BHADLA(1*150)	150	0	0	0	145	11:33	0	-	0.86	0.94	0.94	39	0.08
ADANI SOLAR ENERGY RJ TWO PVT LTD _FATEGARH 2(1*180)	180	0	0	0	182	12:03	0	-	1.31	1.4	1.39	58	0.08
ADEPT RENEWABLE TECHNOLOGIES PVT LTD(1*110)	110	0	0	0	110	10:26	0	-	0.81	0.52	0.52	22	-0.29
ALTRA XERGI POWER PRIVATE LIMITED	380	0	0	0	0	-	0	-	2.65	2.66	2.66	111	0.01
AMP ENERGY GREEN FOUR PRIVATE LIMITED	84	0	0	0	0	-	0	-	0.55	0.56	0.56	23	0.01
AMPLUS AGES PRIVATE LIMITED(1*100)	100	0	0	0	91	10:29	0	-	0.54	0.42	0.42	18	-0.12
AURAIYA SOLAR(1 * 40)	40	0	0	0	0	-	0	-	0.19	0.19	0.18	8	-0.01
AVAADA RJHN PRIVATE LIMITED(1*240)	240	0	0	0	215	12:00	0	-	1.23	0.94	0.94	39	-0.29
AVAADA SUNCE ENERGY PRIVATE LIMITED, BIKANER(1 * 350)	350	0	0	0	311	11:30	0	-	1.78	1.34	1.34	56	-0.44
AVAADA SUNRAYS ENERGY PRIVATE LTD(1*320)	320	0	0	0	325	11:19	0	-	1.81	1.75	1.74	73	-0.07
AVAADA SUSTAINABLE RJPROJECT PVT LTD(1*300)	300	0	0	0	269	11:30	0	-	1.54	1.11	1.11	46	-0.43
AYANA RENEWABLE POWER ONE PRIVATE LIMITED, BIKANER(300)	300	0	0	0	283	11:25	0	-	1.56	1.23	1.23	51	-0.33
AYANA RENEWABLE THREE PVT LTD (1*300)	300	0	0	0	0	-	0	-	0	0	0	0	0
AZURE POWER FORTY THREE PRIVATE LIMITED(1 * 150 + 1 * 150 + 1 * 300)	600	0	0	0	533	11:30	0	-	3.07	2.31	2.31	96	-0.76
AZURE POWER INDIA PVT LTD.(4 * 50)	200	0	0	0	171	13:12	0	-	0.97	0.99	0.99	41	0.02
AZURE POWER MAPLE PVT LTD(1*300)	300	0	0	0	274	12:24	0	-	1.77	1.52	1.52	63	-0.25
AZURE POWER THIRTY FOUR PRIVATE LTD(1 * 130)	130	0	0	0	130	12:30	0	-	0.75	0.72	0.72	30	-0.03
BANDERWALA SOLAR PLANT LTD(1*300)	300	0	0	0	0	-	0	-	0.91	0.93	0.93	39	0.02
CLEAN SOLAR POWER (BHADLA) PVT LTD(1 * 300)	300	0	0	0	300	12:56	0	-	1.68	1.73	1.73	72	0.05
CLEAN SOLAR POWER(JODHPUR) PRIVATE LIMITED(1*250)	250	0	0	0	241	12:15	0	-	1.35	1.52	1.52	63	0.17
DADRI SOLAR(5)	5	0	0	0	3	-	0	-	0.02	0.02	0.02	1	0
DEVIKOT SOLAR POWER NTPC	240	0	0	0	0	-	0	-	1.5	1.52	1.52	63	0.02

EDEN RENEWABLE CITE PRIVATE LIMITED(1 * 300)	300	0	0	0	293	12:17	0	-	1.93	1.96	1.96	82	0.03
FATEHGARH SOLAR PV PROJECT(1*296)	296	0	0	0	296	11:51	0	-	2.17	1.92	1.88	78	-0.29
GORBEA SOLAR PRIVATE LIMITED	100	0	0	0	0	-	0	-	1.79	1.81	1.81	75	0.02
GRIAN ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	90	10:26	0	-	0.51	0.43	0.43	18	-0.08
JUNIPER GREEN COSMIC PRIVATE LIMITED	100	0	0	0	84	10:28	0	-	0.55	0.39	0.39	16	-0.16
JUNIPER NIRJARA ENERGY PRIVATE LIMITED	50	0	0	0	39	10:29	0	-	0.26	0.19	0.19	8	-0.07
KARNISAR SOLAR PLANT NHPC LIMITED	107	0	0	0	118	12:54	0	-	0.72	0.56	0.56	23	-0.16
KOLAYAT SOLAR POWER PLANT NTPC LIMITED(1*550)	550	0	0	0	0	-	0	-	3.34	3.35	3.35	140	0.01
M/S ADANI SOLAR ENERGY FOUR PRIVATE LIMITED(1 * 50)	50	0	0	0	45	12:01	0	-	0.28	0.26	0.26	11	-0.02
M/S ADANI SOLAR ENERGY JODHPUR TWO LIMITED(1 * 50)	50	0	0	0	47	11:44	0	-	0.28	0.27	0.27	11	-0.01
M/S AZURE POWER FORTY ONE PRIVATE LIMITED(1 * 300)	300	0	0	0	288	12:30	0	-	1.66	1.69	1.69	70	0.03
M/S. ONEVOLT ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	86	10:25	0	-	0.51	0.43	0.43	18	-0.08
MEGA SOILS RENEWABLE PRIVATE LIMITED(1 * 250)	250	0	0	0	0	-	0	-	1.48	1.49	1.49	62	0.01
MEGA SURYAURJA PVT LTD(1*250)	250	0	0	0	0	-	0	-	1.51	1.52	1.52	63	0.01
NTPC ANTA SOLAR PV STATION	90	0	0	0	0	-	0	-	0.1	0.11	0.11	5	0.01
NEEMBA RENEW SURYA VIHAAN PRIVATE LIMITED	158	0	0	0	151	10:18	0	-	1.02	0.99	0.99	41	-0.03
NOKHRA SOLAR POWER NTPC	300	0	0	0	0	-	0	-	1.7	1.71	1.71	71	0.01
RENEW SUN BRIGHT PRIVATE LIMITED (RSBPL)(1 * 300)	300	0	0	0	287	11:57	0	-	1.89	1.93	1.93	80	0.04
RENEW SURYA RAVI PVT LTD(1*300)	300	0	0	0	236	10:33	0	-	1.42	1.08	1.08	45	-0.34
RENEW SOLAR ENERGY (JHARKHAND THREE) PVT LTD(300)	300	0	0	0	284	11:54	0	-	1.9	1.94	1.94	81	0.04
RENEW SOLAR POWER PVT LTD(50)	50	0	0	0	217	11:22	0	-	0.32	0.92	0.92	38	0.6
RENEW SOLAR POWER PVT LTD. BIKANER(1 * 250)	250	0	0	0	0	-	0	-	1.56	1.58	1.58	66	0.02
RENEW SOLAR URJA PVT LIMITED(300)	300	0	0	0	285	11:56	0	-	1.98	1.92	1.92	80	-0.06
RENEW SUN WAVES PRIVATE LIMITED(1 * 300)	300	0	0	0	260	12:12	0	-	1.77	1.77	1.77	74	0
RENEW SURYA AAYAN PRIVATE LIMITED	300	0	0	0	0	-	0	-	2.02	2.05	2.05	85	0.03
RENEW SURYA JYOTI PRIVATE LIMITED	185	0	0	0	0	-	0	-	1.09	1.1	1.1	46	0.01
RENEW SURYA PRATAP PRIVATE LIMITED(1*200)	200	0	0	0	202	12:27	0	-	1.44	1.34	1.33	55	-0.11
RENEW SURYA ROSHNI PVT LTD(1*400)	400	0	0	0	0	-	0	-	2.28	2.29	2.29	95	0.01
RENEW SURYA VIHAAN PRIVATE LIMITED	100	0	0	0	98	12:27	0	-	0.64	0.64	0.63	26	-0.01
RISING SUN ENERGY (K) PVT LTD(1*164)	190	0	0	0	190	13:10	0	-	1.17	1.02	1.02	43	-0.15
SB ENERGY FOUR PVT LTD(2 * 100)	200	0	0	0	188	11:59	0	-	1.09	1.08	1.08	45	-0.01
SB ENERGY SIX PRIVATE LIMITED(1 * 300)	300	0	0	0	283	11:25	0	-	1.64	1.8	1.8	75	0.16
SJVN GREEN ENERGY LIMITED	242	0	0	0	313	10:29	0	-	1.71	1.36	1.34	56	-0.37
SERENTICA RENEWABLES INDIA 4 PRIVATE LIMITED_BKN2	168	0	0	0	0	-	0	-	1.03	1.04	1.04	43	0.01
SERENTICA RENEWABLES INDIA 5 PRIVATE LIMITED	176	0	0	0	222	10:47	0	-	1.19	0.96	0.96	40	-0.23
SINGRAULI SOLAR(15)	15	0	0	0	0	-	0	-	0.04	0.04	0.04	2	0
TRANSITION CLEANTECH SERVICES PRIVATE LIMITED	24	0	0	0	82	10:26	0	-	0.17	0.39	0.39	16	0.22
TATA POWER GREEN ENERGY LIMITED	225	0	0	0	189	11:07	0	-	1.1	0.79	0.79	33	-0.31
TATA POWER RENEWABLE ENERGY LTD(1 * 300)	300	0	0	0	286	12:46	0	-	1.82	1.7	1.69	70	-0.13
TATA POWER SAURYA LIMITED	110	0	0	0	77	10:15	0	-	0.49	0.36	0.36	15	-0.13
THAR SURYA IPRIVATE LIMITED(1*300)	300	0	0	0	274	11:32	0	-	1.54	1.22	1.22	51	-0.32
TRANSITION ENERGY SERVICES PRIVATE LIMITED	84	0	0	0	0	-	0	-	0.41	0.43	0.43	18	0.02
TRANSITION GREEN ENERGY PRIVATE LIMITED	100	0	0	0	97	10:24	0	-	0.76	0.46	0.46	19	-0.3
TRANSITION SUSTAINABLE ENERGY SERVICES PVT. LTD.	50	0	0	0	48	10:23	0	-	0.31	0.23	0.23	10	-0.08
TRANSITION SUSTAINABLE ENERGY SERVICES ONE PVT LTD	56	0	0	0	0	-	0	-	0.41	0.43	0.43	18	0.02
UNCHAHAH SOLAR(10)	10	0	0	0	6	11:00	0.087	18:00	0.03	0.03	0.03	1	0
Sub-Total	17,430	0	0	0	-	-	-	-	104.37	98.34	98.2	4,089	-6.17
HYBRID IPP													
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED SOLAR(1*600)	600	0	0	0	624	13:17	0	-	5.3	4.59	4.58	191	-0.72
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED WIND(1*510)	510	0	221	240	392	-	0	-	4.24	3.54	3.54	148	-0.7

ADANI HYBRID ENERGY JAISALMER ONE LIMITED SOLAR(1 * 235.1 + 1 * 124.8)	360	0	0	0	365	12:23	0	-	2.49	2.48	2.48	103	-0.01
ADANI HYBRID ENERGY JAISALMER ONE LIMITED WIND(1 * 101)	101	0	46	51	86	01:15	0	-	0.86	0.89	0.89	37	0.03
ADANI HYBRID ENERGY JAISALMER THREE LIMITED SOLAR(1*300)	300	0	0	0	298	-	0	-	2.4	2.18	2.18	91	-0.22
ADANI HYBRID ENERGY JAISALMER THREE LIMITED WIND(1*75)	75	0	27	44	67	11:45	0	-	0.66	0.67	0.67	28	0.01
ADANI HYBRID ENERGY JAISALMER TWO LIMITED SOLAR(1*299)	300	0	0	0	300	11:30	0	-	2.52	2.37	2.37	99	-0.15
ADANI HYBRID ENERGY JAISALMER TWO LIMITED WIND(1*75)	75	0	25	46	62	12:00	0	-	0.65	0.61	0.61	25	-0.04
ADANI JAISALMER ONE SEPL SOLAR(1*420)	420	0	0	0	379	13:36	0	-	2.77	2.67	2.67	111	-0.1
ADANI JAISALMER ONE SEPL WIND(1*105)	105	0	38	71	81	01:00	0	-	0.93	0.79	0.79	33	-0.14
Sub-Total	2,846	0	357	452	-	-	-	-	22.82	20.79	20.78	866	-2.04
Total	22,182	2,038	941	1,049					171.28	163.84	163.17	6,795	-8.11

Summary Section						
	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Total State Control Area Generation	66,474	31,018	26,586	791.65	746.28	31,097
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		6,459	6,857	419.78	419.78	4,560
Inter National Exchange with Nepal[Import (+ve)/Export (-ve)]		-10	-13	-0.01	-0.01	20
Total Regional Availability(Gross)	117,139	59,918	53,733	1,842.53	1,774.5	61,025

Total Hydro Generation						
	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Hydro	14,722	11,559	10,719	276.59	273.84	11,410
State Control Area Hydro	7,855	4,665	4,188	129.6	129.27	5,387
Total Regional Hydro	22,577	16,224	14,907	406.19	403.11	16,797

Total Renewable Generation						
	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Renewable	20,521	357	452	122.58	122.43	5,099
State Control Area Renewable	13,630	978	1,890	76.95	76.92	3,205
Total Regional Renewable	34,151	1,335	2,342	199.53	199.35	8,304

Total Solar Generation						
	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Solar	19,655	0	0	116.08	115.93	4,828
State Control Area Solar	8,586	67	43	48.39	48.39	2,016
Total Solar	28,241	67	43	164.47	164.32	6,844

Total Wind Generation						
	Inst. Capacity	PEAK	OFF-PEAK	Day Energy		Day AVG.
				Gross Gen	Net Gen	
Regional Entities Wind	866	357	452	6.5	6.5	271
State Control Area Wind	4,328	760	1,708	21.1	21.1	879
Total Wind	5,194	1,117	2,160	27.6	27.6	1,150

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))								
SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		(MW)	MW	Import (MW)	Export (MW)			
Import/Export between EAST REGION and NORTH REGION								
1	132KV Rihand - Nagar Untari	-	-	-	-	-	-	-
2	132KV-Chandauli (UP)-Karmnasa(PG)	-	-	-	-	-	-	-
3	132KV-Rihand (UP)-Garhwa(CG)	15	26	-	27	0	0.55	-0.55
4	132KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	-	-	-
5	220KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	2.15	0	2.15
6	400KV-Allahabad (PG)-Sasaram(PG)	-	-	-	-	0.98	0	0.98
7	400KV-Balia (PG)-Biharsharif(PG)	-	-	-	-	3.25	0	3.25
8	400KV-Balia (PG)-Naubatpur(Bihar)	-	-	-	-	3.57	0	3.57
9	400KV-Balia (PG)-Patna(PG)	-	-	-	-	12.33	0	12.33
10	400KV-Gorakhpur (UP)-Motihari(DMT)	422	236	472	0	7.01	0	7.01
11	400KV-Gorakhpur (UP)-Muzaffarpur(PG)	710	563	789	0	12.34	0	12.34
12	400KV-Sahupuri (UP)-Biharsharif(PG)	-	-	-	-	4.75	0	4.75
13	400KV-Varanasi (PG)-Sasaram(PG)	-72	-49	-99	0	1.31	0	1.31
14	765KV-Balia (PG)-Gaya(PG)	-	-	-	-	12.95	0	12.95
15	765KV-Sasaram (PG)-Fatehpur(PG)	-	-	-	-	5.61	0	5.61
16	765KV-Varanasi (PG)-Gaya(PG)	-490	-596	-662	377	7.3	0	7.3
17	HVDC800KV-Agra (PG)-Alipurduar(PG)	-	-	-	-	8.01	0	8.01

Sub-Total EAST REGION		585	180	500	404	81.56	0.55	81.01
Import/Export between NORTH_EAST REGION and NORTH REGION								
1	HVDC800KV-Agra (PG)-Biswanath Charialli(PG)	-	-	-	-	7.98	0	7.98
Sub-Total NORTH_EAST REGION		0	0	0	0	7.98	0	7.98
Import/Export between WEST REGION and NORTH REGION								
1	132KV-Lalitpur (UP)-Rajghat(MP)	-	-	-	-	-	-	-
2	132KV-Sawai Madhopur (RJ)-Gwalior(MP)	-	-	-	-	-	-	-
3	220KV-Auraiya (NT)-Malanpur(PG)	36	34	-	56	0.5	0	0.5
4	220KV-Auraiya (NT)-Mehgaon(PG)	-	-	-	-	-	-	-
5	220KV-Modak (RJ)-Bhanpura(MP)	107	98	112	-	2.39	0	2.39
6	220KV-Ranpur (RS)-Bhanpura(MP)	69	72	79	-	1.75	0	1.75
7	400KV-Bhinmal (PG)-Zerda(PG)	-	-	-	-	0	0.13	-0.13
8	400KV-Chittorgarh 765 (PG)-Neemuch (WR)	-328	-439	-655	312	5.86	0	5.86
9	400KV-Kankroli (RJ)-Zerda(PG)	-	-	-	-	0.9	0	0.9
10	400KV-RAPS C (NP)-Sujalpur	567	445	664	221	7.01	0	7.01
11	400KV-Rihand (NT)-Vindhyachal(PG)	-	-	-	-	-	-	-
12	765KV-0rai-Gwalior (PG)	-555	-509	0	-941	0	13.09	-13.09
13	765KV-0rai-Jabalpur	2,600	2,400	2,822	0	47.52	0	47.52
14	765KV-0rai-Satna	1,148	1,079	1,219	0	22.91	0	22.91
15	765KV-Agra (PG)-Gwalior(PG)	-	-	-	-	50.25	0	50.25
16	765KV-Chittorgarh-Banaskata D/C	-810	-456	-1,881	835	13.98	0	13.98
17	765KV-Phagi (RJ)-Gwalior(PG)	1,764	1,620	1,835	-5	29.7	0	29.7
18	765KV-Varanasi (PG)-Vindhyachal(PG)	-3,275	-2,219	-3,706	0	61.25	0	61.25
19	HVDC500KV-Mohindergarh (JH)-Mundra(JH)	1,501	1,502	1,503	-	33.25	0	33.25
20	HVDC500KV-Vindhyachal (PG)-Vindhaychal B/B	50	50	0	50	0	1.24	-1.24
21	HVDC800KV-Kurukshetra (PG)(PG)-Champa(PG)	3,000	3,000	3,000	0	67.98	0	67.98
Sub-Total WEST REGION		5,874	6,677	4,992	528	345.25	14.46	330.79
TOTAL IR EXCHANGE		6,459	6,857	5,492	932	434.79	15.01	419.78

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NR-NORTH EAST REGION	89.38	16.78	0	1.63	0	93.5	81.01	-12.49
	0	0	0	0	0	0	7.98	7.98
NR-WR	215.42	127.47	0	-4.69	0	343.89	330.79	-13.1
Total	304.8	144.25	0	-3.06	0	437.39	419.78	-17.61

5.Inter National Exchange with Nepal [Import (+ve)/Export(-ve)] [Linkwise]

Element	Peak	Off-Peak	Maximum Interchange(MW)		Energy (MU)		Net Energy	Schedule Energy
	MW	MW	Import	Export	Import	Export	(MU)	(MU)
132KV-Tanakpur(NH)-Mahendranagar(PG)	-10	-13	41.256	21	0.11	0.12	-0.01	0
132KV-Nautanwa (UP)-Mainhiya (Nepal)					0	0	0	0

5.Frequency Profile

RANGE(Hz)	< 49.2	< 49.7	< 49.8	< 49.9	< 50.0	>= 49.9 - <= 50.05	> 50.05 - <= 50.1	> 50.1 - <= 50.2	> 50.2	> 50.05
%	0	0	1.35	15.75	56.23	66.42	9.98	4.77	3.08	17.82
<-----Frequency (Hz)----->										

Maximum		Minimum		Average Frequency	Freq Variation Index	Standard Deviation	Freq. in 15 mnt blk		Freq Dev Index (% of Time)
Frequency	Time	Frequency	Time				Max.	Min.	
50.33	23:57:20	49.72	12:38:50	49.99	0.079	0.088	50.27	49.8	33.58

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index (% of time)
					< 380	< 390	> 420	> 430	
Abdullapur(PG) - 400KV	413	02:00	397	12:20	0	0	0	0	0
Amritsar(PG) - 400KV	412	03:55	388	14:50	0	7.99	0	0	0
Ballabgarh(PG) - 400KV	416	06:45	388	14:40	0	5.9	0	0	0
Bareilly II(PG) - 400KV	417	06:45	394	22:15	0	0	0	0	0
Bareilly(UP) - 400KV	418	06:45	394	22:15	0	0	0	0	0
Baspa(HP) - 400KV	406	00:00	393	10:35	0	0	0	0	0
Bassi(PG) - 400KV	419	04:00	402	11:55	20.83	20.83	0	0	20.83
Bawana(DTL) - 400KV	416	06:45	397	12:20	0	0	0	0	0

Dadri HVDC(PG). - 400KV	415	06:45	391	14:40	0	0	0	0	0
Gorakhpur(PG) - 400KV	420	07:40	389	21:50	0	3.13	0	0	0
Hisar(PG) - 400KV	418	03:55	393	12:20	0	0	0	0	0
Kanpur(PG) - 400KV	416	08:00	393	22:15	0	0	0	0	0
Kashipur(UT) - 400KV	417	06:30	405	22:15	0	0	0	0	0
Kishenpur(PG) - 400KV	418	05:00	404	12:20	0	0	0	0	0
Moga(PG) - 400KV	414	03:50	391	14:45	0	0	0	0	0
Nallagarh(PG) - 400KV	406	00:00	393	10:35	0	0	0	0	0
Rihand HVDC(PG) - 400KV	397	15:05	390	21:20	0	0	0	0	0
Rihand(NT) - 400KV	399	10:50	391	21:20	0	0	0	0	0

6.1 Voltage Profile: 765kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 728	< 742	> 800	> 820	
Anta RS(RJ) - 765KV	794	15:15	770	22:15	0	0	0	0	0
Balia(PG) - 765KV	789	07:45	745	22:15	0	0	0	0	0
Bareilly II(PG) - 765KV	795	06:45	749	22:15	0	0	0	0	0
Bhiwani(PG) - 765KV	790	06:30	762	12:15	0	0	0	0	0
Fatehpur(PG) - 765KV	788	08:00	747	22:15	0	0	0	0	0
Jhatikara(PG) - 765KV	788	06:45	757	12:20	0	0	0	0	0
Lucknow II(PG) - 765KV	795	08:00	747	22:15	0	0	0	0	0
Meerut(PG) - 765KV	800	06:50	757	12:20	0	0	0	0	0
Moga(PG) - 765KV	796	06:45	762	11:55	0	0	0	0	0
Phagi(RJ) - 765KV	797	04:00	767	22:15	0	0	0	0	0
Unnao(UP) - 765KV	784	08:00	745	22:15	0	0	0	0	0

7(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00)							Peak Hours (20:00)						
	T-GNA Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXI RTM (MW)	Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXI RTM (MW)
PUNJAB	1,745.14	7.44	0	96.64	0	0	0	2,131.7	7.92	0	987.37	0	0	0
HARYANA	2,176.11	1.93	195.15	0	0	0	0	2,519.31	7.44	-540	-100	0	0	0
RAJASTHAN	648.02	-58.1	-22.1	-237.06	0	0	0	918.08	-23.2	-132.5	-250	0	0	0
DELHI	1,804.79	0	-131	-45.23	0	0	0	2,082.44	0	-618	-35.93	0	0	0
UTTAR PRADESH	1,808.29	3.19	348.82	615.31	0	0	0	2,732.66	22.61	-240.51	1,346.68	0	0	0
UTTARAKHA ..	0	-8.7	-89	316.01	0	0	0	0	-4.59	38.85	-51.68	0	0	0
HIMACHAL PRADESH	-328	-37.9	-113.56	-697.28	0	0	0	-579	-39.3	-86.63	-182.3	0	0	0
J&K(UT) & LADAKH(UT)	-662.5	0	-14.4	-524.5	0	0	0	-672.04	-7.2	275.52	72.48	0	0	0
CHANDIGARH	42.5	0	-83	-20	0	0	0	106.29	0	-115	0	0	0	0
RAILWAYS_NR ISTS	36.2	0	21.26	0	0	0	0	36.2	21.26	0	0	0	0	0
TOTAL	7,270.55	-92.14	112.17	-496.11	0	0	0	9,275.64	-15.06	-1,418.27	1,786.62	0	0	0

State	Day Energy (MU)					
	GNA schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total (MU)
PUNJAB	114.18	48.52	0.07	0.03	45.56	208.36
HARYANA	145.43	59.56	0.8	1.85	0.29	207.93
RAJASTHAN	128.13	11.11	-0.94	-1.14	-5.19	131.97
DELHI	93.59	41.58	0.08	-4.02	1.45	132.68
UTTAR PRADESH	223.17	25.24	0.56	-0.53	11.1	259.54
UTTARAKHAND	29.51	0.26	-0.08	0.95	2.67	33.31
HIMACHAL PRADESH	20.26	-9.05	-0.36	-2.48	-8.98	-0.61
J&K(UT) & LADAKH(UT)	44.74	-8.75	-0.21	0.65	-7.08	29.35
CHANDIGARH	7.73	1.03	0	-1.32	0.23	7.67
RAILWAYS_NR ISTS	2.69	0.87	0.17	0.18	0	3.91
TOTAL	809.43	170.37	0.09	-5.83	40.05	1,014.11

7(B). Short-Term Open Access Details

State	GNA schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXIL GDAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	5,186.62	4,273.75	2,259.91	1,678.21	10.63	0	0	0
HARYANA	6,810.33	4,877.53	2,803.36	2,137.36	84.66	0.06	0	0
RAJASTHAN	5,895.87	4,800.12	918.08	17.39	-20.2	-64.2	0	0
DELHI	4,465.41	3,162.32	2,111.8	1,180.7	143.99	0	0	0
UTTAR PRADESH	10,968.68	7,350.47	2,737.53	72.9	73.89	1.64	0	0
UTTARAKHAND	1,427.23	1,043.06	36.73	0	1.92	-12.7	0	0
HIMACHAL PRADESH	878.64	815.27	-297.59	-579	10.79	-39.3	0	0
J&K(UT) & Ladakh(UT)	1,914.35	1,774.11	-122.5	-784.5	0	-54.9	0	0
CHANDIGARH	355.12	279.73	106.29	0	0	0	0	0
RAILWAYS_NR ISTS	125.14	99.6	36.2	36.2	21.26	0	0	0

State	IEX DAM (MW)		PXI DAM(MW)		IEX RTM (MW)		PXI RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	51.8	0	0	0	3,534.41	0	0	0
HARYANA	797.28	-865	0	0	821.44	-400	0	0
RAJASTHAN	-8.73	-528.04	0	0	0	-1,400	0	0
DELHI	139.16	-625	0	0	796.71	-301.3	0	0
UTTAR PRADESH	386.46	-2,158.84	0	0	2,774.15	-1,113.32	0	0
UTTARAKHAND	257.06	-103	0	0	399.32	-421.68	0	0
HIMACHAL PRADESH	-42.27	-373.43	0	0	-182.3	-709.67	0	0
J&K(UT) & LADAKH(UT)	275.52	-16.3	0	0	220.24	-1,004.4	0	0
CHANDIGARH	0	-115	0	0	103.4	-33	0	0
RAILWAYS_NR ISTS	21.26	0	0	0	0	0	0	0

8.Major Reservoir Particulars

RESERVOIR	Parameters			Present Parameters		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (m3/s)	Usage (m3/s)
Bhakra	445.62	513.59	1,728.8	476.49	381	483.14	536	1,414.28	936.47
Chamera-I	748.75	760	753.95	754.3	11	-	-	320.49	264.61
Gandhisagar	381	399.9	725	-	-	-	-	-	0
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-	-	0
Koteshwar	598.5	612.5	610.73	609.4	4	595.8	0	201	199.08
Pong	384.05	426.72	1,084	393.25	97	398.66	191	316.47	224.89
RPS	343.81	352.81	175.66	-	-	-	-	-	0
RSD	487.91	527.91	390.3	505.3	161	503.74	149	273.28	256.02
Rihand	252.98	268.22	860.5	-	-	-	-	-	0
Tehri	740.04	830	1,164.11	749.78	55	743.7	21	323.2	201
TOTAL	-	-	-	-	709	-	897	2,848.72	2,082.07

9. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter and intra regional corridors

WR	0
ER	0
Simultaneous	8.33
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	4.17

ii)%age of times ATC violated on the inter and intra regional corridors

WR	5.21
ER	0
Simultaneous	10.76
Delhi	0
Rajasthan	0
UP	0
Punjab	2.78
Haryana	10.76

iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand-Dadri	0
--------------	---

10. Zero Crossing Violations

State	No. of violations(Maximum 15 in a day)	Maximum number of continuous blocks without sign change
CHANDIGARH	0	5
DELHI	8	28
HARYANA	8	22
HIMACHAL PRADESH	1	7
J&K(UT) & Ladakh(UT)	8	16

PUNJAB	6	28
RAJASTHAN	8	19
UTTAR PRADESH	2	7
UTTARAKHAND	7	22

11. NCR's and Ladakh Power Supply Position(based on SCADA data)

	Inst Capacity	20:00	03:00	Day Peak			
Station/Constituents	(MW)	Peak MW	Off Peak MW	MW	HRS	Net MU	AVG MW
NCR_GENERATION	9225	4,409	3,204	4775	21:30:00	85.97	3,582
NCR_DRAWAL	-	14,710	14,353	17688	14:45:00	362.13	15,089
NCR_DEMAND	-	19,119	17,557	21480	14:30:00	448.1	18,671
LADAKH_DEMAND	-	10	-8	11	20:15:00	-0.01	0

12. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
CHANDIGARH	0	0	0	0	0	0	0	
DELHI	0	0	0	0	0	0	0	
HARYANA	0	0	0	0	0	0	0	
HIMACHAL PRADESH	0	0	0	0	0	0	0	
J&K(UT) & Ladakh(UT)	0	0	0	0	0	0	0	
PUNJAB	0	0	0	0	0	0	0	
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	
RAJASTHAN	0	0	0	0	0	0	0	
UTTAR PRADESH	0	0	0	0	0	0	0	
UTTARAKHAND	0	0	0	0	0	0	0	

13.Grid Disturbance / Any Other Significant Event:

14.Weather Conditions :

15.Synchronisation of new generating units :

16.Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

17.Instances of persistent/significant non-complaint with the grid code

18.Complete generation loss in a generating station :

19.Remarks :

No Records Found

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.
*Unscheduled Load Shedding carried out by Uttar Pradesh.

Shift In Charge