ARYADI BUSINESS PVT.LTD.

PPM SERVICE REPORT

UPS PREVENTIVE MAINTENANCE

ISO 9001:2015 | ISO 14001:2015 | ISO 45001:2018 Certified

REPORT NUMBER	TICKET NO	REGISTERED ON	CLOSED ON
ARYADI-PPM-16549	**CS-PPM-032397**	**2026-01-02 05:21:57**	**2026-03-16 12:25:03**

Customer Details

Customer Name	COLLIERS - MARUTI SUZUKI INDIA LTD
Branch Name	MSIL - Jaipur
Address	Maruti Suzuki India Ltd A 403, Bajiya Security, Nursery circle, Vaishali nagar, Jaipur Jaipur Rajasthan 302005 India
Mobile No.	9587662915
Client Ticket No.	N.A.

Service Ticket Details

Type	PPM
Category	UPS
Sub Category	Offline UPS
Status	Closed
Asset Condition	GOOD
Complaint Registered	2026-01-02 05:21:57

Asset Details

Equipment Name	UPS	**Make**	Eaton
Model	15KVA,415v,50hz	**Serial Number**	N.A.
Asset Location	SERVER ROOM RO, First Floor		

Service Details

PROBLEM STATEMENT

Quarterly PPM service required

TECHNICIAN / ENGINEER OBSERVATION

Quarterly PPM service required Q 1

ACTION TAKEN

we have checked the UPS found working ok main and battery mode UPS working is ok UPS fan alarm showing but fan is working normal condition

TECHNICIAN / ENGINEER REMARKS

work done

Pre Image(s)

0 PHOTO(S)

No pre-work images captured.

Post Image(s)

0 PHOTO(S)

No post-work images captured.

Checklist

Check Loose Connection	:	OK	IR Value	:	
Check Cleaning	:	OK	Earthing Voltage	:	
Check Charging Status	:	OK	Output Voltage	:	
Check Bypass Switch	:	OK	Charging Voltage	:	
Check Wire Color Change	:	OK	Current Load	:	
Check Battery Terminals	:	OK			
Check Battery Voltage	:	OK			
Check IR Value	:	OK			
Check Earthing Voltage	:	OK			
Check Output Voltage	:	OK			
Check Charging Voltage	:	OK			
Check Current Load	:	OK			

Acknowledgement

Technician Details		Onsite Client Representative (Verified By)	
Name	—	Name	Mr. Kundan
Phone Number	—	Designation	manager
		Contact Number	9587662915

Authorised Signatory

2026-03-16 12:25:01