
A1 BORDER



A O O B


TxA DATA

REMOTE AMPLIFICATION CABINE ALARM BEACON LOOPS TERMINAL

WIRENR /COLORCODE

CONNECTED TO

WIRENR /COLORCODE



FIBERS INDICATED "DATA" ARE USED FOR DATA (RS485) DISTRIBUTION IN CABINETS

FIBERS INDICATED "DATAx" ARE USED FOR DATA (RS485) DISTRIBUTION IN CABINETS

FIBERS INDICATED "AUDIO" ARE USED FOR AUDIO DISTRIBUTION IN CABINETS

FIBERS INDICATED "AUDIO×" ARE USED FOR AUDIO DISTRIBUTION IN CABINETS

NOTES ПРИМЕЧАНИЯ

EXISTING CABLES OF RETURN LOOP WILL BE REMOVED AND REPLACED WITH NEW ON. СУЩЕСТВУЮЩИЕ КАВЕЛИ ОБРАТНОЙ ПЕТЛИ ДОЛЖНЫ ВЫТЬ ДЕМОНТИРОВАНЫ И БУДУТ ЗАМЕНЕНЫ НА НОВЫЙ КАВЕЛЬ.

2. 5 CORE CABLE WAS USED FOR BEACONS LOOP: 4 CORES WERE TERMINATED ONLY 1-ST CORE IS PHASE FOR RED BEACON, 2-ND CORE IS PHASE YELLOW BEACON, 3-RD CORE IS NEUTRAL, 4-TH CORE IS EARTHLING. 5 жильный кавель использовался для цепей провлесковых маячков; только 4 жилы были расключены: 1-ая жила - фаза для

КРАСНОГО ПРОВЛЕСКОВОГО МАЯЧКА, 2-АЯ ЖИЛА — ФАЗА ДЛЯ ЖЕЛТОГО ПРОВЛЕСКОВОГО МАЯЧКА, 3-ЬЯ ЖИЛА — НЕЙТРАЛЬ, 4-АЯ ЖИЛА

LEGEND УСЛОВНЫЕ ОБОЗНАЧЕНИЯ

DENOTED EXTEND OF DESTRUCT

REFERENCE DRAWINGS ССЫЛОЧНЫЕ ЧЕРТЕЖИ

0-000-J-5084

кавельный журнал кип

X-000-J-5222-04917D

INSTRUMENT CABLE BLOCK DIAGRAM

INSTRUMENT CABLE SCHEDULE

X-000-J-6286-04917D

JR /PANEL WIRING DIAGRAM

.PROJĘCT DRAWING CREATED BASED ON REVISION OF THE MASTER DRAWING TIPOEKTHЫЙ MEPTEЖ COЗДАН НА ОСНОВЕ РЕВИЗИИ KOHTPO/IBHOPO MEPTEKA

FOR PROJECT: X-000-049-17									
Α	26/12/17	ISSUED FOR COMMENT	AY	RKN	GN				
			BD						
REV	DATE	REVISION	BY	CH'K	EN				
			SUPV	MGR	OPE				



ТЕҢІЗШЕВРОЙА

TENGIZCHEVROIL

KTL PAGA UPGRADE INTERCONNECTION DIAGRAM LCR-3 IC-400-J-1342

МОДЕРНИЗАЦИЯ СИСТЕМЫ ОПОВЕЩЕНИЯ КТЛ СХЕМА МЕЖСОЕДИНЕНИЙ MO-3 IC-400-J-1342

DRAWN BY AY	RKN	X-000-049-17		
ENGINEER GN	SUPERVISOR BD	DRAWING No. 2-400-J-5035-04917D	REV A	
OPERATIONS	PROJ MGR	7 Z-100-0-3033-013170 F		
		SCALE: _ DATE: 18/12/1	7	

