



SERVICE REPORT

Tel.: +971 6 741 2778
Fax: +971 6 741 2595
P.O. Box: 7777, Ajman, UAE
e-mail: info@amaanajh.com
Website: www.amaanajh.com

SRN: **FS-TEST-0001**

Customer Test Site - Ajman Tower		Job No FS-TEST-0001	Page 1 of 1	
		Site Name Test Site - Ajman Tower	Location	
Engineer / Technician Arshith Technician		Date 12 Mar 2026		
Fire Alarm System				
Qty	Type		Time Arrive	Hrs Mns
			Time Left	Hrs Mns
			Travel Time	Hrs Mns
Make	No. of Zones / Loops		Total	Hrs 00 Mns 00

Fire Fighting System		Type of Job Fire Systems Inspection	
Fire Extinguisher	☐ Gas Suppression	☐ PPM	☐
Hose Reel	☐ Kitchen Hood	☐ Inspection	☒
Sprinkler	☐ Wet / Dry Riser	☐ Rectification	☐
Fire Pump Set	☐ Others	☐ Others	☐

Comments:

HVAC / Chiller Unit A: Main chiller for building cooling — In good condition

HVAC / AHU-01: Air handling unit Floor 1 — Filter replacement recommended

Supervisor: Inspection completed. Minor maintenance required.

Parts Used	Specification	Qty	Parts Required	Specification	Qty
			Smoke detector head	Apollo / pcs	2

Customer Remarks:

Customer Name : Test Site - Ajman Tower	Engineer/Technician Name: Arshith Technician
Mobile No:	ID No:

Fire Systems Inspection — Attachments & Approvals

Site: Test Site - Ajman Tower

Inspection Photos

3 photo(s)

Chiller Unit A

Chiller Unit A

AHU-01

Approval Signatures

Supervisor	
Comments	Inspection completed. Minor maintenance required.
Signature	

Operations Manager	
Comments	—
Signature	Not signed

Business Development	
Comments	—
Signature	Not signed

Procurement	
Comments	—
Signature	Not signed

General Manager	
Comments	—
Signature	Not signed