

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

RC.NO. 23/2026

DATED: 20-06-2025

It is certified that an inspection team headed by Dy. Dist. Medical & Health Officer of the Devarkonda, Nalgonda District, inspected the Discipline Resolute High School, Dindi Road, Kacharam Agraharam, Deverkonda, Nalgonda, Telangana on 20/06/2025 and based on the water test Report (Attached) bearing No: 7411, **Government of Telangana, Department of Water and Taste Examination, Directorate of I.P.M, P.H.Labs, Food,(H) Administration, Narayanaguda, Hyderabad - 29 dated 16-06-2026**, certified that the Discipline Resolute High School has safe drinking water facilities for the students and members of staff of the institution. The school is also maintaining hygienic sanitation conditions in the school building and the campus as per the norms prescribed by the Central, State, and U.T. Governments.

This certificate is valid till **20/06/2026**

District Medical & Health Officer,

Nalgonda District

Dy. Dist. Medical & Health Officer,
Devarkonda.

To
The Principal,
Discipline Resolute High School,
Dindi Road, Kacharam Agraharam,
Deverkonda, Nalgonda, Telangana

HEAD MASTER
Discipline Resolute High School

Discipline Resolute High School

Manager

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M, P.H. Labs, Food (H) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: Discipline Resolute High School, Dindi Rd, Deverkonda,
Kacharam Agraharam, TS :

2. Collected by: (Samples collected by Party)

3. Collected on : 16-06-2025

4. Received on: 16-06-2025

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml
7409	R.O water	Direct from R.O plant water		Nil		
7410	R.O water(TPC)	Direct from R.O plant water	Total Aerobic Bacterial Plate Count for 24 hrs at 37°C = 1 CFU / ml			

Remarks: The above samples are bacteriologically satisfactory .

[Signature] 23/6/25
Dy. Chief Water Analyst
Institute of Preventive Medicine
Public Health Labs & Food (H) Admin
Narayanaguda, Hyderabad-28, T.S

HEAD MASTER
Discipline Resolute High School
[Signature]

Discipline Resolute High School
[Signature]
Manager

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
 Directorate of I.P.M.P.H.Labs, Food (II) Administration, Narayanaguda, Hyderabad - 29.

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

REPORT OF PHYSICO-CHEMICAL ANALYSIS OF WATER				
Sample From	Discipline Resolute High School,	Collected by		
Address	Dindi Rd, Deverkonda, Kacharam Agrapharam, TS .	Collected on	(Samples collected by Party)	
District	Deverkonda,	Received on	16-06-2025	
State	TS	Sample volume	2 ltr	
Source profile	R.O Plant Water	Sample ID	7411	
S.No	Parameter	Source / Sample ID	Drinking Water -Specification As per IS 10500 :2012	
		Direct R.O plant water collected at above address / 7411	Requirement (Acceptable)	Permissible limit in the absence of alternative source
Physical parameters				
1	colour(Hazen),max	<5	5	15
2	Turbidity (NTU),max	1.10	1	5
3	Odour	UnObjectionable	UnObjectionable	UnObjectionable
4	Taste	Agreeable	Agreeable	Agreeable
5	p ^m	7.3	6.5 - 8.5	No relaxation
6	Electrical Conductivity at 25°C (Micro Mhos/cm)	72		
7	TDS(mg/L),max	47	500	2000
Chemical parameters (mg/L)				
1	Alkalinity(as CaCO3) ,phenolphthalein ,max	Nil	...	...
2	Total alkalinity (as CaCO3) ,max	16	200	600
3	Total hardness (as CaCO3),max	10	200	600
4	Calcium hardness (as CaCO3),max	3		
5	Magnesium hardness (as CaCO3),max	7		
6	Calcium (as Ca),max	1.2	75	200
7	Magnesium (as Mg),max	1.7	30	100
8	Ammonical Nitrogen,max	Nil		
9	Nitrite(as N),max	Nil		
10	Nitrate(as N),max	0.1	45	No relaxation
11	Sulphate (as SO4),max	Nil	200	400
12	Chloride(as Cl),max	11	250	1000
13	Fluoride(as F),max	0.03	1.0	1.5
14	Iron (as Fe),max	Nil	0.3	No relaxation

Remarks: The given sample is physico chemically satisfactory .

HEAD MASTER
 Discipline Resolute High School

Discipline Resolute High School
 Narayanaguda, Hyderabad-29, T.S.
Manager