

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 28/04/26

It is certified that an inspection team headed by

Anchal Vats

(Name of Officers with designation)

from NIR LAB.

PHED

inspected the J.P. Academy, Mawana Road, Meerut.

(Name & Address of the school) on 27/04/26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. TC917526000000156F

dated 27/04/26 of NIR LAB. (PHED Lab)

certified that the

J.P. Academy

(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27/04/27

Signature with Seal:

Name

ANCHAL VATS

Designation

Quality Manager

Name & Address of the Office / Department:

To

Principal

J.P. Academy, Meerut.
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



NIR LABORATORY PRIVATE LIMITED

(Formerly Known as Neon Industrial Testing & Research Laboratory)

NABL Accreditation Certificate TC-(9175), MOEF&CC Recognized Govt. approved Lab,

An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified

Laboratory : 205 A-B, Rajpura, Mawana Road Near Subhash Inter College Meerut, www.nirlaboratory.in

Mobile : 8218221131, 8449335841, E-mail : nirlaboratory@gmail.com, neonitrl@gmail.com

TEST REPORT

SAMPLE CODE:		RO/NIR/20260427-01		PAGE		01 of 01	
ULR: / NO.		TC917526000000156F		SERVICE REQUEST DATE		27.04.2026	
REPORT ISSUE DATE		01.05.2026		SAMPLE RECD. ON		27.04.2026	
NAME & ADDRESS OF CUSTOMER				SAMPLE DETAILS			
M/s- JP Academy, Mawana Road, Meerut				Description :One RO water sample received us by client : 27.04.2026			
				Sample Marking : RO water			
				Sample Procedure : IS:3025 & APHA 24 th Ed.			
				Sample Quantity & Packing: 1.5Ltr.& Plastic Bottle			
				Analysis Done on 27.04.2026 to 01.05.2026			
TEST RESULT				Standards IS:10500-2012			
WATER QUALITY ANALYSIS				limit			
S.No.	Parameter	Result	Unit	Desirable. Limit	Permissible. Limit	Test method	
1.	Turbidity	<1.0	NTU	1.0max	5.0max	IS:3025(P-10)	
2.	pH	6.54	---	6.5-8.5	No Relaxation	IS:3025(P-11)	
3.	Total Dissolved Solids	84.2	Mg/l	500	2000	IS:3025(P-16)	
4.	Total Hardness (as CaCO ₃)	48.0	Mg/l	200	600	IS:3025(P-21)	
5.	Calcium (as Ca)	14.4	Mg/l	75	200	IS:3025(P-40)	
6.	Chloride (as Cl)	7.94	Mg/l	250	1000	IS:3025(P-32)	
7.	Sulphate (as SO ₄)	4.60	Mg/l	200	400	IS:3025(P-24)	
8.	Total Alkalinity (asCaCO ₃)	64.6	Mg/l	200	600	IS:3025(P-23)	
9.	Fluoride (as F)	<0.1	Mg/l	1.0	1.5	IS: 3025(P-60)	
10.	Electrical Conductivity	170.0	µs/cm	Not Specified	Not Specified	IS: 3025(P-14)	
11.	Iron (as Fe)	<0.1	Mg/l	0.3	No Relaxation	APHA 24 th Edition-3500	
12	Magnesium (as Mg)	2.8	Mg/l	30.0	100	IS: 3025(P-46)	
13.	Nitrate (as NO ₃)	0.60	Mg/l	45.0	No Relaxation	IS: 3025(P-34)	
14.	Phosphate (as Po ₄)	0.10	Mg/l	Not Specified	Not Specified	IS: 3025(P-31)	
Microbiological / Bacteriological Tests:-							
15	E-Coli	Absent	Per/100 ml	Shall Not Be Detectable in any 100 ml sample		IS:15185: 2016	
16	Total Coliform	Absent	Per/100 ml	Shall Not Be Detectable in any 100 ml sample		IS:15185: 2016	

Checked By

End of report

Aakansha Gupta

Auth. Sign. Biological

Signature

Anchal Vats

(Q.M)

Auth. Sign. Chemical

Signature

Note:- 1. The Sample will be stored up to 21 days (in case of non perishable items only) from the date of issue of the test report. 2. The results given above are related to the tested sample and mentioned parameters. Endorsement of Product if neither inferred nor implied. 3. Total liability of our works is limited to Invoiced Amount. 4. This report can not used as evidence in a court of law without the written approval of the lab. 5. Certificate shall not be reproduced except in full, without the written approval of the laboratory. 6. Any sort of play by the customer with the date of this certificate shall be illegal.