

Annexure-A

Response to Pre Bid Queries against the tender no. Tr-413 for Refresh of Fire Detection & Suppression System and Integrated Building Management System (IBMS) installed at Data Center, Raipur & DR Center, Bilaspur

S/N	RFP Page Reference	RFP Clause Reference	Specification as per RFP	Query/Changes/Modification Required in RFP	Response to the Query
1	15	Clause 5: Earnest Money Deposit	5.1 Bidder should submit an Earnest Money Deposit (EMD) of Rs. 5,00,000.00 (Rs. Five Lakh only) online through payment gateway via e-bidding portal and money receipt paid through online	We request you to please allow submission of EMD using bank guarantee & share us bank guarantee format for validation from bank.	As per Tender
2	30	Clause 37: Security Deposit cum Performance Guarantee	37.1 On acceptance of Purchase Order, the Contractor will have to deposit an amount of 10% of the total value of the order towards Security Deposit cum Performance Guarantee, either in the form of CTS Demand Draft or Bank Guarantee within 30 days from Date of issue of Order. The security deposit shall be kept till the successful completion of the contract.	We request you to please allow us bank guarantee format for validation from bank.	Bank Guarantee format is attached in corrigendum as Annexure-B
3	32	Clause 40.1: Payment Terms	Supply Part – Delivery of Equipment’s / Materials / Software: Subsequent to the completion of delivery & acceptance of materials, the contractor shall submit the bills and (a) 80% payment towards the value of equipment / material supplied & the same duly verified by the officials from the O/o ED/CE (EITC) at accepted rates as per Bill of Quantity shall be paid normally within a period of one month from the date of presentation of Bills along with the relevant documents. No claim of interest will be entertained in case of delay in payment. (b) 20% payment against the supply of materials shall be released only after installation, integration, testing and commissioning of the same and after declaration of its Go-Live by CSPDCL.	We request you to please allow below payment terms for better cash flow - a. 10% advance against submission of mutually agreed ABG b. 80% payment to be released on pro-rata supply of materials & the same duly verified by the officials from the O/o ED/CE (EITC) at accepted rates as per Bill of Quantity shall be paid normally within a period of one month from the date of presentation of Bills along with the relevant documents.	As per Tender
4	33	Clause 40.2: Payment Terms	40.2 Services Part - Installation, configuration, Testing & Commissioning, migration/implementation, (a) Submission and Approval of AS-IS & TOBE/ Solution Documents: Payment of 20% of the services cost shall be made after submission and approval of AS-IS & TO-BE documents. (Solution document for the Installation, Commissioning, Configuration, Integration and Testing of the equipment’s & software under the scope) including design documents and necessary drawings. The payment for AS-IS & TO-BE shall be released only after the supply of hardware & software to the designated CSPDCL sites as per work order. (b) Completion of Deployment /Implementation works: Payment of 70% of the services cost shall be done on the completion of the installation & integration works of all the equipment’s and software as per scope of work and after the declaration of its Go-Live by CSPDCL. (c) Post Go-live Support: Payment of 10% of the services cost shall be done on the completion of successful operation of the system for 3 months after Go-Live i.e. after the completion of post Go-live support period of 3 months from the date of Go-live or Project Sign-off.	We request you to please allow below payment terms for 2nd milestone as below - Completion of Deployment /Implementation works: Payment of 70% of the services cost shall be done on the pro-rata installation of equipment’s and software as per scope of work & duly verified by the officials from the O/o ED/CE (EITC) within 30 days from the date of submission of verified copy.	As per Tender
5	35	Subcontracting	CSPDCL discourage the practice of sub-contracting to ensure the quality of services as per scope of work order. Therefore, Sub-contracting is not allowed for execution of the project implementation works including the supply of materials required for the project implementation. It should be performed by the Bidder or OEM only. Petty contracting for the implementation works/services shall not be allowed through labor contract or through any third party agency. However, sub-contracting may be allowed only for the deployment of Man-Power required for providing FMS support of 4 years	Design, Engineering, supply & commissioning shall be from bidder/OEM directly, however requesting you to please allow OEM recommended vendor for installation work (like cable laying, devices fixing etc) under OEM supervision	As per Tender

6	30	Clause 38.1 (Price)	The prices quoted by the Bidder shall be in Indian Rupees. The prices should be FIRM and not subject to any price escalation.	Please allow changes black highlighted in bold: The prices quoted by the Bidder shall be in Indian Rupees. The prices should be FIRM and not subject to any price escalation for a period of 6 months from the date of Letter of Award/Purchase Order. Unless otherwise agreed between the parties, should (i) the Delivery Date or Installation Date be beyond six months from the agreed date and (ii) the cost to the Bidder supplying the Goods and/or Services be increased by any circumstances of any kind whatsoever beyond the control of the Bidder, including without limitation, to increased production cost of manufacturers or suppliers/subcontractor, variations in rates of exchange, devaluation of any relevant currency or increase in relevant rates of freight or insurance, the Bidder shall notify CSPDCL of such increase and CSPDCL shall bear such increase, in addition to the Contract Sum.	As per Tender
7	44	Clause 61 (Indemnity)	The Contractor shall also indemnify CSPDCL and keep indemnified for against any loss or damage that CSPDCL may sustain on account of violation of patent, trademarks etc. by the Contractor in respect of replaced/upgraded hardware and software. The total liability of the Contractor under the contract shall not exceed the total cost of the project.	Request you to please delete the red highlited and allow the black highlighted in bold: The Contractor shall also indemnify CSPDCL and keep indemnified for against any loss or damage that CSPDCL may sustain on account of violation of third party patent, trademarks etc. by the Contractor in respect of replaced/upgraded hardware and software. The total liability of the Contractor under the contract shall not exceed the total cost of the project.	As per Tender.
8	44	Add Clause (Limitation of Liability)		Request you to please add the standard Limitation of Liability clause as below : Notwithstanding anything contained in this contract, Bidder's aggregate liability (including liquidated damages, if any) hereunder for any loss, damage and expenses arising out of or in connection with its performance of this Contract shall be limited to the contract price paid by CSPDCL to the Bidder for the work under this Letter of Award/Purchase Order. Neither party shall be liable to the other for any indirect, incidental, consequential, special, punitive, or exemplary damages, including but not limited to loss of profits, loss of business opportunities, or loss of data, even if such damages were foreseeable or the party was advised of the possibility of such damages, whatsoever.	As per Tender.
9	38	Clause 45.7 (Warranty)	The said material if required to be replaced, shall be collected by the Contractor from Area stores / work site at his own cost and responsibility. These materials will like-wise be returned duly repaired / replaced and tested subsequently by the Contractor to the destination indicated on "Freight paid basis" at their cost in a reasonable time. The warranty period as stipulated in above shall also be applicable for repaired / replaced material, which shall however be counted afresh from the date of its delivery in CSPDCL Stores / at site.	Request you to please delete the red highlited and allow the black highlighted in bold: a. In case the delivery of materials is delayed beyond the scheduled time of the order, 'Liquidated Damage for Late Delivery' will be imposed. The rate of half percent (½ %) of the delayed goods / pending products for each calendar week of delay or part thereof subject to a maximum 5(10)% of the cost of the item will be imposed and will be deducted from the bill amount b. If installation/service of any component/part is not made within scheduled completion time of the order, 'Liquidated Damage for Late Services' will be imposed in addition to late delivery charges. The rate of half percent (½ %) of the service cost of the item delayed for installation for each calendar week of delay or part thereof subject to a maximum of 5(10)% of the service cost of item pending for the installation /implementation will be imposed and will be deducted from the bill amount.	As per Tender

10	39	Clause 46.3(a) & (b) -	a) In case the delivery of materials is delayed beyond the scheduled time of the order, 'Liquidated Damage for Late Delivery' will be imposed. The rate of half percent (½ %) of the delayed goods / pending products for each calendar week of delay or part thereof subject to a maximum 10% of the cost of the item will be imposed and will be deducted from the bill amount. b) If installation/service of any component/part is not made within scheduled completion time of the order, 'Liquidated Damage for Late Services' will be imposed in addition to late delivery charges. The rate of half percent (½ %) of the service cost of the item delayed for installation for each calendar week of delay or part thereof subject to a maximum of 10% of the service cost of item pending for the installation /implementation will be imposed and will be deducted from the bill amount.	Request you to please delete the red highlighted and allow the black highlighted in bold: a. In case the delivery of materials is delayed beyond the scheduled time of the order, 'Liquidated Damage for Late Delivery' will be imposed. The rate of half percent (½ %) of the delayed goods / pending products for each calendar week of delay or part thereof subject to a maximum 5(10)% of the cost of the item will be imposed and will be deducted from the bill amount b. If installation/service of any component/part is not made within scheduled completion time of the order, 'Liquidated Damage for Late Services' will be imposed in addition to late delivery charges. The rate of half percent (½ %) of the service cost of the item delayed for installation for each calendar week of delay or part thereof subject to a maximum of 5(10)% of the service cost of item pending for the installation /implementation will be imposed and will be deducted from the bill amount.	As per Tender
11	41	Clause 53 (Defect Liability)	In case, any of the supplies and equipment delivered under the contract are found to be defective as to material and workmanship and / or not in accordance with the requirement, and / or do not achieve the guaranteed performance as specified herein, the contractor shall forthwith replace / make good such defective supplies at no extra cost to CSPDCL without prejudice to the other remedies as may be available to CSPDCL under the contract.	Please allow changes black highlighted in bold: In case, any of the supplies and equipment delivered under the contract are found to be defective as to material and workmanship and / or not in accordance with the requirement, and / or do not achieve the guaranteed performance as specified herein during the agreed warranty period, the contractor shall forthwith replace / make good such defective supplies at no extra cost to CSPDCL without prejudice to the other remedies as may be available to CSPDCL under the contract.	As per Tender
12	44	Clause 62 (Compensation / Proceedings on Cancellation)	62.1 After the award of the contract, if the Contractor does not perform satisfactorily or delays execution of the contract, CSPDCL reserves the right to get the balance contract executed by another party of its choice by giving one month's notice for the same. In this event, the Contractor is bound to make good the additional expenditure, which CSPDCL may have to incur in executing the balance of the contract. This clause is applicable, if for any reason, the contract is cancelled.	Please allow changes black highlighted in bold: After the award of the contract, if the Contractor does not perform satisfactorily or delays execution of the contract, CSPDCL reserves the right to get the balance contract executed by another party of its choice by giving one month's notice for the same. In this event, the Contractor is bound to make good the additional expenditure, which CSPDCL may have to incur in executing the balance of the contract. This clause is applicable, if for any reason of Contractor's default, the contract is cancelled.	As per Tender
13	44	Clause 63 (Recoveries for Liabilities against Other Contracts)	Any amount recoverable from the Contractor against earlier contracts with the CSPDCL will be adjusted from payment due against the contract that may be awarded under this tender specification.	Request you to please delete the red highlighted: Any amount recoverable from the Contractor against earlier contracts with the CSPDCL will be adjusted from payment due against the contract that may be awarded under this tender specification.	As per Tender
14	91	Annexure-3 Technical Specification	FK 5112 System for Server Room 1 & 2 and UPS	Removal of currently installed pipe lines and install new pipeline shall required hot & hieght work, required approval and downtime to be provided by CSPDCL.	Necessaey approvals for shutdown and downtime shall be coordinated & provided by CSPDCL as per the prevailing situations.
15	91	Annexure-3 Technical Specification	Auto Dialer with minimum 10 numbers enrollment provisioned.	Please confirm Autodialer quantity, it shall be one unit based on our understanding please confirm	Minimum one (01) Auto Dialer shall be provided each at Data Center, Raipur and Disaster Recovery Center, Bilaspur. Neccessay changes has been incorporated in the updated Price -Bid Schedule.
16	92	Annexure-3 Technical Specification	Biometric Reader for Server room	Please confirm if UPS room entry required over bio metric or not?	Biometric Access control shall be provided for critical areas including Server Room only. UPS Rooms access shall be provided through Access Control System as per site requirement.
17	92	Annexure-3 Technical Specification	non POE switch for access control system	Request you to please let us know the ports of switch to be considered? Access controllers and Bio metric readers shall be over IP, hence may we consider 8 port switch for this?	As per tender specification,the Access Control System shall be rovided with a 24-Port unmanaged non-POE Ethernet switch.

18	92	Annexure-3 Technical Specification	32 Channel NVR with minimum 90 days video retention with data safety provision	Please suggest if we may go ahead with storage calculation as per below - 1280*720, h.265 compression, 24*7 basis recording, 25 FPS for 90 days?	The bidder shall ensure minimum 90 days video retention as specified in the tender. Accordingly, the bidder shall provide storage calculation with minimum 1280x720 resolution, h.265 compression, 24*7 basis recording, 25 FPS for 90 days retention period.
19	88	Annexure-3 Technical Specification	32 Channel NVR with minimum 90 days Embedded OS Linux, CPU ARM Processor, Flash 256 MB, RAM 4 GB, Watchdog Hardware + Software, Power Restoration System Restart Automatically after Power Recovery, Record Throughput (MB) 192 Mbps, Network Throughput (MB) min 200 Mbps, HDD Devices Internal x 4, supports RAID 0, 1, 5 (RAID Max. Volume: 16TB), Video Output HDMI x 1, VGA x1, support H.265, H.264, MPEG4 and MJPEG Multiple codec.	We request you to please generalised the specification of NVR as below : 32 Channels NVR, 8 SATA Slots - each slot shall support 10 TB, fully loaded with 80TB Raw Storage, shall support RAID 5 feature, HDMI output, 2 USB ports, Video Output HDMI x 1, VGA x 1, support H.265, H.264. Please remove watchdog hardware & software as embedded standalone NVR shall not support.	As per Tender
20	87	Annexure-3 Technical Specification	5 Megapixel (2592×1944) AI Dome Camera (2.8mm lens) NDAA & STQC certified ; 1. 2.8 progressive CMOS, 30fps 2560×1920 (5MP) 5MP, 2.8mm M12 lens F 2.0 Up to 30 Meter IR Range Video Analytics: Trip wire, Intrusion, Loitering and Restricted Zone and Smart Motion Detection. AI features: People Vehicle classification, Deep Research, Path Extraction (Tightly integrated with VMS) H.265H.264M-JPEG Video Compression PoE Support, NAS Storage support, SD Card (1 TB supported, Min triple stream support. Two way audio support, Digital IO : 1:1 120dB WDR, 3D noise Reduction, Adaptive Streaming , Smart Streaming and ROI, SNR > 70 dB. BIS, CE, FCC, RoHS, IP54, UL. *NDAA Compliant, BIS ER01STQC Certified.	AI features: People Vehicle classification, Deep Learning, Path Extraction (Tightly integrated with VMS) - please note this shall not be applicable for NVR. We request you to please allow below specification as per STQC approved cameras - 5 Megapixel (2592×1944) dome camera, 1. 2.8 progressive CMOS, Smart IR (AutoManual)OFF 40Meters, WDR, BLC, HLC, Wide Dynamic Range 130 dB, ONVIF Profile SGM, Firmware encrypted & Signed, support analytics of Motion Detection, Scene Change, Tamper Detection, Smart Motion, Smart Intrusion, Smart Loitering, Smart Line Crossing Detection, Unattended Object Detection, Missing Object Detection, People Counter, Queuing, Crowd Gathering, Heat Map, Face Detection, with IP66 & IK10 protection, UL listed, CE, FCC, BIS Certified & STQC approved	As per Tender
21	87	Annexure-3 Technical Specification	5 Megapixel (2592×1944) AI Bullet Camera (2.8mm lens 3.6 mm lens) NDAA & STQC certified; 1. 2.8 progressive CMOS, 30fps 2560×1920 (5MP) 5MP, 2.8mm M12 lens F 2.0 (or 3.6 mm optional) Up to 50 Meter IR Range (Smart IR). Video Analytics: Trip wire, Intrusion, Loitering and Restricted Zone and Smart Motion Detection. AI features: People Vehicle classification, Deep Learning, Path Extraction (Tightly integrated with VMS) H.265H.264M-JPEG Video Compression PoE Support, NAS Storage support, SD Card (1 TB supported, Min triple stream support. Two way audio support, Digital IO : 1:1 120dB WDR, 3D noise Reduction, Adaptive Streaming , Smart Streaming and ROI, SNR > 70 dB.Ingress Protection: IP67. BIS, CE, FCC, RoHS, UL.	AI features: People Vehicle classification, Deep Learning, Path Extraction (Tightly integrated with VMS) - please note this shall not be applicable for NVR. We request you to please allow below specification as per STQC approved cameras - 5 Megapixel (2592×1944) bullet camera, 1. 2.8 progressive CMOS, Smart IR (AutoManual)OFF 40Meters, WDR, BLC, HLC, Wide Dynamic Range 130 dB, ONVIF Profile SGM, Firmware encrypted & Signed, support analytics of Motion Detection, Scene Change, Tamper Detection, Smart Motion, Smart Intrusion, Smart Loitering, Smart Line Crossing Detection, Unattended Object Detection, Missing Object Detection, People Counter, Queuing, Crowd Gathering, Heat Map, Face Detection, with IP66 protection, UL listed, CE, FCC, BIS Certified & STQC approved	As per Tender
22	89 & 93	Annexure-3 Technical Specification	The panels shall be mounted inside the risk protected and there shall be a network of air sampling pipe work. Panel should be Vds or UL Listed. VDS Listed Aspirating Detector- 800 SQM coverage	Request your kind attention on contradicting technical specifications. We request you to please allow VDS UL listed for better products selection for Indian Market.	It is clarified that, Aspirating Smoke Detection System shall be UL/Vds listed.
23	96	Annexure-3 Technical Specification	Lot items quantities for cable, conduit, cable tray, rubber mat etc.	We request you to please share the lot items quantities mentioned under BOQ for better estimation	Bidder shall assess site conditions and quote accordingly.
24	83	Annexure-3 Technical Specification	Building management system, access control system, Fire alarm system, Gas suppression & Aspiration smoke detection system should be of same make to maintain SLA and seamless integration.	Gas suppression may not be seamlessly integrated as this system works on potential free contact points. Aspiration & Fire alarm can be integrated with BMS using open communication protocol. However not necessarily from the same OEM. Please allow make selection to meet the integration requirement without having any dependency with same OEM.	Requirement shall be met to ensure the seamless integration Fire Control Panel using renowned OEMs like Siemens /Simplex /Notifier/Ravel

IT/66/2026-ED (EITC) OFC SECTION			I/334164/2026		
25	84	Annexure-3 Technical Specification	The Access Control System's (ACS) shall integrate seamlessly with CCTV system, Building Management System (BMS), Fire Alarm System and Aspiring Smoke Detection System. Preferably, all should be of same make to maintain SLA and seamless integration.	Seamless integration with access control & CCTV is not possible as this is NVR based. Access Control & BMS, Fire, Aspiration seamless integration are not possible, please allow potential free contact point integration. Seek your approval for standalone NVR, standalone Access control & standalone BMS. However, BMS shall be integrated with Fire alarm panel with Aspiration panel over open protocol as per industry standard. Please allow.	As per Tender
26	62 & 80	Annexure-3 Technical Specification	Microprocessor based intelligent 1 loop Main Fire Alarm Control Panel which should be capable of connecting 159 Detectors & 159 modules in a single loop with Power Supply, Battery, LCD Display and Auto Dialler and all other accessories Intelligent addressable Fire Alarm Control Panel with addressable loop supporting up to 252 devices, complete with 24 VDC power supply, built-in NAC circuits, DACT @ city-tie communication, and networkable capability. The panel shall be UL 864 (10th Edition) listed, suitable and compliant with all applicable fire alarm codes and standards.	Request your kind attention on contradicting technical specifications for fire alarm panel. Request you to please allow below for better performance of system : Intelligent addressable Fire Alarm Control Panel with addressable loop supporting up to 252 devices, complete with 24 VDC power supply, built-in NAC circuits, DACT @ city-tie communication, and networkable capability. The panel shall be UL 864 (10th Edition) listed, suitable and compliant with all applicable fire alarm codes and standards.	It is clarified that, the Fire Alarm Control Panel specifications as mentioned on Page-80 shall prevail i.e. Intelligent addressable Fire Alarm Control Panel with addressable loop supporting up to 252 devices, complete with 24 VDC power supply, built-in NAC circuits, DACT @ city-tie communication, and networkable capability. The panel shall be UL 864 (10th Edition) listed, suitable and compliant with all applicable fire alarm codes and standards.
27	81	Annexure-3 Technical Specification	Intelligent Addressable type Manual Call Point Single Action Manual Pull Station UL38 listed, sitting directly in the fire detection system loop circuit without use of any external module, comply with NFPA 72 Class ② (Style 7) survivability requirements.	We request you to please allow Class A style, which is also standard as per UL. Please accept.	Class-A style shall be acceptable, provided it complies with UL/NFPA standards and meets survivability requirements as specified in the tender.
28	82	Annexure-3 Technical Specification	Direct Digital Controllers: BACnet/IP Fully programmable Direct Digital Control (DDC) unit , supporting 16 universal inputs, ② outputs, analog and digital signal processing, BACnet /IP and Modbus communication, real-time control of HVAC, lighting, and energy systems, onboard logic and scheduling, remote monitoring capability, secure access control, and compliant with BIS, IEC, and relevant building automation standards.	We request you to please allow to select DDC as per OEM manufacturing standards for BMS system based on field devices mentioned in the tender.	DDC selection may be as per OEM standard, however it shall fully comply with BACnet/IP, Modbus and BMS interoperability requirements specified in the tender
29	85	Annexure-3 Technical Specification	IP Controller for access doors having autonomous operations of field equipment through peer to peer communications with OSDP Readers ② 4 Monitored or Unmonitored Inputs ② 2 Relay Outputs ② 4 Open-collector Outputs ② 1 general-purpose FLN bus to connect to IPM, OPM and 8IO devices ② Capacity for 500,000 users ② Maximum 5 cards per user ② Large offline event buffer with up to 200,000 events ② Anti-passback	Considering data center environment & having less than 10 doors for each location, we request you to please allow max 100,000 card holder support for controller with 25,000 event buffer. This shall be more than sufficient and shall increase competitiveness of the tender.	As per Tender. Controller capacity specified in the tender is a minimum requirement considering future scalability and expansion.
30	87	Annexure-3 Technical Specification	Integration with proposed Access Control System through open source API or other feasible options for seamless integration between the 2 systems.	We would like to request to delete this clause, as CCTV is NVR based (Linux) hence not support seamless integration. Please allow integration with potential free contact point, in case required.	As per Tender. Integration between Access Control System, CCTV and BMS through Open API/ standard interfaces is mandatory.
31	87	Annexure-3 Technical Specification	Cameras to be popped up based on the ACS events @ alarms	We request you to remove this clause as seamless integration shall not be supported by NVR and Access control system.	As per Tender. Cameras pop up on the ACS events @ alarms is mandatory for effective monitoring and security response.
32	10	Clause 3.2 : Eligibility Criteria	Bidder should be the Original Equipment Manufacturer (OEM) of offered IBMS (like Honeywell, Schneider, Siemens, Johnson Controls or equivalent) or Fire Fighting System (FFS) Or their Authorized Service Provider /System Integrator /Partner /Dealer.	In case the bidder is an authorized Service Provider / System Integrator / Partner / Dealer of the IBMS products or Fire Fighting System (FFS) , bidder should submit the Manufacturers Authorization Form (MAF) cum undertaking letter from the OEM/s to provide service guarantee for support and performance guarantee for the offered products during the contract period. Proforma for MAF is enclosed as in Schedule-14.	It is clarified that, If bidder is an OEM OR an authorized Service Provider / System Integrator / Partner / Dealer of any OEM, they should submit the MAF from other OEMs of the products quoted in the format mentioned in Schedule-14

33	10	Clause 3.3 : Eligibility Criteria	Bidder should have either of the following experience of Implementing IBMS (i.e. Supply, Installation & Integration of IBMS) in India at Data Centres / SCADA Control Centres in Power Utility / PSU / Govt. Organization / Scheduled Banks / Corporates during the last 5 years from date of bid submission: a. at least one (01) project costing not less than Rs. 7.40 Cr. Or, b. at least two (02) projects each costing not less than Rs. 4.6 Cr. Or, c. at least three (03) projects each costing not less than Rs. 3.7 Cr. Further, the projects implemented (for above requirement) should include at least 7 components / sub systems from the following, collectively in maximum three (03) orders: a. Servers / Workstations / NVR, b. CCTV / Video Recording System / Digital Surveillance, c. Access Control System, d. Water Leakage System, e. Building Management System, f. Public addressing system, g. Temperature & Humidity Control (RTH), h. Very Early Smoke Detection Apparatus (VESDA), i. Rodent Repellent System, j. DG Set & UPS, k. Fire Fighting & Suppression System. l. PACs/HPACs/HVACs	Bidder should have either of the following experience of Implementing IBMS or Fire Fighting System (i.e. Supply, Installation & Integration of IBMS/FFS) in India at Data Centres / SCADA Control Centres/ Any Control Monitoring Centers in Power Utility / PSU / Govt. Organization / Scheduled Banks / Corporates during the last 5 years from date of bid submission: a. at least one (01) project costing not less than Rs. 7.40 Cr. Or, b. at least two (02) projects each costing not less than Rs. 4.6 Cr. Or, c. at least three (03) projects each costing not less than Rs. 3.7 Cr. Further, the projects implemented (for above requirement) should include at least 5/12 components / sub systems from the following, collectively in maximum three (03) orders: a. Servers / Workstations / NVR, b. CCTV / Video Recording System / Digital Surveillance, c. Access Control System, d. Water Leakage System, e. Building Management System, f. Public addressing system, g. Temperature & Humidity Control (RTH), h. Very Early Smoke Detection Apparatus (VESDA), i. Rodent Repellent System, j. DG Set & UPS, k. Fire Fighting & Suppression System. l. PACs/HPACs/HVACs	As per Tender
34	11	Clause 3.4 : Eligibility Criteria	The bidder should have a minimum of Twenty (20) technically qualified resources on its payroll for providing Facility Management Service (FMS) support of IBMS in Data Centres/SCADA Control Centres.	The bidder should have a minimum of Twenty (20) technically qualified resources on its payroll for providing Facility Management Service (FMS) support of IBMS/FFS in Data Centres/SCADA Control Centres/ Any IT Control Monitoirng Services.	As per Tender
35	30	Clause 37: Security Deposit cum Performance Guarantee	37.1 On acceptance of Purchase Order, the Contractor will have to deposit an amount of 10% of the total value of the order towards Security Deposit cum Performance Guarantee, either in the form of CTS Demand Draft or Bank Guarantee within 30 days from Date of issue of Order. The security deposit shall be kept till the successful completion of the contract.	Since this contract is divided into two parts—the project with a one-year warranty and a subsequent four-year Facility Management Service (FMS)—we propose that the 10% PBG be handled separately for the initial project amount and the FMS amount.	As per Tender

ED (EITC), CSPDCL, Raipur