

ASR DISPERSE 8331

Multifunctional Boiler Water Treatment



PRODUCT BULLETIN

PRODUCT DESCRIPTION

ASR DISPERSE 8331 is a single drum treatment formulated for the protection against boiler corrosion and scale formation. ASR DISPERSE 8331 is an all-in-one powder product. This product has been formulated specifically for systems that have proper deaeration equipment (dissolved oxygen is less than 0.4ppm in boiler feedwater) and low alkalinity in boiler feedwater. Suggested maximum use pressure is 600 psi [42 Bar].

Physical & Chemical Properties:

These properties are typical. Refer to the Material Safety Data Sheet for the most current data.

Form:

free flowing powder

pH (1% W/W solution)

10.3-11.3

Solubility in Water

complete

Odor:

sweet

Color:

off-white to beige

ACTIVE INGREDIENTS

Alkaline Buffer Compound

Complexing Agent

Oxygen Scavenger

Surface Control Polymer

Corrosion Inhibitor

Scale Dispersant

GOVERNMENT APPROVALS

When use situations necessitate compliance with FDA regulations, ASR DISPERSE 8331 is acceptable under 21 CFR 173.3 10 Boiler Water Additives. ASR DISPERSE 8331 is also approved with the USDA and CFIA.

MATERIALS OF COMPATIBILITY (Neat product)

Compatible Materials

Carbon Steel

EPDM

Fiberglass

Natural Rubber

Neoprene

Nickel

Plexiglass

Polypropylene

PVC

304/316 Stainless Steel

Teflon

Non-Compatible Materials

Aluminum

Buna-N

Copper

Copper Alloys

Hypalon

Placite

Polyurethane

DOSAGE AND FEEDING

Feed **ASR DISPERSE 8331** by making a 5 to 10% solution of the product using demineralized water, condensate, or zeolite softened water between 50 and 100°F. Mix gently, only until dissolving is complete. To minimize reaction with the air, a floating cover is recommended. Make only enough solution to last for a 24-hour period. Fresh solution should be made up daily.

When a deaerator or feedwater heater is present, ASR DISPERSE 8331 should be fed continuously to the storage section. When no deaeration equipment is available, ASR DISPERSE 8331 must be fed continuously to the suction side of the feedwater pump. Any interruption in feed will result in scale formation and/or corrosion in the boiler and possible tube failure.

For systems with deaeration equipment, ASR DISPERSE 8331 must be fed at least 8 inches under the lowest waterline via a stainless steel injection quill (ASR Part No. P4610).

It is recommended that ASR DISPERSE 8331 be fed neat, however where dilution is required use cooled condensate (<90°F) [32°C] or the softest water available. A floating "doughnut" type cover is recommended to minimize reaction with air.

N.B : Do not add other chemicals to diluted product without first bench testing dilutions for stability.

SAFETY AND HANDLING

Read the label and Material Safety Data Sheet for complete handling information before using this product.

STORAGE

ASR DISPERSE 8331 storage temperature should not exceed 120°F / 49°C. An in-plant storage limit of six months is recommended.

ADDITIONAL INFORMATION

ASR DISPERSE 8331 is one of a family of multi-functional boiler treatment products.

NOTE: *Variations in feedwater hardness, dissolved oxygen and alkalinity may require supplemental feed of other products.*