02/04/2014

AVERAGE TURBINE EFFICIENCY FIGURES

1	Wimalasurendra Power Station	1GWh = 1.983MCM / 70 M.C. ft.	or	1MW =	0.55 cumecs/	19.44 cusecs
2	Laxapana Power Station	1GWh = 0.935 MCM/ 33 M.C. ft.	or	1MW =	0.26 cumecs/	12.17 cusecs
3	Polpitiya Power Station	1GWh = 1.643 MCM/ 58 M.C. ft.	or	1MW =	0.456 cumecs/	16.1 cusecs
4	New Laxapana Power Station	1GWh = 0.822 MCM/ 29 M.C. ft.	or	1MW =	0.228 cumecs/	8.06 cusecs
5	Canyon Power Station	1GWh = 2.246 MCM/ 79.3 M.C. ft.	or	1MW =	0.624 cumecs/	22.03 cusecs
6	Ukuwela Power Station	1GWh = 5.099 MCM/ 180 M.C. ft.	or	1MW =	1.416 cusecs/	50 cusecs
7	Bowatenna Power Station	1GWh = 8.511MCM/ 6.9 TAF	or	1MW =	2.364 cumecs/	33.5 cusecs
8	Victoria Power Station	1GWh = 2.087 MCM/ 72.5 M.C. ft.	or	1MW =	0.577 cumecs/	20.4 cusecs

---

RESERVOIR ENERGY PARAMETERS

1	Castlereigh	0.4584 MCM/GWh	or	1 M.C ft =	0.0618	GWh (with W.P.S. + L.P.S. + S.P.S.)
2	Maussakelle	0.4404 MCM/GWh	or	1 M.C ft =	0.06435	GWh (with N.L.P.S. + S.P.S. + Canyon)
3	Norton	0.596 MCM/GWh	or	1 M.C ft =	0.0475	GWh (with L.P.S. + S.P.S.)
4	Laxapana.	1.648 MCM/GWh	or	1 M.C ft =	0.0172	GWh (S.P.S.)
5	Canyon	0.5479 MCM/GWh	or	1 M.C ft =	0.0517	GWh(with N.L.P.S. + S.P.S.)
6	Victoria	2.087 MCM/GWh	or	1 M.C ft =	0.0138	GWh
7	Polgolla	5.10 MCM/GWh	or	1 M.C ft =	0.0056	GWh
8	Bowatenna	8.511 MCM/GWh	or	1 M.C ft =	0.0033	GWh

SPILT ENERGY (ENERGY LOSSES)

1	Castlereagh	1 M.C. ft.	=	1/70	GWh	1 MCM	=	0.504	GWh
2	Norton	1 M.C. ft.	=	0.0475	GWh	1 MCM	=	1.677	GWh
3	Mausekella	1 M.C. ft.	=	0.0126	GWh(with canyon)	1 MCM	=	0.445	GWh
4	Laxapana	1 M.C. ft.	=	1/58	GWh	1 MCM	=	0.609	GWh

---

1 TAF = 1.2335 M.C.M.

1 M.C.F. = 1/35.3 M.C.M.

Laxapana Power Station