

az5 / PLC\_1 [CPU 1511C-1 PN] / Program blocks

Data\_block\_1 [DB2]

Data_block_1 Properties							
General							
Name	Data_block_1	Number	2	Type	DB	Language	DB
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Data_block_1										
Name	Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA/Web API	Writ-able from HMI/ OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
D_SEL	Bool	0.0	false	False	True	True	True	False		
I_SEL	Bool	0.1	false	False	True	True	True	False		
P_SEL	Bool	0.2	false	False	True	True	True	False		
GAIN	Real	2.0	0.0	False	True	True	True	False		
TI	Time	6.0	T#0ms	False	True	True	True	False		
TD	Time	10.0	T#0ms	False	True	True	True	False		
SP_INT	Real	14.0	0.0	False	True	True	True	False		
PV_IN	Real	18.0	0.0	False	True	True	True	False		
MAN	Real	22.0	0.0	False	True	True	True	False		
MAN_ON	Bool	26.0	false	False	True	True	True	False		
LMN	Real	28.0	0.0	False	True	True	True	False		
D_SEL_1	Bool	32.0	false	False	True	True	True	False		
I_SEL_1	Bool	32.1	false	False	True	True	True	False		
P_SEL_1	Bool	32.2	false	False	True	True	True	False		
GAIN_1	Real	34.0	0.0	False	True	True	True	False		
TI_1	Time	38.0	T#0ms	False	True	True	True	False		
TD_1	Time	42.0	T#0ms	False	True	True	True	False		
SP_INT_1	Real	46.0	0.0	False	True	True	True	False		
PV_IN_1	Real	50.0	0.0	False	True	True	True	False		
MAN_1	Real	54.0	0.0	False	True	True	True	False		
MAN_ON_1	Bool	58.0	false	False	True	True	True	False		
LMN_1	Real	60.0	0.0	False	True	True	True	False		