Name	Value	Data Type	Scope
S1_START	0	BOOL	HMI_Program

    AliasFor: Remote_IO:2:I.7(C)
    Base Tag: Remote_IO:I.Data[2].7(C)
    Constant   No
    External Access: Read/Write
    S1_START - Station1_Program/S1_Inputs - 1(XIC)

Name	Value	Data Type	Scope
S1_StartLED	0	BOOL	HMI_Program

    AliasFor: Remote_IO:6:O.0(C)
    Base Tag: Remote_IO:O.Data[6].0(C)
    Constant   No
    External Access: Read/Write
    S1_StartLED - HMI_Program/MainRoutine - 1(XIC)
    S1_StartLED - Station1_Program/S1_Outputs - *0(OTE)

Name	Value	Data Type	Scope
S1_STOP	1	BOOL	HMI_Program

    AliasFor: Remote_IO:3:I.0(C)
    Base Tag: Remote_IO:I.Data[3].0(C)
    Constant   No
    External Access: Read/Write
    S1_STOP - HMI_Program/MainRoutine - 1(XIC)
    S1_STOP - Station1_Program/S1_Inputs - 0(XIC)

Name	Value	Data Type	Scope
S2_START	0	BOOL	HMI_Program

    AliasFor: Remote_IO_2:2:I.7(C)
    Base Tag: Remote_IO_2:I.Data[2].7(C)
    Constant   No
    External Access: Read/Write
    S2_START - Station2_Program/S2_Inputs - 1(XIC)

Name	Value	Data Type	Scope
S2_StartLED	0	BOOL	HMI_Program

    AliasFor: Remote_IO_2:6:O.0(C)
    Base Tag: Remote_IO_2:O.Data[6].0(C)
    Constant   No
    External Access: Read/Write
    S2_StartLED - HMI_Program/MainRoutine - 2(XIC)
    S2_StartLED - Station2_Program/S2_Outputs - *0(OTE)

Name	Value	Data Type	Scope
S2_STOP	1	BOOL	HMI_Program

    AliasFor: Remote_IO_2:3:I.0(C)
    Base Tag: Remote_IO_2:I.Data[3].0(C)
    Constant   No
    External Access: Read/Write
    S2_STOP - HMI_Program/MainRoutine - 2(XIC)
    S2_STOP - Station2_Program/S2_Inputs - 0(XIC)

Name	Value	Data Type	Scope
S3_START	0	BOOL	HMI_Program

    AliasFor: Remote_IO_3:2:I.7(C)
    Base Tag: Remote_IO_3:I.Data[2].7(C)
    Constant   No
    External Access: Read/Write
    S3_START - Station3_Program/S3_Inputs - 1(XIC)

Name	Value	Data Type	Scope
S3_StartLED	0	BOOL	HMI_Program

    AliasFor: Remote_IO_3:6:O.0(C)
    Base Tag: Remote_IO_3:O.Data[6].0(C)
    Constant   No
    External Access: Read/Write
    S3_StartLED - HMI_Program/MainRoutine - 3(XIC)
    S3_StartLED - Station3_Program/S3_Outputs - *0(OTE)

Name	Value	Data Type	Scope
S3_STOP	1	BOOL	HMI_Program

    AliasFor: Remote_IO_3:3:I.0(C)

S3_STOP (Continued)

Base Tag: Remote_IO_3:I.Data[3].0(C)
Constant   No
External Access: Read/Write
S3_STOP - HMI_Program/MainRoutine - 3(XIC)
S3_STOP - Station3_Program/S3_Inputs - 0(XIC)