

POLARIS DC-1 — BUILDING PERMIT DECISION AND CONDITIONS

Document Ref: PDC-PP-001 Rev A
Project: Polaris DC-1 — Aviapolis Data Campus, Phase 1, Vantaa, Finland
Issuing authority: City of Vantaa Building Control (Rakennusvalvonta), Building Control Committee
Decision reference: 2025-1187-R
Decision date: 18 December 2025
Status: Permit Document — binding condition set

This is synthetic demonstration data. The issuing authority is named generically after a real municipal function (City of Vantaa Building Control / Rakennusvalvonta) for realism; the decision reference, the named officers, the application number, all dates other than those fixed in the project baseline, and all condition text are invented for the purpose of exercising the White Hat IQ platform. No real permit, real applicant conduct or real officer is described.

1. DECISION HEADER

Item	Value
Applicant	Polaris Digital Infrastructure Oy (the Employer)
Applicant's representative	NordBuild Oy, General Contractor, acting under power of attorney for the application
Property	Plot 92-52-7-2, Aviapolis, Vantaa (4.8 ha, greenfield)
Application reference	RAKVAL-2025-04417
Permit type	Building permit (rakennuslupa) under the Land Use and Building Act (132/1999) §125, including the associated demolition-free earthworks and blasting notification
Decision body	Vantaa Building Control Committee, delegated decision by the Chief Building Inspector
Decision date	18 December 2025
Decision reference	2025-1187-R
Validity — commencement	The Works authorised by this permit must be commenced within three (3) years of the date this decision becomes final, i.e. by 18 December 2028 at the latest. Notice of commencement (aloitusilmoitus) shall be lodged with Building Control not less than 7 days before site works begin.
Validity — completion	The Works must be completed within five (5) years of the date this decision becomes final, i.e. by 18 December 2030 at the latest, subject to Condition 2 (sectional occupancy).
Appeal period	14 days from publication of this decision. Publication is deemed to occur on 19 December 2025. Any appeal lies to the Helsinki Administrative Court. Works commenced before the appeal period has run are at the Applicant's own risk.
Building tax value (for fee calculation)	See Section 5

This decision is issued on the basis of the application drawings, the Employer's Requirements referenced therein, the geotechnical and site constraints report submitted with the application, and the statements obtained from the Regional State Administrative Agency (environmental

obtained from the Regional State Administrative Agency (environmental matters), Fintraffic / Finavia (aviation matters, Helsinki-Vantaa Airport being approximately 3 km from the site), the Vantaa rescue authority (fire and blasting matters), and Caruna Espoo Oy (grid interface, informational only — the grid connection itself is the subject of a separate agreement, PDC-GC-001).

2. APPROVED SCOPE AND DRAWINGS REGISTER

The permit authorises construction of a single-storey industrial/technical building with services mezzanine, comprising four data halls, a 110/20 kV primary substation and switchgear building, a standby generation compound (8 units), a chiller and dry-cooler yard, an administration and network operations centre (NOC) block, and a security gatehouse, together with associated external works, drainage, landscaping and two fibre entry routes, as follows:

Item	Value
Total gross floor area (GFA)	14,450 m ² , ±3% design tolerance
Storeys	Single storey plus services mezzanine
Data halls	4, each 2.5 MW IT load
Substation	110/20 kV primary substation and switchgear building
Standby generation	8 units, enclosed compound
Cooling plant	Chiller and dry-cooler yard
Administration / NOC block	2-storey, offices, NOC, welfare
Security	Gatehouse, perimeter fence, vehicle gate
Site area	4.8 ha, greenfield

The permit is granted strictly in accordance with the following drawings, deposited with and stamped by Building Control on 3 December 2025. No departure from these drawings is authorised without a separate amendment decision (poikkeamispäätös) or, for minor changes, written confirmation from Building Control that the change falls within permitted tolerance.

Drawing no.	Title	Rev
PDC-DWG-A-001	Site plan and setting-out	B
PDC-DWG-A-010	Ground floor general arrangement	B
PDC-DWG-A-011	Services mezzanine general arrangement	B
PDC-DWG-A-020	Elevations — north and east	A
PDC-DWG-A-021	Elevations — south and west	A
PDC-DWG-A-030	Sections 1-1 and 2-2	A
PDC-DWG-S-001	Structural framing plan	B
PDC-DWG-S-010	Foundation plan and blasting extent	B
PDC-DWG-M-001	Data hall containment layout	A
PDC-DWG-E-001	Electrical single-line diagram (site)	B
PDC-DWG-M-010	Cooling schematic	A
PDC-DWG-F-001	Fire suppression and compartmentation plan	A

PDC-DWG-A-040	Security and access control layout	A
PDC-DWG-C-001	External services and drainage layout	B

3. CONDITIONS OF PERMIT

The permit is granted subject to the following conditions, each of which is binding on the Applicant and its Contractor. Non-compliance with any condition may result in a stop-work order under §180 of the Land Use and Building Act.

3.1 Appointed supervisors

1. Before any site works commence, the Applicant shall submit for Building Control's approval the appointment of a **responsible site manager** (vastaava työnjohtaja) holding qualifications appropriate to a building of this demanding class (vaativa työnjohtotehtävä). Works may not commence until this appointment is approved and confirmed in writing.
2. Before any water and drainage works commence, a **KVV supervisor** (kiinteistön vesi- ja viemärlaitteiston työnjohtaja) shall be appointed and approved in the same manner.
3. Before any ventilation and air-handling works commence, an **IV supervisor** (ilmanvaihtotyön johtaja) shall be appointed and approved in the same manner.
4. A change of any appointed supervisor during the Works requires prior written approval of a replacement before the outgoing supervisor ceases duties. Works in the relevant discipline shall not proceed during any gap in an approved appointment.

3.2 Inspections during construction and occupancy

5. The following statutory inspections shall be called by the responsible site manager and witnessed by Building Control at the stages customary for a building of this type: commencement inspection, foundation inspection, structural frame inspection, fire compartmentation inspection, and the inspections proper to the KVV and IV supervisors' disciplines. The Contractor shall give not less than 5 working days' notice of each inspection.
6. No part of the Works may be taken into use, and no occupancy may occur, before the **occupancy inspection (käyttöönottotarkastus)** for that part has been passed. Building Control confirms, on the Applicant's application recorded in this file, that **sectional occupancy inspections are permitted on a per-data-hall basis**: each of the four data halls, together with the shared infrastructure necessary to support it, may be presented for its own occupancy inspection and taken into use independently of the other halls, provided that:
 - (a) the shared infrastructure sized for the full 10 MW facility (primary substation, standby generation, shared cooling spine, site access) has passed its own occupancy inspection as part of the first such sectional inspection; and
 - (b) construction activity on the remaining, not-yet-occupied halls does not compromise the fire, escape or life-safety provisions of any hall already occupied.
7. A final occupancy inspection of the whole permitted scope, including the administration/NOC block, external works and landscaping, shall be held

administration, A/C block, external works and landscaping, shall be held following occupancy of the fourth and final data hall.

8. As-built drawings reflecting the condition of each Section at the time of its occupancy inspection shall be lodged with Building Control not later than the date of that inspection.

3.3 Blasting

9. Blasting in the eastern third of the plot, as shown on PDC-DWG-S-010, is authorised only on production of a valid **blasting permit issued by the Vantaa rescue authority** (pelastuslaitos) under the Explosives Act and the Rescue Act. A copy of that permit shall be lodged with Building Control before blasting begins.
10. A **pre-condition survey (katselmus) of neighbouring properties** within the zone of influence identified in the blasting plan shall be carried out and documented, with photographic record, before blasting begins.
11. **Vibration monitoring** shall be maintained continuously during blasting, with a peak particle velocity limit of **12 mm/s** at the nearest sensitive structure, measured in accordance with the applicable Finnish standard. Any exceedance shall halt blasting pending review.
12. Neighbours within the pre-condition survey zone shall be given **not less than 7 days' written notice** before blasting commences in their vicinity, and shall be given a contact point for complaints during the blasting programme.
13. Blasting shall take place only **08:00–18:00 on weekdays**. No blasting is permitted on weekends, public holidays, or outside these hours.

3.4 Noise

14. The **night-time noise limit at the north-east residential boundary is 45 dB(A)**, consistent with the Employer's Requirements. This limit applies to all construction and, following completion, to operational plant.
15. **Generator testing and commissioning** (including load-bank testing) is restricted to **09:00–16:00 on weekdays** for the duration of the construction and commissioning period, unless a specific exemption is obtained in writing from Building Control for an identified test that cannot practicably be run within these hours.

3.5 Aviation

16. Helsinki-Vantaa Airport lies approximately 3 km from the site. No part of any permanent structure, including plant, antennae or lightning protection, shall exceed **75.0 metres above ground level, corresponding to +85.0 metres above mean sea level (N2000)**, without a separate aviation obstacle clearance from the relevant aviation authority.
17. **Obstacle lighting** conforming to the applicable aviation lighting standard shall be fitted to the highest fixed point of plant on the completed building (expected to be the dry-cooler yard structure or generator exhaust stacks, to be confirmed at detailed design) and shall be operational from practical completion of that plant.
18. **Crane operations** of any kind on this site require a separate aviation clearance from Fintraffic / Finavia, obtained by the Contractor, with a stated **minimum lead time of 21 days** per crane location and configuration. No crane shall be erected or operated without evidence of a current clearance held on site.

3.6 Stormwater and drainage

19. Surface water discharge from the developed site shall be attenuated and limited to a maximum discharge rate of **20 litres/second/hectare**, consistent with the greenfield run-off rate assumed by the receiving network, using on-site attenuation as shown on PDC-DWG-C-001.
20. **Oil separators** (class I, full retention) shall be installed and maintained on drainage serving the generator compound and any fuel storage or fuel-handling areas before those areas are commissioned.

3.7 Landscaping and tree replacement

21. Landscaping shall be completed in accordance with the approved landscaping scheme within one growing season of practical completion of the adjacent external works, or as otherwise agreed in writing with Building Control.
22. Trees removed from the site during construction shall be replaced at a ratio of not less than **2:1** with species from the approved planting list, planted within the site boundary or, where site area does not permit, at a location agreed with the City's green area authority.

3.8 District heating waste-heat connection

23. Before final occupancy of the administration/NOC block (the last element of the permitted scope), the Applicant shall demonstrate that the district-heating waste-heat recovery connection at the site boundary chamber has been constructed and functions as designed, including delivery of the minimum thermal output and flow temperature specified in the Employer's Requirements (see PDC-DH-001). Evidence of this demonstration shall be lodged with Building Control as part of the final occupancy inspection documentation.

3.9 Archaeology and unrecorded finds

24. The site survey lodged with this application notes unrecorded made ground in the north-west corner of the plot, of uncertain origin. If, during earthworks or at any other time during the Works, any previously unrecorded structure, artefact, or other indication of archaeological or historical remains is encountered anywhere on the site, **work in the affected area shall stop immediately** and the **Finnish Heritage Agency (Museovirasto)** shall be notified without delay, in accordance with the Antiquities Act (295/1963). Work in the affected area shall not resume until the Finnish Heritage Agency has confirmed that it may do so. This condition applies notwithstanding the sectional completion programme and shall not, of itself, be treated as excusing delay elsewhere on the site.

3.10 General

25. This permit does not relieve the Applicant or its Contractor of any obligation under the Working Environment Act, the Rescue Act, or any other applicable statute.
26. Any condition of this permit found to be in conflict with the approved drawings shall be referred to Building Control for clarification before proceeding.

4. FEES AND SECURITIES

Item	Value	Basis
Building permit fee	EUR 214,600	Per the Vantaa Building Control fee tariff, calculated on permitted GFA and building class
Blasting notification processing fee	EUR 4,200	Fixed fee, rescue authority coordination
Sectional occupancy inspection fee (× 4 halls + 1 final)	EUR 3,100 per inspection	Per the fee tariff, five inspections total
Landscaping/tree-replacement security	EUR 85,000	Held as a bank guarantee, released on Building Control's confirmation of Condition 21/22 compliance
Stormwater attenuation compliance security	EUR 60,000	Held as a bank guarantee, released on commissioning confirmation of the attenuation system per Condition 19

Fees are payable within 30 days of invoicing by Building Control. Securities shall be lodged before the commencement inspection (Condition 5) and are in addition to, and independent of, any performance security required under the construction contract.

As-built documentation: a complete as-built drawing set, a schedule of statutory certificates (electrical, fire suppression, pressure equipment, lifting equipment as applicable), the KVV and IV supervisors' final reports, and the vibration monitoring record for the blasting works shall be lodged with Building Control before the final occupancy inspection under Condition 7. Sectional as-built documentation under Condition 8 forms part of, and is not superseded by, this final submission.

5. DECISION

The application is **APPROVED** subject to the conditions set out in Section 3 above. This decision, together with the approved drawings listed in Section 2, constitutes the building permit for Polaris DC-1.

Issued at Vantaa, 18 December 2025.

Elina Rantakangas
Chief Building Inspector
City of Vantaa Building Control (Rakennusvalvonta)

On behalf of the Building Control Committee, decision 2025-1187-R.

*This is synthetic demonstration data prepared for the White Hat IQ platform.
No real permit application, real decision, or real officer is described.*