Project planning report

Saved project inputs and selected calculation results

2026-10-25 10:21:05.716113+00:00

Project

This report presents saved project inputs and the original results of the selected calculations. Country-specific requirements, electrical design and installation checks remain open. It does not approve the complete installation.

Project	Berlin · Beispielprojekt · PV und Speicher
Project reference	c7795bc2c1e14e389622015c809ace45
Input revision	18

Site and project inputs

Location	Berlin · Beispielstandort
Country	DE
Time zone	Europe/Berlin
Project note	Interaktives Beispiel mit echten JRC-Wetterdaten und nachgewiesenen Trina-Moduldaten; Dachgeometrie und Verbrauch sind Beispielannahmen.

Energy scenario and selected equipment

These checks compare the saved scenario parameters with the equipment selected for this calculation. They do not establish manufacturer performance.

4.5 × 3 = 13.5 kWh

Assessment status	Further checks required
Model	SAJ BU2-5.0-HV1
Model	SAJ BC2-HV1
Model	SAJ H2-10K-T3
Module count	3
Parallel arrangement	1
Usable energy · Source document · Page 2	4.5 kWh https://de-linker.com/wp-content/uploads/2026/09/B2-5-25K-HV1HV5-datasheet-EN-BEU.pdf

Check	Assessment status	Result	Requirement
Usable energy	Checked requirements met	13.5 kWh	13.5 kWh
Continuous AC discharge power	Further checks required	—	7.587 kW
Scenario operating mode	Checked requirements met	—	—
Storage losses and operating conditions	Further checks required	—	—
Converter ports and system topology	Further checks required	—	—

Energy scenario

PV generation and curtailment are calculated at the DC bus; load supply and grid flows are calculated on the AC side. Storage results use the saved loss assumptions.

Battery temperature is a fixed scenario condition used to check the documented charging and discharging temperature ranges. It is not inferred from outdoor weather. This model uses fixed loss assumptions and does not simulate temperature changes.

Simulated load demand	1.103 kWh
PV generation (DC)	9.634 kWh
Grid import	0 kWh
PV export	0.798 kWh
PV curtailment (DC)	0 kWh
Unserved simulated load	0 kWh
Solar share of gross demand	100 %
PV used or stored on site	91.374 %
Calculated intervals	2
Battery temperature for this scenario	20 °C

Saved calculation references

Data source	Beispielannahme · kein externer AC-Hilfsverbrauch
Data source	Declared reference assumptions: DC/DC 98% each way, storage 99% each way, forward inverter 96%, fixed battery temperature 20 °C, zero internal and DC auxiliary demand and standing loss. No reverse charging. These are scenario assumptions, not manufacturer performance data.
Data source	Beispielverbrauch · 6.000 kWh pro Jahr
Data source	JRC PVGIS typical meteorological year
Calculation reference	37101494e75844d7bb146ca95c499052 · Input revision 18