Project planning report

Saved project inputs and selected calculation results

2026-10-27 20:17:50.506008+00:00

Project

This report presents saved project inputs and the original results of the selected calculations. Country-specific requirements, electrical design and installation checks remain open. It does not approve the complete installation.

Project	Linker production acceptance · owned synthetic project
Project reference	1812286480344d6d8cec94e2f5f2c00e
Input revision	12

Site and project inputs

Location	Paris · public city-centre reference · synthetic acceptance
Country	FR
Time zone	Europe/Paris
Project note	Owned synthetic production acceptance. No customer data, no installation claim, no inquiry.

Provisional bill of materials

This list combines the selected equipment, saved roof modules and documented included components. Quantities are shown where established. Mounting, cabling, protection and other installation materials still require project-specific design.

Quantity	Product	Reference	Supply scope
20 pc	Trina Solar TSM-460NEG9R.28		PV reference module · project quotation

PV modules used in the calculation

Module counts come from the saved layout of the selected generation result. The listed modules are design references; electrical and mounting suitability require project-specific assessment.

Input revision	11
PV nameplate power	9.2 kWp
Source document · Page 2	Trina Solar TSM-460NEG9R.28 https://de-linker.com/wp-content/uploads/2026/09/240831_Datasheet_Vertex-S_NEG9R.28_EN_2024_C_web.pdf

Quantity	Model	Module power (STC)
20	Trina Solar TSM-460NEG9R.28	460 W

PV generation scenario

This section presents the selected saved PV profile and its original assumptions. Detailed shading and electrical design require separate assessment.

PV generation	9,315.201 kWh
Calculation period (UTC)	2023-01-01T00:00:00+00:00 – 2024-01-01T00:00:00+00:00
Calculated intervals	8,760

Energy scenario

These values come from the selected saved energy result and reflect its original scenario parameters. The general energy-flow model does not establish the performance of the selected equipment.

Calculation period (UTC)	2023-06-16T09:00:00+00:00 – 2023-06-16T11:00:00+00:00
Simulated load demand	1.103 kWh
PV generation	12.341 kWh
Grid import	0 kWh
PV export	11.238 kWh
PV curtailment	0 kWh
Unserved simulated load	0 kWh
Solar share of gross demand	100 %
PV used or stored on site	8.934 %
Calculated intervals	2

Saved calculation references

Data source	Synthetic 2023 zero external AC auxiliary load · Paris reference scenario
Data source	Owned synthetic PV/load-only baseline: explicitly zero storage capacity and power, unit efficiencies, zero loss. No SKU performance assertion.
Data source	Synthetic 2023 gross load · Paris reference scenario
Data source	JRC PVGIS typical meteorological year
Calculation reference	f32e226aa7d74ae9a65e655dffb4cc22 · Input revision 12
Calculation reference	e9875888ea9d4273ae162448554de1ab · Input revision 11