Project planning report

Saved project inputs and selected calculation results

2026-10-25 13:14:58.988799+00:00

Project

This report presents saved project inputs and the original results of the selected calculations. Country-specific requirements, electrical design and installation checks remain open. It does not approve the complete installation.

Project	Berlin · Beispielprojekt · PV und Speicher
Project reference	c7795bc2c1e14e389622015c809ace45
Input revision	20

Saved calculation comparison

Difference = comparison minus baseline. Differences in ratios are shown in percentage points. PV differences also require the same AC/DC boundary.

Matching comparison conditions do not establish manufacturer performance or installation approval.

Baseline calculation

Declared reference assumptions: DC/DC 98% each way, storage 99% each way, forward inverter 96%, fixed battery temperature 20 °C, zero internal and DC auxiliary demand and standing loss. No reverse charging. These are scenario assumptions, not manufacturer performance data.

Input revision	18
Calculation reference	37101494e75844d7bb146ca95c499052
Model	SAJ BU2-5.0-HV1
Model	SAJ BC2-HV1
Model	SAJ H2-10K-T3
Usable energy	13.5 kWh
Module count	3
Parallel arrangement	1
Location	Berlin · Beispielstandort
Country	DE
Time zone	Europe/Berlin
Calculated periods (UTC)	2023-06-16T09:00:00+00:00 – 2023-06-16T11:00:00+00:00
Starting stored energy	0 kWh
Required final stored energy	No minimum required
Scenario requirements	Checked requirements met

Comparison calculation

Declared reference assumptions: DC/DC 98% each way, storage 99% each way, forward inverter 96%, fixed battery temperature 20 °C, zero internal and DC auxiliary demand and standing loss. No reverse charging. These are scenario assumptions, not manufacturer performance data.

Input revision	20
Calculation reference	4a89969354884bb79292f9ca000574c4
Model	SAJ BU2-5.0-HV1
Model	SAJ BC2-HV1
Model	SAJ H2-10K-T3

Usable energy	18 kWh
Module count	4
Parallel arrangement	1
Location	Berlin · Beispielstandort
Country	DE
Time zone	Europe/Berlin
Calculated periods (UTC)	2023-06-16T09:00:00+00:00 – 2023-06-16T11:00:00+00:00
Starting stored energy	0 kWh
Required final stored energy	No minimum required
Scenario requirements	Checked requirements met

Saved calculation comparison

Result	Baseline calculation	Comparison calculation	Difference
Simulated load demand	1.103 kWh	1.103 kWh	0 kWh
Solar supplied to load	1.103 kWh	1.103 kWh	0 kWh
Grid import	0 kWh	0 kWh	0 kWh
Unserved simulated load	0 kWh	0 kWh	0 kWh
PV export	0.798 kWh	0 kWh	-0.798 kWh
Stored energy at end	7.391 kWh	8.198 kWh	0.806 kWh
PV generation	9.634 kWh (DC)	9.634 kWh (DC)	0 kWh
Solar share of gross demand	100 %	100 %	0 pp
PV used or stored on site	91.374 % (DC)	100 % (DC)	8.626 pp

Comparison basis

Site and time zone	Match
Calculated periods	Match
Load and auxiliary sources	Match
PV weather or identical generation input	Match
Time resolution	Match
Operating requirements	Match
Starting stored energy	Match
Required final stored energy	Match
Load measurement scope	Match
Calculation method	Match
Scenario requirements	Match
Battery temperature	Match

Design and assumption changes

Storage parameters	Changed
Equipment selection	Changed
PV layout and generation settings	Unchanged
DC auxiliary demand	Unchanged

Saved calculation references

Data source	Beispielannahme · kein externer AC-Hilfsverbrauch
Data source	Declared reference assumptions: DC/DC 98% each way, storage 99% each way, forward inverter 96%, fixed battery temperature 20 °C, zero internal and DC auxiliary demand and standing loss. No reverse charging. These are scenario assumptions, not manufacturer performance data.
Data source	Beispielverbrauch · 6.000 kWh pro Jahr
Data source	JRC PVGIS typical meteorological year
Calculation reference	37101494e75844d7bb146ca95c499052 · Input revision 18
Calculation reference	4a89969354884bb79292f9ca000574c4 · Input revision 20