Project planning report

Saved project inputs and selected calculation results

2026-10-25 04:24:04.204501+00:00

Project

This report presents saved project inputs and the original results of the selected calculations. Country-specific requirements, electrical design and installation checks remain open. It does not approve the complete installation.

Project	Lyon · synthetic energy scenario · acceptance
Project reference	334e269920d540fe8573a66a1031e0be
Input revision	6

Site and project inputs

Location	Lyon · synthetic acceptance data; not a surveyed site
Country	FR
Time zone	Europe/Paris
Project note	Independent synthetic two-hour analytic scenario. No measured customer data, product approval, country release or annual forecast.

Energy scenario and selected equipment

These checks compare the saved scenario parameters with the equipment selected for this calculation. They do not establish manufacturer performance.

4.5 × 3 = 13.5 kWh

Assessment status	Further checks required
Model	SAJ BU2-5.0-HV1
Model	SAJ BC2-HV1
Model	SAJ H2-10K-T3
Module count	3
Parallel arrangement	1
Usable energy · Source document · Page 2	4.5 kWh https://de-linker.com/wp-content/uploads/2026/09/B2-5-25K-HV1HV5-datasheet-EN-BEU.pdf

Check	Assessment status	Result	Requirement
Usable energy	Checked requirements met	13.5 kWh	5 kWh
Continuous AC discharge power	Further checks required	—	5 kW
Continuous AC charge power	Further checks required	—	5 kW
Scenario operating mode	Checked requirements met	—	—
Storage losses and operating conditions	Further checks required	—	—
Converter ports and system topology	Further checks required	—	—

Energy scenario

These values come from the selected saved energy result and reflect its original scenario parameters. The general energy-flow model does not establish the performance of the selected equipment.

Simulated load demand	4 kWh

PV generation	4 kWh
Grid import	0.38 kWh
PV export	0 kWh
PV curtailment	0 kWh
Unserved simulated load	0 kWh
Solar share of gross demand	90.5 %
PV used or stored on site	100 %
Calculated intervals	2

Saved calculation references

Data source	Synthetic external AC auxiliary · explicit zero
Data source	Explicit analytic acceptance scenario: 5 kWh usable, 5 kW AC in/out, separate 90% efficiencies, zero auxiliary and standing losses. No manufacturer, SKU or equipment approval.
Data source	Synthetic gross load · 2 kW for two hours
Data source	Synthetic available PV · 4 kW then 0 kW
Calculation reference	60d5753119cd46879aa357a0404ca0cd · Input revision 6