



MGPS LAYOUT



<div>1. Marking and saddling</div> <div>2. Installation of copper pipe, Valve box & alarms.</div> <div>3. Pressure testing of copper pipe.</div> <div>4. Color coding .</div> <div>5. Installation of gas outlets.</div> <div>6. Testing of pipe line.</div> <div>7. Fixing of accessories.</div> <div>8. final testing & hand over.</div> <div>Note:-</div> <div>- 5 amp switch and socket required for all Area Alarm</div> <div>- Panels (AAP) above 7 feet from F.F.L.</div> <div>- Trap door (2'x2') required in false ceiling wherever AAP located</div> <div>- All the Medical outlets will be installed at right side of patient.</div> <div>- All the layout of medical gas pipelines will be as per the approved shop drawings.</div> <div>- Any Change in civil work where required will not be in our scope.</div> <div>- All pipe line will run above fall ceiling .</div> <div>- inside rooms & wards pipe line will run above fall ceiling and vertical down drops will install on surface of wall .</div> <div>- All alarm & valve boxes will install on surface of wall .</div>	ISOLATION VALVE BOX :-		PIPE LINE :-		OUTLETS:-	PURPOSE OF DRAWING :- DRAWING FOR APPROVAL	CONTRACTOR :- <div>MPS</div> <div>MPS ASTA CONSORTIUM</div> <div>59, INDU HOUSE RAMA ROAD INDUSTRIAL AREA NEW DELHI-110015 Ph:9810207360,9700961991 Email:sotc.mpsasta@gmail.com</div>				
	2 GAS SERVICE	AVSU2	AAM2	OXYGEN						SOTC GANDHI HOSPITAL, HYDERABAD	SHEET TITLE :- EIGHTH FLOOR MGPS LAYOUT
	3 GAS SERVICE	AVSU3	AAM3	NITROUS OXIDE		SCALE -	1:1	05	03		
	4 GAS SERVICE	AVSU4	AAM4	M.AIR-4		DEALT -	PANKAJ YADAV				
	6 GAS SERVICE	AVSU6	AAM6	S.AIR-7		CHECKED BY -	BHUPINDER				
	ISOLATION VALVE			VACUUM							
				AGSS							
BED HEAD PANEL			CO2								