

(*)NOTE:
FASTENING LEVEL NECESSARY FOR HIGHEST GUIDES
FITTING AT BOTH SIDES OF HOISTWAY-CUSTOMER








TABLE 1	V (m/s)	ONCDEH
DL > 1000 Kg & 1 ≤ V ≤ 1.75 & CARG = Sliding	V = 1.0	CH+CWTRUNB +905
	V = 1.75	CH+CWTRUNB +1125
DL > 1000 Kg & 1 ≤ V ≤ 1.75 & CARG = Roller	V = 1.0	CH+CWTRUNB +976
	V = 1.75	CH+CWTRUNB +1195

LOAD ON HOOKS		
Nos	KGS	UTILITY
1	1500	CAR GUIDE ROPING
2	1000	LIFTING TOOL & WORKING PLATFORM ROPING
3	1000	CWT RAIL ROPING
4	500	MACHINE ROPING
5	500	MACHINE



PIT REACTIONS (KN)
P12 = 175
P13 = 142

REVISIONS		REVISIONS		REVISIONS	
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED		NOTE :- DO NOT SCALE THIS DRAWING			

APPROVALS		OTIS ELEVATOR CO. (INDIA) LIMITED	
CURRENT CHARACTERISTICS POWER SUPPLY A.C. 400 VOLTS, 3 PHASE 4 WIRES WITH NEUTRAL, 50 HERTZ LIGHT SUPPLY A.C. 230/240 VOLTS. CONFIRMED <u>YES</u>	THIS ARRANGEMENT AND SUPPLEMENTARY NOTES APPROVED BY <u>OWNER</u>	BUILDING ASTA INFRA PROJECTS PRIVATE LIMITED	
	HOISTWAY SIZES GUARANTEED PLUMB WITHIN +50/-0 mm** OF FIGURES SHOWN	LOCATION SECUNDERABAD (TELANGANA)	
	SIGNED <u>YES</u>	OWNER M/s. ASTA INFRA PROJECTS PRIVATE LIMITED	
	DATE <u>31/05/2023</u>	ARCHT.	
		DATE: PRELIM <u>02/06/2023</u>	FINAL <u>02/06/2023</u>
		SCALE <u>-</u>	DRAWN BY <u>KAA</u>
		CHECKED BY <u>SDJ</u>	SALES No. <u>52NK7548</u>
RECORD OF CLT'S DRGS.	THREE SHEETS	DRG. No.	REV.
LAYOUT BASED ON MOF	SHEET <u>THU</u>	52NK7548M	00
REC'D WITH E-MAIL DATE <u>31/05/23</u>			