

Date : 31.10.2023

MGMH_PETLABURZ - 22 HP VRF _Machnes Configuration

S.NO.	floor	ROOM	AREA (sq.ft)	IDU TYPE	PROPOSED TR	SELECTED TR	QTY	TOTAL TR	IDU KW	ODU KW	SELECTED ODU	DIV%
1	THIRD FLOOR	SENIOR FACULTY	130	HI WALL	1.5	1.5	1	1.5	75.0	61.6	22	122%
2		SAMPLE COLLECTION	100	HI WALL	1.0	1.0	1	1.0				
3		ULTRA SOUND	100	HI WALL	1.5	1.5	1	1.5				
4		PRE OPERATIVE WARD	240	4 WAY CASSETTE	1.5	2.0	1	2.0				
5		POST OPERATIVE WARD	210	4 WAY CASSETTE	1.5	2.0	1	2.0				
6		ANESTHESIST ROOM	100	HI WALL	1.0	1.0	1	1.0				
7		EMBRYOLOGIST ROOM	100	HI WALL	1.0	1.0	1	1.0				
8		COUNSELLING ROOM1	100	HI WALL	1.0	1.0	1	1.0				
9		COUNSELLING ROOM2	100	HI WALL	1.0	1.0	1	1.0				
10		WAITING ROOM	60	HI WALL	0.8	0.8	1	0.8				
11		SEMEN COLLECTION ROOM	110	HI WALL	1.0	1.0	1	1.0				
12		ANDROLOGY	310	HI WALL	1.5	1.5	1	1.5				
13		CRYO ROOM	80	HI WALL	0.8	0.8	1	0.8				
14		MAJOR OT	343	HI WALL	1.5	1.5	2	3.0				
15		UPS ROOM	110	HI WALL	1.5	1.5	1	1.5				
TOTAL							16	20.6	75.0	61.6	22	

INDIVIDUAL AC - Machnes Configuration

S.NO.	floor	ROOM	AREA (sq.ft)	IDU TYPE	SELECTED TR	QTY
1	THIRD FLOOR	RECEPTION	110	HI WALL	1.5	1
2		ANDROLOGY	310	HI WALL	1.5	1
3		UPS ROOM	110	HI WALL	1.5	1
					4.5	3