





















LEGEND		ISOLATION VALVE BOX :-		PIPE LINE :-		OUTLETS:-		PURPOSE OF DRAWING :-		<div><div></div><div>MPS ASTA CONSORTIUM</div><div>59, INDU HOUSE RAMA ROAD INDUSTRIAL AREA NEW DELHI-110015 Ph:9810207360,9700961991 Email:sotc.mpsasta@gmail.com</div></div>			
	5 Amp switch & socket	2 GAS SERVICE	AVSU2	AAP2	OXYGEN			DRAWING FOR APPROVAL					
	Isolation valve	3 GAS SERVICE	AVSU3	AAP3	NITROUS OXIDE			SOTC GANDHI HOSPITAL, HYDERABAD					
	Pressure Regulator	4 GAS SERVICE	AVSU4	AAP4	M.AIR-4			SHEET TITLE :-					
WORKING PROCEDURE:		6 GAS SERVICE	AVSU6	AAP6	S.AIR-7			MGPS LAYOUT		SCALE - 1:1		REV . NO 09	SHEET. NO 03
1. MARKING AND SADDLING		ISOLATION VALVE			VACUUM			MAC/SOTC/GANDHI/MGPS/01		DEALT - PANKAJ YADAV			
2. INSTALLATION OF COPPER PIPE, VALVE BOX & ALARMS.		BED HEAD PANEL			AGSS					CHECKED BY - BHUPINDER			
3. PRESSURE TESTING OF COPPER PIPE.					CO2								
4. COLOR CODING .													
5. INSTALLATION OF GAS OUTLETS.													
6. TESTING OF PIPE LINE.													
7. FIXING OF ACCESSORIES.													
8. FINAL TESTING & HAND OVER.													

SCALE -		1:1		REV . NO		SHEET. NO	
DEALT -		PANKAJ YADAV		09		03	
CHECKED BY -		BHUPINDER					