


APPROVED

Sd/- Dt: 28-05-2024 CHIEF ENGINEER (TSMSIDC) **HYDERABAD**

// TRUE COPY //



DEPUTY EXECUTIVE ENGINEER O/O MANAGING DIRECTOR (TGMSIDC) HYDERABAD

Isolation valve Pressure Regulator PIPE LINE :-**OUTLETS:-OXYGEN** NITROUS OXIDE M.AIR-4 S.AIR-7

Important Note:

- 1. ALL INSIDE WALL WILL BE FLUSH TYPE NO PROJECTION ALLOWED.
- 2. THERE WILL BE 2 M WIDE PLATFORM FOR THE LOADING- UNLOADING OF CYLINDER DIRECT FROM THE TRUCK.
- 3. GAS MANIFOLD ROOM 3 WINDOWS WILL BE ABOVE 7 FT FROM THE FLOOR LEVEL INSIDE THE MANIFOLD ROOM.
- 4. THICKNESS OF WALL SHOULD BE 9" MINIMUM.
- 5. THERE SHOULD BE ADEQUATE NUMBERS OF 18" EXHAUST (EF) FANS ABOVE 10 FT CENTER AS SHOWN IN THE DRAWING.
- 6. THERE SHOULD BE CLIMBING STEPS FOR CLIMBING FROM THE ROAD TO THE PLATFORM.
- 7. SPACE OF THE EQUIPMENTS TO BE INSTALLED HAS BEEN INDICATED. 8. THERE WILL BE 2 NO. 2.4 MTR WIDE PERFORATED ROLLING SHUTTER


HAVING 2.4 M HEIGHT FOR ENTRANCE OF EQUIPMENTS.

- 9. $\frac{5}{15}$ AMP SWITCH AND SOCKET REQUIRED FOR ALL AREA ALARM PANELS (AAP) AT HEIGHT OF 6' FROM FFL.
- 11. ALL DIMENSIONS ARE IN MM

CONTRACTOR:-ROAD INDUSTRIAL AREA NEW DELHI-110015 Ph:9810207360,9700961991 MPS ASTA CONSORTIUM Email:sotc.mpsasta@gmail.com PROJECT:-

SOTC GANDHI HOSPITAL, HYDERABAD

SHEET TITLE :-**MGPS MANIFOLD ROOM** DRG. NO.:-



VACUUM

AGSS

CO₂

END USER:

TELANGANA MEDICAL SERVICES & INFRASTRUCTURE DEVELOPMENT

CORPORATION

GANDHI HOSPITAL

INSIDE PLANT ROOM

5 Amp switch & socket

Ø54 MM

Ø28 MM

Ø54 MM Ø42 MM

Ø54 MM

Ø42 MM

Ø28 MM

OXYGEN

N2O

AIR-4 AIR-7

VAC

AGSS

CO₂

LEGEND

PANKAJ YADAV **DEALT** -

REV. NO PAGE . NO

