

PLINTH AREA - 494.84 Sq.M. (5324 Sft.)

APPROVED
Sd/- Dt : 12-07-2023
CHIEF ENGINEER (TSMCID)
HYDERABAD.
// TRUE COPY //

NOTES:-

1. Trap door required in false ceiling 400 x 400 mm at every Floor Isolation Valve
2. 5/15 Amp. switch 7 socket for every Area Alarm below the false ceiling.
3. 5/15 Amp. switch & socket for every Bed Head Panel.

Mode of Insatallation:-

1. Marking and saddling
2. Installation of copper pipe, Valve box & alarms.
3. Pressure testing of copper pipe.
4. Color coding .
5. Installation of gas outlets.
6. Testing of pipe line.
7. Fixing of accessories.
8. final testing & hand over.

LEGEND:

Integrated Area Alarm and Zonal Valve box

2 GAS SERVICE



3 GAS SERVICE



ISOLATION VALVE




BED HEAD PANEL



LEGEND:

PIPE LINE :-

OXYGEN



TRIGAS



CO2



OUTLETS:-



PROJECT :

**IVF CENTER ON FIFTH FLOOR IN
MOTHER & CHILD HEALTH BUILDING
OF
GANDHI HOSPITAL AT
MUSHEERABAD, SECUNDERABAD.
TELANGANA STATE**

TITLE :

**PRELIMINARY
ARCHITECTURAL DRAWING**

CONTRACTOR :

ASTA VARDHMAN CONSORTIUM

**PLOT NO. 27, 8-2-334/27,
AVENUE -7 , ROAD NO. 3,
BANJARAHILLS, HYDERABAD.**

CLIENT :

**TELANGANA STATE MEDICAL
SERVICES AND INFRASTRUCTURE
DEVELOPMENT CORPORATION.**

DRG. NO. :-

LSS/IVF/HYDRABAD-01

SUB CONTRACTOR :-

**LSS ENGINEERING
434/1, Firni Road, Mundka
New Delhi - 110041**

DATE - 03/09/2023

SCALE - NTS

DEALT - MK PATEL

CHECKED BY - T.A.

REV . NO

00

SHEET. NO

01

Dv. EXECUTIVE ENGINEER