

ELECTRICAL EQUIPMENT SCHEDULE (UPDATE)

LOCATION : SAHIL CDS SUBSTATION NO.2

HOLD:

1	Tag Number
2	Drawing/ Document Number

REVISIONS						EPC CONTRACTOR ROBT STONE (ME) L.L.C., Abu Dhabi 			 أدنوك ADNOC	
REV	DATE	BY	CH'D	APP'D	DESCRIPTION					
A	29-07-2024	AK	SR	TE		DRAWING No.				
						PROJECT TITLE		LOCATION		PROJ. No.
						EPC FOR UPGRADATION OF FACILITIES AT SE FIELD		SAHIL SS2		P30255
						ELECTRICAL EQUIPMENT SCHEDULE(UPDATE) SAHIL CDS SUBSTATION NO.2				
						Doc No.: 16-01-63-1613		Class: 2	Rev. A	SHT. 01 OF 03



NOTES:		REFERENCE DOCUMENTS	
1	THIS SCHEDULE INCLUDES ALL THE TAGGED ITEMS IN SUBSTATION 2 IN SAHIL AREA .		P30255-16-99-56-XXXX - KEY SLD(INSTALLATION) FOR SAHIL: CDS
2	DETAILS WILL BE FURNISHED LATTER. later?		P30255-16-01-59-1644 - ELECTRICAL EQUIPMENT LAYOUT SUBSTATON NO 2 SAHIL CDS
			P30255-16-01-56-1602 - SINGLE LINE DIAGRAM FOR 11kV SWITCHGEAR (INSTALLATION) SAHIL : SUBSTATION 2 - CDS
			P30255-16-01-56-1603 - SINGLE LINE DIAGRAM FOR 415V NORMAL SWITCHGEAR (16-01-MSWG-XXXX) SAHIL : 415V - SUBSTATION 2 - CDS SAHIL
			P30255-16-01-56-1607 - SINGLE LINE DIAGRAM UPS-4502 : 125V DC UPS (UPDATE) SUBSTATION No.2 - SAHIL
			P30255-16-99-54-XXXX - DATASHEET FOR 11kV AIR INSULATED SWITCHGEAR(AIS)-SAHIL
			P30255-16-99-54-XXXX - DATASHEET FOR 415V SWITCHGEAR SAHIL
		update	P30255-16-99-54-XXXX - DATASHEET FOR 33/11.5kV POWER TRANSFORMER:SAHIL
			P30255-16-99-54-XXXX - DATASHEET FOR 11/0.433kV DISTRIBUTION TRANSFORMER(CONSEVATOR TYPE)
			P30255-30-99-54-1607 - DATASHEET FOR DISTRIBUTION BOARD (SAFE AREA)
			P30255-16-99-54-XXXX - DATASHEET FOR 125V DC UPS:SAHIL

	DOCUMENT TITLE:		ADNOC DOCUMENT NO:				
	ELECTRICAL EQUIPMENT SCHEULE SAHIL CDS SS2		16-01-63-1613				
	PROJECT TITLE:		SHEET 02 OF 03				
	EPC FOR UPGRADATION OF FACILITIES AT SE FIELD		REV	A	DATE	7/29/2024	
		ADNOC PROJECT NO: P30255					

GEOGRAPHICAL LOCATION		TAG NUMBER				DESCRIPTION	MANUFACTURER		LOCATION	POWER SUPPLY / RATING	DATA SHEET No.	REFERENCE DOCUMENT No.	TAG REV.	DATE	NOTES	
AREA	PLANT AREA	EQPT. CODE	SYS. CODE	UNIT No.	SEQ. No.		NAME	SERIAL NUMBER								
SAHIL SS2 INSTALLATION SCOPE																
16	01	HSWG	43	06	xx	11kV SWITCHGEAR	NOTE-2	NOTE-2	SWITCHGEAR ROOM	11kV, 3Ph, 3 Wire, 50Hz, 1600A, 31.5kA for 3 sec	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	MSWG	44	20	xx	415V SWITCHGEAR	NOTE-2	NOTE-2	SWITCHGEAR ROOM	415V, 3Ph, 4 Wire, 50 Hz, 1600A, 50 kA for 1 sec	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	RTCP	43	05	xx	RTCC PANEL FOR TRANSFORMER -1	NOTE-2	NOTE-2	SWITCHGEAR ROOM	NOTE-2	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	RTCP	43	06	xx	RTCC PANEL FOR TRANSFORMER -2	NOTE-2	NOTE-2	SWITCHGEAR ROOM	NOTE-2	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	TP	43	19	xx	POWER TRANSFORMER -01	NOTE-2	NOTE-2	TRANSFORMER SHED	33/11.5kV, 20/25MVA,ONAN/ONAF,Dyn11 Z-10.0%	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	TP	43	20	xx	POWER TRANSFORMER -02	NOTE-2	all transformer and switchgear ratings are subject to calculations and power system studies based verification- update in next revision after submission of the calculations and Rev A of Power system studies		33/11.5kV, 20/25MVA,ONAN/ONAF,Dyn11 Z=10.0%	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	TP	44	37	xx	DISTRIBUTION TRANSFORMER-01	NOTE-2			11/0.433kV, 1MVA, ONAN, Dyn11, z=5%	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	TP	44	38	xx	DISTRIBUTION TRANSFOMER -02	NOTE-2			11/0.433kV, 1MVA, ONAN, Dyn11, z=5%	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	NER	43	03	01	NEUTRAL EARTH RESISTOR -01	NOTE-2			11kV, 400A for 10s, 40A continous, 630A Isolation switch	-	REFER SHEET NO.2	A	28/06/2024	-	
16	01	NER	43	04	01	NEUTRAL EARTH RESISTOR -02	NOTE-2			11kV 400A for 10s 40A continous, 630A Isolation switch	-	REFER SHEET NO.2	A	28/06/2024	-	
16	01	ECP	49	01	xx	SCMS INTERFACE CABINET	NOTE-2			NOTE-2	-	REFER SHEET NO.2	A	28/06/2024	-	
16	01	DB	44	48	xx	MDB (EMERGENCY PANEL)	NOTE-2		NOTE-2	SWITCHGEAR ROOM	415V, 315A, 3Ph, 4w, 20 kA for 1 sec	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-
16	01	DB	44	44	xx	AUXILIARY DB	NOTE-2		NOTE-2	SWITCHGEAR ROOM	415V, 63A, 3Ph, 4w, 10 kA for 1 sec	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-
16	01	UPS	45	02	xx	125V DC UPS MODIFICATION	NOTE-2	NOTE-2	SWITCHGEAR ROOM	125V DC	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	
16	01	DB	45	02	xx	125V DC DB MODIFICATION	NOTE-2	NOTE-2	SWITCHGEAR ROOM	125V DC	REFER SHEET NO.2	REFER SHEET NO.2	A	28/06/2024	-	

all transformer and switchgear ratings are subject to calculations and power system studies based verification- update in next revision after submission of the calculations and Rev A of Power system studies

GEOGRAPHICAL LOCATION		TAG NUMBER				DESCRIPTION	MANUFACTURER		LOCATION	POWER SUPPLY / RATING	DATA SHEET No.	REFERENCE DOCUMENT No.	TAG REV.	DATE	NOTES
AREA	PLANT AREA	EQPT. CODE	SYS. CODE	UNIT No.	SEQ. No.		NAME	SERIAL NUMBER							