

RPL SPILL RESPONSE

STOP · CONTAIN · REPORT

RPL-ENV-PRO-005 App-B | Large type — post in truck cab | Uncontrolled when printed

1 STOP — SAFE?

Electrical hazard? → Stay back.
Call DCC: 1-800-555-0177
Confirm de-energization before approaching.

2 ISOLATE the source

Close valve / plug / apply pressure.
DO NOT approach energized equipment.

3 CONTAIN the spill

Deploy 20-gal truck kit:
Drain covers FIRST
Sock around perimeter
Pads on spill body
DO NOT wash with water. NO dispersant.

4 CALL DCC within 30 min

Phone: 1-800-555-0177
Provide: name · location (GPS/address/county)
equipment type · WAM asset ID
estimated gal · substance · PCB label color

5 PHOTOGRAPH & COMPLETE FORM

Photos before & after containment.
Upload to EHS-IMS.
Complete EHS-F-201 Parts A–D
(at scene or within 2 hours).

PCB LABEL: BLUE = non-PCB (NP-T/NP-M) YELLOW = PCB No label = treat as PCB (UNK)

NOTE: On-call ENV Specialist decides reportability — provide facts only, do not state reportable/not.

EMERGENCY CONTACTS

DCC (24/7):	1-800-555-0177
ENV-ONCALL:	Page through DCC / OMS group ENV-ONCALL
IDEM Emergency (backup only):	(888) 233-7745
Emergency / Fire:	911
EHS-F-201 location:	Truck glove box / Service center EHS station