



Procedure #10

Prepared by:
Andy Gomes**Approved by:**
Clive Baek**Revised Date:** March 2026**Original Date:** January 2017**BOOSTER PUMP STRAINER CLEANING PROCEDURE**

The booster pump suction-side strainers are to be blown weekly. Monthly, the strainers need to be removed and given a proper cleaning and washing. Only one booster pump can be taken out of service at a time while the other must remain in service. This is to provide the feedwater pumps with the required positive suction head pressure.

Booster Pump Strainer Removal and Cleaning			
Step	Operation	Initial when Complete	Date and Time when Complete
1	Shutdown the booster pump that is to be flushed. (Verify the in-service pump is operating as required.)		
2	Isolate and lockout the booster pump power, suction valve, discharge valve, and recirculation valve in accordance with UBC's Lockout Procedure.		
3	Drain the water in the strainer by opening the strainer drain valve.		
4	Remove the strainer.		
5	Wash and clean the strainer at the chemical testing bench.		
6	Replace the strainer.		
7	Remove the lockout.		
8	Return the pump to service.		
9	Repeat steps 1 through 8 for the other booster pump.		
10	Make an appropriate log book entry.		
End of Procedure			