



Procedure #8

Prepared by:
Andy Gomes**Approved by:**
Clive Baek**Review Date:** March 2026**Original Date:** January 2017

CLEAVER BROOKS MUD DRUM BLOWDOWN PROCEDURE

Blowing down the mud drum removes suspended solids from the boiler that have collected in the mud drum.

ASSUMPTIONS:

- Mud drum blow down is initiated when the boiler is being prepared for an outage.
- Blow down tank quench water is in service and blow down tank drain valves are closed.

Step	Operation	Initial when Complete	Date and Time when Complete
1	Check that the blow down tank cooling water supply valve is open.		
2	Make sure all valves are in the proper position for blowing down the C.B. Boiler and no drain valves in the line are open to the sewer.		
Note: There are two valves in the Cleaver-Brooks blow down line, located on the front of the mud drum. One is a fast acting valve, located closest to the mud drum and the other is a slow acting valve, located down-stream of the fast-acting valve.			
3	Open the fast acting valve.		
4	Slowly open the slow acting valve. Keep this valve open for about 2-3 seconds .		
5	Close the slow acting valve.		
6	Close the fast acting valve.		
7	Make an appropriate log book entry.		
Note: It is important to open and close these valves in this manner to avoid putting stress, resulting in increased wear, on the fast acting valve.			