

EPICS Support for OPC UA – Cheat Sheet

Concepts

A *Session* is a named connection between client and server (*0..n per IOC*).

Any piece of data on the server is called an *Item*, which is accessed through its *NodeID*, consisting of a numerical *namespace index* and a *name* or *numerical ID*.

To monitor (subscribe to) items, they are added to a *Subscription* (*0..n per Session*).

Initialization from startup script

```
opcuaCreateSession <name> <server URL> [<debug> [<autoconnect>]]
```

Create a new session.

name	Name of the session to create
server URL	URL of the OPC UA server to connect to
debug	Initial level of debugging [def: 0 = off]
autoconnect	Automatically connect/reconnect to server [def: y]

```
opcuaSetOption <session> <option name> <value>
```

Set session specific options.

session	Name of the session to configure
option name	Name of the option to configure
value	Value for the specified option

Currently supported options for the Unified Automation SDK client:

batch-nodes	Maximum number of nodes per low-level service call
-------------	--

```
opcuaCreateSubscription <name> <session> <interval> [<priority> [<debug>]]
```

Create a new subscription.

name	Name of the subscription to create
session	Name of the session this subscription is related to
interval	Publishing interval for the subscription in ms [double]
priority	Priority of the subscription [0..255; def: 0 = lowest]
debug	Initial level of debugging [def: 0 = off]

Database configuration

All OPC UA related records use the setting DTYP = "OPCUA".

Periodic SCAN settings will create a "polling" behavior, which is not suggested for OPC UA. Instead, items should be monitored for changes by connecting them to a subscription and setting SCAN = "I/O Intr".

Simple setup: one item, one record, no structures

In addition to DTYP and SCAN, the link in the INP/OUT fields must be set.

@<name> ns=<namespace>;s=<identifierString> [<option>=<value>...]

@<name> ns=<namespace>;i=<identifierNumber> [<option>=<value>...]

name	Name of the subscription or session
namespace	Namespace index number of the NodeID
identifierString	Name (string identifier) of the node
identifierNumber	Numerical identifier of the node

Supported options are:

sampling	Sampling interval in ms [double; def: -1 = use publishing interval]
qsize	Size of server side queue [def: 1 = no queueing]
discard	Discard policy on queue overrun [old/new; def: old = drop oldest]
timestamp	Timestamp source [server/source; def: server]
monitor	Set up monitor (output record gets bidirectional) [y/n; def: y]

Full setup: one itemRecord, multiple connected data records

For each item, an itemRecord instance is created. Its INP link follows the definition from the simple setup shown above.

All connected data records define their INP/OUT links to point to the itemRecord.

@<item> [<option>=<value>...]

item	Name of the itemRecord this data record is connected to
------	---

Supported options are:

element	Path of the data record's element inside the item's structure ["." = hierarchy separator; "" = root element in case of no structure]
timestamp	Timestamp source [server/source; def: server]
monitor	Set up monitor (output record gets bidirectional) [y/n; def: y]

Example

With the following setup in the IOC startup script

```
opcuaCreateSession PLC opc.tcp://192.168.1.145:4840
opcuaCreateSubscription SUB1 PLC 100
```

Database records might look like this.

```
record(longin, "OPC:li1") {
    field(DTYP, "OPCUA")
    field(INP, "@SUB1 ns=3;s=\"Data_block_1\".\"myInt\"")
    field(SCAN, "I/O Intr")
}
record(ao, "OPC:ao1") {
    field(DTYP, "OPCUA")
    field(OUT, "@PLC ns=3;s=\"Data_block_1\".\"myDouble\" monitor=n")
}
record(ao, "OPC:ao2") {
    field(DTYP, "OPCUA")
    field(OUT, "@SUB1 ns=3;s=\"Data_block_1\".\"myDouble\"")
}

record(opcuaItem, "OPC:item1") {
    field(INP, "@SUB1 ns=3;s=\"Data_block_1\".\"myStruct\"")
    field(SCAN, "I/O Intr")
}
record(longin, "OPC:sli1") {
    field(DTYP, "OPCUA")
    field(INP, "@OPC:item1 element=Int1")
    field(SCAN, "I/O Intr")
}
record(ai, "OPC:sai1") {
    field(DTYP, "OPCUA")
    field(INP, "@OPC:item1 element=sub2.sub21.Double1")
    field(SCAN, "I/O Intr")
}
```

The first three records use the simple setup. While OPC:ao1 is bound to the session and is only writing, OPC:ao2 is monitored, i.e. bound to a subscription and being updated if the value changes on the PLC.

The lower three records show a full setup. The itemRecord OPC:item1 is connecting to a structured item, and the two data records are connected the itemRecord, pointing to elements of its structure at different hierarchy levels.

The unusual node identifiers in the example (containing quote characters that have to be escaped) are the default naming used by TIA Portal for an S7-1500 series PLC.