SOP — Centrifugal Pump Maintenance

Document ID: APEL-SOP-MNT-211 | Owner: Maintenance | Revision: 6.9

This page defines the task-specific controls for preparation.

Preparation

- Review asset history.
- Confirm spares.
- Verify isolation.
- Check lifting requirements.
- Conduct toolbox talk.

Mechanical inspection

This page defines the task-specific controls for mechanical inspection.

Mechanical inspection

- Coupling
- Shaft alignment
- Bearings
- Mechanical seal
- Casing
- Baseplate and anchors

Alignment

This page defines the task-specific controls for alignment.

Alignment

- Use calibrated tools.
- Check soft foot.
- Record shim changes.
- Torque critical fasteners to specification.

Post-maintenance test

This page defines the task-specific controls for post-maintenance test.

Post-maintenance test

- Discharge pressure
- Flow
- Bearing temperature
- Vibration
- Seal leakage

Closeout

This page defines the task-specific controls for closeout.

Closeout

- Record parts consumed.
- Capture failure mode.
- Store before/after measurements.
- Create follow-up work if needed.
- Supervisor review.