Standard Operating Procedure: Field Instrument Failure & Voting Overrides

Document ID:	SOP-OPS-204	**Effective Date:**	2026-08-01
Revision:	2.5	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Instrumentation & Operations	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Purpose

Protocol for managing instrument transmitter drift, signal freezing, and 2oo3 voting disagreements (e.g. INC-2026-004).

2. Step-by-Step Procedure

1. Verify sensor reading against redundant channel and independent gauge.
2. Place affected control loop into DCS Manual mode.
3. Apply documented safety override with Shift Supervisor written concurrence.
4. Mobilize I&C; technician for field zero and span verification.