Standard Operating Procedure: Refinery Total Power & Utility Interruption

Document ID:	SOP-OPS-206	**Effective Date:**	2026-08-01
Revision:	4.0	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Refinery Shift Management	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Purpose

Emergency islanding and safe unit shutdown under total electrical grid trip.

2. Step-by-Step Procedure

1. Confirm emergency diesel generators (EDG) energized critical UPS buses.
2. Ensure instrument air pressure maintained via backup accumulator tanks.
3. Execute automated furnace fuel gas shutdown trip.
4. Align flare header snuffing steam to maintain water seals.