SOP — CDU-4 Startup Sequence

Document ID: APEL-SOP-OPS-201 | Owner: Operations | Revision: 9.1

This page defines the task-specific controls for pre-start readiness.

Pre-start readiness

- Confirm maintenance handback.
- Verify utilities.
- Check current line-up.
- Review permits.
- Confirm control-room/field communications.

Warm-up sequence

This page defines the task-specific controls for warm-up sequence.

Warm-up sequence

- Establish circulation.
- Begin controlled heating.
- Stabilize column pressure.
- Introduce crude at reduced rate.
- Increase feed in planned steps.

Monitoring points

This page defines the task-specific controls for monitoring points.

Monitoring points

- Furnace outlet temperature
- Column pressure
- Feed flow
- Desalter differential pressure
- Reflux stability

Hold conditions

This page defines the task-specific controls for hold conditions.

Hold conditions

- Loss of instrument air
- Unstable pressure
- Hydrocarbon leak
- Critical instrument failure
- Utility instability

Handover

This page defines the task-specific controls for handover.

Handover

- Record startup time.
- Record deviations.
- Remove/control temporary overrides.
- Transfer stable operation to normal monitoring.