Standard Operating Procedure: Hydrogen Compressor Anti-Surge Response

Document ID:	SOP-OPS-202	**Effective Date:**	2026-08-01
Revision:	2.1	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Operations HCU-1	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Purpose

Prescribes actions to prevent and recover from aerodynamic surge events on hydrogen recycle compressor C-301.

2. Step-by-Step Procedure

1. Confirm anti-surge controller UIC-301 operating mode (ensure Auto Tracking).
2. If surge alarm activates, manually open recycle valve FCV-301 to 50% open.
3. Verify seal gas differential pressure remains > 3.0 bar.
4. Stabilize suction drum level to prevent liquid carryover.