Standard Operating Procedure: Emergency Response to Cooling Water Loss

Document ID:	SOP-OPS-205	**Effective Date:**	2026-08-01
Revision:	3.0	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Refinery Operations	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Purpose

Response to sudden cooling water supply pressure collapse on primary headers.

2. Step-by-Step Procedure

1. Verify auto-start of standby diesel/turbine cooling water pumps P-205B/C.
2. Reduce refinery crude charge rate by 30% immediately to shed thermal load.
3. Maximize air fin cooler fans across distillation tower overheads.
4. Monitor compressor jacket temperatures; trip compressors if jacket temp > 85 °C.