Standard Operating Procedure: Emergency Battery Limit Unit Isolation

Document ID:	SOP-SAF-208	**Effective Date:**	2026-08-01
Revision:	3.2	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Safety & Emergency Response	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Purpose

Activation of emergency shutdown valves (MOV/XV) to isolate CDU-4 or HCU-1 during major fire or vapor release.

2. Step-by-Step Procedure

1. Shift supervisor triggers master Emergency Depressuring (EDP) pushbutton.
2. Verify closing confirmation of suction isolation valve XV-410 within 12 seconds.
3. Activate perimeter deluge curtain around crude transfer pump bays.
4. Confirm all fuel gas feeds isolated to fired heaters.