P-102 Inspection Report — 2026

Document ID: APEL-INS-P102-2026 | Owner: Inspection & Integrity | Revision: 1.0

This dated record evaluates P-102 crude-transfer service.

Identity

Field	Value
Asset	P-102
Unit	CDU-4
Date	2026-07-15
Criticality	HIGH
WO	WO-6021

2026 measurements

The recorded measurements support later trend analysis.

Measured values

Parameter	Value	Unit
Pressure	42.0	bar
Corrosion	3.8	mm
Vibration	7.2	mm/s
Seal temperature	84	°C

2026 condition findings

The inspector records condition without extending the evidence.

Findings

- Pressure above approved limit; corrosion and vibration require engineering review.
- External observation does not establish internal structural condition.
- Record is linked to the work order.

2026 historical context

Pressure change +5.0 bar; corrosion change +1.4 mm; vibration change +1.9 mm/s.

Series

- Pressure: 34 → 37 → 42 bar.
- Corrosion: 1.2 → 2.4 → 3.8 mm.
- Vibration: 4.1 → 5.3 → 7.2 mm/s.

2026 recommendation

The recommendation states the next action supported at that date.

Disposition

- Open engineering integrity review, verify instrumentation and establish authorized operating disposition.
- This report is not a final fitness-for-service decision.
- Owner: Inspection & Integrity.