Incident Report — PT-102 Indication Disagreement — 2026

Document ID: APEL-INC-2026-004 | Owner: HSE / Instrumentation | Revision: 1.2

During the July 2026 P-102 review, PT-102 disagreed with a temporary local gauge.

Facts

Date	16 Jul 2026
Asset	PT-102 / P-102
Issue	Indication disagreement
Consequence	No injury; disposition paused

Containment

The team did not choose the lower value simply because it reduced the apparent deviation.

Actions

- Hold final disposition.
- Request calibration verification.
- Compare independent indication.
- Preserve both readings.

Instrumentation review

Instrumentation examined calibration status and the measurement path.

Review items

- Calibration status
- Impulse line
- Independent gauge
- Signal configuration
- Timestamp consistency

Technical significance

Measurement uncertainty matters when a threshold decision depends on one instrument.

AI behavior

- Report disagreement.
- Identify sources.
- Retrieve instrument procedure.
- Do not silently choose one.
- Escalate uncertainty.

Closure

The event closes when the accepted measurement basis is documented.

Required fields

- Instrument ID
- Calibration result
- Independent comparison
- Accepted value
- Reviewer
- Closure date