Abnormal Situation Management (ASM) & Transient Response Manual

Document ID:	APEL-MAN-OPS-102	**Effective Date:**	2026-08-01
Revision:	3.0	**Classification:**	CONFIDENTIAL - STRICT PROPRIETARY
Department:	Operations & Process Safety	**Site Location:**	Jamnagar Refinery Complex (JRC)

1. Operational Upset Classification

Defines tiering of process abnormalities: Tier 1 (Self-correcting minor drift), Tier 2 (Significant deviation requiring operator intervention), Tier 3 (Emergency unit trip condition).

2. Response Sequence for Hydraulic Surges

In the event of rapid discharge pressure fluctuations on primary transfer pumps (e.g. P-102), operators must immediately confirm true pressure via field mechanical gauge PG-102 before adjusting downstream bypass valves.

3. Safe Operating Limit Violation Protocol

If any rotating machine exceeds Zone D vibration or casing pressure rating, console operator possesses non-negotiable authority to trip equipment without prior supervisory permission.