SOP — Pump Condition Monitoring

Document ID: APEL-SOP-INS-221 | Owner: Inspection & Integrity | Revision: 5.3

This page defines the task-specific controls for monitoring philosophy.

Monitoring philosophy

- Use trends rather than isolated numbers.
- Combine process and mechanical indicators.
- Link readings to asset IDs.

P-102 thresholds

This page defines the task-specific controls for p-102 thresholds.

P-102 thresholds

Parameter	Normal	Review	Immediate
Pressure	≤40 bar	>40 bar	>45 bar
Vibration	<4 mm/s	4–7 mm/s	>7 mm/s
Corrosion	<2 mm	2–3 mm	>3 mm

Trend interpretation

This page defines the task-specific controls for trend interpretation.

Trend interpretation

- 2024 pressure 34 bar; 2025 37 bar; 2026 42 bar.
- 2024 corrosion 1.2 mm; 2025 2.4 mm; 2026 3.8 mm.
- 2024 vibration 4.1; 2025 5.3; 2026 7.2 mm/s.

Evidence package

This page defines the task-specific controls for evidence package.

Evidence package

- Current measurement
- Instrument verification
- Historical trend
- Photograph
- Maintenance history
- Applicable SOP

Disposition

This page defines the task-specific controls for disposition.

Disposition

• P-102 is HIGH criticality.

• 2026 crosses multiple review triggers.

• Engineering determines final disposition.