

Lock-out and Tag-out devices and equipment

Designation	Description (diagram, photos, etc.)	Functioning
No Voltage checker		A NVC, or No Voltage Checker is a device that allows to check after the electrical installation has been cut off that it is indeed cut off, by checking that there is indeed no more tension. This is a specific function, not to be confused with simple voltage detection or voltage measurement.
Insulating pole with voltage detector		Pole with flashing voltage detector for checking the absence of voltage before earthing a line or a transformer for carrying out work in MV substations or cells.
Universal Valve Locking System		
Electric locking system		
Mechanical locking system		

Note: the photos used above are photos taken from suppliers' presentation documents.

Points of vigilance: The colors of the padlocks used in the photos may not correspond to the colors used for identification.

Designation	Description (diagram, photos, etc.)	Functioning
Lockout padlock		The lockout padlock ensures the closure of the lockout equipment. A color-coded system identifies the type of consignment, as example: Red: electrical lockout. Blue: pneumatic lockout. Green: water deposit. Yellow: gas lockout. Orange: hydraulic lockout. Black: mechanical lockout.
Named security padlock		A unique key is provided with each padlock. The key will not be removed if the padlock shackle is not properly engaged. Each padlock is customizable. The color of the security name padlock is different from the colors of the security padlocks.
Safety Lockout Hasps		Allows multiple stakeholders to condemn a single energy source.
Lock-out box		After the isolation of the work equipment, the lock-out key(s) are placed in a lockout box. Each approved member of the work team places an individual padlock or lockout device in the group lockout box.
Wall lock out box		Same as group lock out box, wall mounted with a slot on the front of the box for keys on the top.