

1.0 SCOPE

This engineering standard specification contains specific requirements for selection of material & dimensional data to be used in the fabrication of bare & hot insulation supports. It includes requirements for various types of supports on bare & hot insulated pipe. The standard pipe support consists of the following sections:

- 1.1 List of standard pipe supports and the detail drawings – sheet D-1 to D-134.
- 1.2 List of standard pipe support components and detail drawings-sheets M-1 to M-60.
- 1.3 The pipe support components are used for building up pipe supports. The dimensions and applicable size are shown in the detail drawings.

2.0 DESIGN CRITERIA FOR ALL SUPPORTS

- 2.1 Miscellaneous structure steel is to be designed in accordance with "Manual of Steel Construction" – American Institute of Steel Construction Inc. (AISC) Specification.
- 2.2 All other components of pipe supports shall conform to the latest requirements of ASME B31.3, Code of Process Piping and Manufacturer's Standardization Society (MSS) Standard Practice SP-58 & SP-69.
- 2.3 One assembly to be furnished for each support number unless otherwise specified.
- 2.4 All assemblies to be shop welded unless marked for field welding.
- 2.5 Each assembly to be shipped, completely fabricated and assembled.
- 2.6 All threaded parts are RH unless marked LH.
- 2.7 Field to modify grating or handrails to accommodate hangers and supports where required.
- 2.8 All bolt holes are 3 mm larger than bolt diameter.
- 2.9 All materials are carbon steel unless otherwise specified.
- 2.10 For carbon steel lines 24" and smaller, the reinforcing pad materials are cut from the pipe. for lines 26" and larger, the reinforcing pad are fabricated from plates in field.
- 2.11 The reinforcing pad materials of alloy steel, stainless steel & stress relief lines shall be same materials as main line, and it shall be fabricated together with main lines in shop.
- 2.12 The dimensional tolerences in fabricated pipe hangers and supports shall conform to the requirements in MSS SP-89 SEC. 4.0.

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD.						ENGINEERING STANDARD	
						HP6-DSD-A4-500-001	
BY	SHIH		CHK.	YANG		SELECTION PRACTICE	
DATE	7/15/'24		APPR.	CHEN			
						P-1	REV. 1

FILE: P1-1M.DWG