

3.0 MATERIAL SPECIFICATIONS DESIGNATED AS :

		TEMP. RANGE(°C)		
C.S. Plate	ASTM A283 Grade C	-29	TO	399
C.S. Bar	ASTM A36 Hot Rolled		”	
C.S. Rod	ASTM A36 Hot Rolled		”	
C.S. Forging	ASTM A668 Grade B Annealed		”	
C.S. Bolting	ASTM A307 Grade B/A563 Grade A	-29	TO	260
C.S. Pipe	ASTM A53 Grade B E.R.W	-29	TO	399
Alloy Plate	ASTM A387 Grade 22 Annealed	-29	TO	621
Alloy Bolting	ASTM A193 Grade B7/A194 Grade 2H Nut	-29	TO	538
Alloy Pipe	ASTM A335 Grade P22	-29	TO	621
Stainless Plate	ASTM A240 Grade 304	-254	TO	649
Stainless Bolting	ASTM A193 Grade B8/A194 Grade 8 Nut		”	
Stainless Pipe	ASTM A312 Grade TP304		”	
Bolt for Structure	ASTM A325	-29	TO	343
Steel				
C.S. Plate	ASTM A516 Grade 60 Impact Tested	-45	TO	-29
(COLD SERVICE)				
Structural Steel	ASTM A36 or Equal			

4.0 PIPE SUPPORT DRAFTING PROCEDURE

4.1 The numbering system for pipe supports shall be as follows :

4.1.1 The numbering system for standard pipe supports shall be in accordance with standard type dwgs.

4.1.2 Special pipe support number shall be designated by the following rule :



- * PS – Denotes general special support
- VSH – Denotes variable spring support
- CSH – Denotes constant spring support
- HSN – Denotes hydraulic snubber support
- MSN – Denotes mechanical snubber support
- STR – Denotes strut support
- SWB – Denotes sway brace support
- TPS – Denotes temporary special support

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD.						ENGINEERING STANDARD	
						HP6-DSD-A4-500-001	
BY	SHIH		CHK.	YANG		P-2	
DATE	7/15/'24		APPR.	CHEN			
SELECTION PRACTICE						REV.	
						1	

FILE: P1-2M.DWG