



4.0 PIPE SUPPORT DRAFTING PROCEDURE (Cont'd)


4.2.5 Pipe Support at Elbow



4.2.6 Trunnion for Vertical Pipe



4.2.7 Trunnion at Elbow



4.3 Elevation of pipe support shall be shown on piping support location plan. The indicated elevation shall be the top elevation of the supporting beam.

FILE: P1-4M.DWG

|                                                            |          |  |       |      |  |                    |  |                      |           |
|------------------------------------------------------------|----------|--|-------|------|--|--------------------|--|----------------------|-----------|
| 中威工程顧問股份有限公司<br>CHUNG WEI ENGINEERING CONSULTING CO., LTD. |          |  |       |      |  | SELECTION PRACTICE |  | ENGINEERING STANDARD |           |
|                                                            |          |  |       |      |  |                    |  | HP6-DSD-A4-500-001   |           |
| BY                                                         | SHIH     |  | CHK.  | YANG |  |                    |  | P-4                  | REV.<br>1 |
| DATE                                                       | 7/15/'24 |  | APPR. | CHEN |  |                    |  |                      |           |